



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 43-98-E Vol.3

Manufacturer: Alliance Laundry Systems LLC, Shepard Street, P.O. Box 990, Ripon, Wisconsin 54971-0990

Trade Name(s): Unimac, Huebsch, Speed Queen, Ajax, Private Labeled Models

Product: Commercial Steam Clothes Dryers

Pertinent Code Section(s): 27-792

Prescribed Test(s): RS 14-6 (UL 1240)

Laboratory: Underwriters Laboratories Inc., and CSA International

Test Report(s): UL file E189503, dated February 6, 9, 10 and 11, 1998, CSA 1204349, 1251142, and 1273737 dated April 5, 2002

Description: - Commercial, steam heated clothes dryers, designed for commercial and coin-operated usage for high and low pressure application. Steam pressure must be provided from an external source, not part of this application. Variations include electro-mechanical and electronic controls. Unit consists of solenoid operated steam valve, blower, regulating thermostat and limit controls. Units with model numbers and ratings are listed below.

Model Number	Nominal Pressure	Heating Capacity BHP/Hr
(AT, ST, HT, UT, MT, NT, YT, ZT)025S	125	3.0
(AT, ST, HT, UT, MT, NT, YT, ZT)030S	125	3.0
(AT, ST, HT, UT, MT, NT, YT, ZT)035S	125	3.4

(AT, ST, HT, UT, MT, NT, YT, ZT)T30S	125	4.6 (Per Pocket)
(AT, ST, HT, UT, MT, NT, YT, ZT)050S	125	4.6
(AT, ST, HT, UT, MT, NT, YT, ZT)075S	125	4.6
(AT, ST, HT, UT, MT, NT, YT, ZT)120S	125	10.0
(AT, ST, HT, UT, MT, NT, YT, ZT)170S	125	15.0

- Notes:**
- Application and Installation Precautions may be installed on a combustible floor. Application is suitable for water-washed fabrics only.
 - Clearance requirements:**
Top and sides – 0 inches; Rear – 24 inches minimum from back of dryer, 36 inches suggested for service; Front – 28 inches minimum for door opening.

Terms and Conditions: The above described steam heated clothes dryer, installed as per clearances to combustible construction specified above, be accepted for use under the following conditions:

- All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped and delivered is equivalent to those tested and accepted for use, as provided in Section 27-131 of the Building Code.
- Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance May 11, 2006
Examined By Simon Derphinder