



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 441-06-E

Manufacturer: Cleveland Range LLC, 1333 East 179th Street, Cleveland, Ohio 44110

Trade Name(s): Cleveland

Product: Gas-fired steamer

Pertinent Code Section(s): 27-800, 27-826, RS 15.1 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.11)

Laboratory: CSA International

Test Report(s): File No. 156602-1754870, dated June 16, 2006

Description: Gas steam generators, as tabulated below. Unit is comprised of main burner, pilot burner, safety valves, gas and pressure control devices. The design has a continuous ignition system.

Steam Boiler/ Steam Generator	Max. Input Heat Rating (BTUH)
22CGT3	45,000
22CGT6	62,000

Terms and Conditions: The above gas-fired steamers are accepted under the following conditions:

1. Units shall use only natural gas.
2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code.
3. Units shall have a fire-suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The fire-suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
4. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
5. The installation shall not interfere with accessibility for operation and servicing.
6. For grease removal, suitable baffle type grease filters, MEA-accepted, shall be installed.
7. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
8. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
9. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 11/22/06

Examined By Shyam R D