



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 45-07-E

**Manufacturer:** Frymaster, L.L.C, 8700 Line Avenue, Shreveport, LA 71106

**Trade Name(s):** Super Runner Electric Fryer

**Product:** Commercial electric fryer

**Pertinent Code Section(s):** 27-777(d), 27-787, 27-792, RS 13-2, 3

**Prescribed Test(s):** RS 14-6 (UL 197)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File No. E44571, Vol. 2, Section 1, dated November 11, 2004.

**Description:** A single free-standing 40 lb. electric fryer designed for cooking all types of deep-fried food products. The single unit measures 15.7 inches wide, 27.2 inches deep and 44 inches high.

**Product Covered:** Model No. SR14, 14kW

**Terms and Conditions:** The above-described commercial electric fryer is accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical and Building Code requirements.
2. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Units shall be installed under hoods that vent to the outside, comply with Reference Standards RS 13 and RS 13-3, and shall be fitted with open heads that are capable of simultaneous discharge and manual release. The fire suppression system, exclusively used for cooking equipment, shall be filed with the New York City Buildings Department and examined and approved by the Fire Department.
4. For grease removal, suitable baffle type grease filters, MEA-approved, shall be installed.
5. Adequate supply of fresh air for unit ventilation and combustion requirements shall be provided into room or space enclosing equipment.
6. The installation shall not obstruct access for operation and servicing.
7. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
8. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
9. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 7/30/07

Examined By Shyam S. Arora