



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 455-06-E Vol. 2

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, ILL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): UL 346

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File S739, Project 92NK28415, issued April 1, 1993 and revised April 17, 2007

Description: Fire alarm equipment.

Model No.	Description
EPS45-2R	Pressure switch 4-40 psi
EPS45-2V	Pressure switch 4-40 psi

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated May 21, 2007, F.P. Index #0705037

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, applications and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17 and Reference Standards 17-2, 17-2A, 17-2B and 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation and UL Standard.
3. Manufacturer's maintenance procedures and UL listing requirements & limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 1, 2007
Examined By Donald [Signature]