



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 458-06-E

Manufacturer: Lennox Industries, Inc.
200 S. 12th Avenue
Marshalltown, IA 50158

Trade Name(s): Dave Lennox Signature Collection

Product: Heat pump units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995, UL 465), RS14-6 (ANSI Z21.47)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA11694, dated March 7, 2006

Description: Outdoor sections of heat pumps consisting of an outdoor section and a fan coil unit, with or without factory- or field-installed electric heater assembly.

Product Covered:

Outdoor Section Model	Cooling Capacity	Fan Coil Model and Electric Heat
*XP15-024-230	2.0	CBX32MV-024/030
*XP15-030-230	2.5	CBX32MV-024/030
*XP15-036-230	3.0	CBX32MV-036
*XP15-042-230	3.5	CBX32MV-048
*XP15-048-230	4.0	CBX32MV-048
*XP15-060-230	5.0	CBX32MV-060

Note: * with additional suffix

Terms and Conditions: The above-described heat pump units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use only Refrigerant R-22.
3. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
4. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State

Final Acceptance 11/16/06

Examined by Shyam Prasad