



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 503-06-M

Manufacturer: Supress Products LLC, PO Box 3472, San Rafael, CA 94912

Trade Name(s): Sound Engineered Drywall

Product: Wall/Ceiling panel for interior finish acceptance

Pertinent Code Section(s): 27-348

Prescribed Test(s): Reference Standard 5-5 (ASTM E-84), UPitt Toxicity

Laboratory: Bodycote Testing Group (E-84)
Southwest Research Institute (Toxicity)

Test Report(s): SWRI Project Number 01.11813.02.060, dated October 24, 2006
Bodycote ASTM E-84 test report #06-02-522, dated July 10, 2006

Description: Sound Engineered Drywall is a high-performance sound and vibration-absorbing panel for use in residential and commercial construction. Panels are used for both walls and ceilings and are installed in a manner similar to regular drywall.

Model Number	Panel Size
SED5848	4' x 8'
SED5849	4' x 9'
SED58410	4' x 10'
SED58412	4' x 12'

Upon exposure to fire, the product does not produce product of decomposition or combustible that are more toxic than those given off by wood or paper when decomposing or burning under comparable conditions.

Flame Spread Rating – 10
Smoke Developed Rating – 20

Terms and Conditions: The above-described panel is accepted with the following conditions:

1. Panel is for interior-finish usage with Class A flame spread rating, as indicated.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance November 13, 2006

Examined By Simon Deshpande