



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 528-06-E

Manufacturer: Euro'Cryor SpA, Viale delle Industrie, Solesino (Pd), ITALY 35047

Trade Name(s): Vela

Product: Remote-control refrigerated cabinets to display foodstuff

Pertinent Code Section(s): 27-771, 27-772

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Intertek, ETL Semko Division

Test Report(s): No. 30416474 dated April 22, 2003, revised April 26, 2005

Description: Remote-control commercial refrigerated display cabinets designed to be permanently connected and floor supported, with a 110V to 220V operating range.

Product Covered:

Models Cryor 101, Cryor 101-D, Cryor 201, Iside, Osiride, Arcus, Arcus-D, Vela, Top Glass, Swing, Coiba, Cockpit, Spherox, Eclipse, Cryor SM1, Cryor SM2, Cryor SM3, Cryor SM4, Blues, Jazz, Spherox-DWR, Blues-DWR, Jazz-DWR, Gemini, Gemini-D, Eclipse 2 Dk, Country, Micron, Spring, Summer, Horus and New Pick.

Terms and Conditions: The above-described units are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and the New York City Building and Electrical Codes.
2. The installation shall not obstruct access for operation and servicing.
3. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 8/28/07
Examined By [Signature]