

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 53-04-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer – System Sensor, Unicorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.**

**Trade Names–System Sensor, Unicorporated Division of Honeywell International Inc.**

**Product – Fire Alarm Equipment.**

**Pertinent Code Section(s) –RS 17-3, RS 4-6 (886-89-BCR).**

**Test – UL 268.**

**Laboratory – Underwriters Laboratories, Inc.**

**Test Reports – UL File S911, Vol. 107, Sec. 1, issued November 25, 2004.**

**Description – System Sensor detectors.**

Model No.	Description
BEAM 200, BEAM 200S	Beam Detectors

Pursuant to “Promulgation of the Rules relating to Materials and Equipment Application Procedures” dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated February 23, 2004, FP Index No. 0401044.

**Recommendation-** That the above equipment be accepted on condition that all uses, configuration, arrangements and functions, applications, and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard RS-17-3. Further, the installation and spacing shall be in accordance with the manufacturer’s recommendation, NFPA 72 and UL Standard. Periodic maintenance and sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 14, 2004  
Examined by Donald [Signature]