

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner
MEA 55-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Firelite.

Product – Fire alarm equipment.

Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-69-BCR).

Tests – UL 864.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – UL File S3705, project 01NK47331, Vol. 11, Sec. 1, iss. January 11, 2002 and UL letter dated February 6, 2002.

Description – System Sensor's control unit accessory modules as follows:

Model Number	Description
CRF-300-6	Relay module
CMF-300-6	Supervising control module
MMF-300-10	Input monitor module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated February 20, 2002, F.P. Index No. 0202022.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Standards RS 17-3. The referenced provide shall be used only with listed and approved fire control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 13, 2002

Examined by Mark J. Kelly