



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 55-07-E

Manufacturer: Pacific Energy Fireplace Hearth Products Ltd.,
Allenby Road, Duncan, B.C., CANADA V9L 6V8

Trade Name(s): Town & Country Fireplaces

Product: Direct-vent, gas-fired decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.50a)

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): 3090425COQ-002 dated April 17, 2006;
3087133COQ-002a & 3096999COQ-002 dated
September 29, 2006;
3087133COQ-002b dated October 26, 2006;
3099037COQ-002 dated October 11, 2006.

Description: Gas-fired, decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. Units are equipped with electronic ignition.

Model No.	Description	Rating (BTUH)
TC30.CE Series C	Direct vent, zero clearance fireplaces, electronic ignition with battery back-up.	35,000 – 27,000
TC36.CE Series C	Same as Above	47,000 – 47,000
TC36.CARE Series C	Same as Above	47,000 – 35,000
TC36.CSTE Series C	Same as Above	61,000 – 46,000
TC42.CE Series C	Same as Above	61,000 – 46,000
TC54.CE Series C	Same as Above	93,000 – 67,000

Terms and Conditions: The above-described appliances are accepted for decorative heating operation under the following conditions:

1. Venting of the above equipment is subject to Section 27-879 of the New York City Building Code.
2. Liquid propane shall not be permitted.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 6/4/07

Examined By [Signature]