



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 574-06-M

Manufacturer: OEG Building Material, 5014 16th Avenue, Suite 334, Brooklyn, N.Y, 11204

Trade Name(s): OEG USA Fiberglass Insulation

Product: Fiberglass thermal insulation

Pertinent Code Section(s): 27-335.1

Prescribed Test(s): RS 5-5(ASTM E-84), Toxicity

Laboratory: VTEC Laboratories, Anderson Laboratories, Inc.

Test Report(s): VTEC Nos. V100-2511-1, dated October 6, 2006 and V100-2511-2, dated October 22, 2006

Description: Thermal insulation material from inorganic glass fibers preformed into rolled up sheets and is available in plain or with multi-purpose facings.

Upon exposure to fire, the material does not produce products of decomposition or combustion that are more toxic than those given off by wood or paper when decomposing or burning under comparable conditions.

Flame Spread Rating – 10
Smoke Developed Rating – 0

Terms and Conditions: The above-described thermal insulation is accepted for use under the following conditions:

1. The material may be used in either new or existing noncombustible construction Group I or combustible Group II buildings.
2. Installation shall be in accordance with Section 27-335.1 and manufacturer's supplied instructions.
3. All shipments and deliveries of such equipment shall be provided with a label, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance March 22, 2007

Examined By Sean Deshpande