



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 588-06-E

Manufacturer: Lennox Hearth Products, 1110 West Taft Avenue, Orange, CA 92865

Trade Name(s): Superior Slimline

Product: B-vented gas fireplace

Pertinent Code Section(s): 27-800, 27-825, 27-826

Prescribed Test(s): RS 14-6 (ANSI Z21.60)

Laboratory: Omni Test Laboratories

Test Report(s): Certificate 116-F-30-5, dated May 17, 2005.

Description: B-vented gas fireplace designed for indoor, in-built installation. Unit is comprised of a B-vented system combustion chamber and heat exchanger assembly, main burner assembly, direct ignition system consisting of igniter, a flame sensor, ignition module, combination gas-pressure regulator and controls. Unit is provided with an overheat switch, fan switch and pressure switch. The model number and input heating rating are listed below

Model No.	Input Heating Rating Range (Btu/hr)
SSBV-3530CNM SSBV-3530CNE	17,500 – 23,000
SSBV-4035CNM SSBV-4035CNE	21,500 – 29,000

Terms and Conditions: The above-described B-vent type fireplaces are accepted for operation under the following conditions:

1. Units are for through-the-wall installation only.
2. Units shall use natural gas only.
3. Units shall be installed by a licensed plumber only, who shall insure that installation is provided with required unobstructed vent opening and that all Gas Company requirements for this type of installation are strictly enforced.
4. If steel flue tube passes through a combustible wall, it must pass through a double metal thimble that is two inches larger than the flue.
5. Units shall not be installed behind doors, in an alcove or at locations where curtains or drapes can come into contact with them.
6. Gas pressure regulator shall be installed and gas inlet pressure shall be adjusted by the installer to give inlet pressure at the burner orifice recommended by the manufacturer.
7. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
8. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
9. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance _____ 10/12/07

Examined By _____ Shyam. (R)