



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 622-06-E Vol. 2

**Manufacturer:** System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Fike Corporation

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** RS 17-3, RS 4-6 (886-89-BCR)

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL Multiple Listing, File No. S4021, issued December 17, 2004, revised October 2, 2006.

### Description:

System Sensor Model No.	Fike Model No.	Description
EBR	63-1063	Detector Relay Base
EBS	63-1064	Detector Sounder Base

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation, RS 17-5 (NFPA 72) and UL standard.
3. The above product shall be used only with listed, approved/accepted compatible detector heads and fire alarm equipments.
4. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance February 28, 2007.

Examined By

Donald [Signature]