

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 63-02-M

Report of Material and Equipment Acceptance Division

Manufacturer – Cooley Incorporated, 50 Esten Avenue, Pawtucket, Rhode Island 02862.

Trade Name – Billboard 15.

Product – PVC coated fabric for flexsign.

Pertinent Code Sections – 27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test – RS 7-3 [NFPA 701(Test Method 2)].

Laboratory – Magill Laboratories, Inc.

Test Report – No. 87 dated February 13, 2002.

Description – The Billboard 15 bill board membrane is composed of flame retardant PVC film that is laminated to a 2.06 oz. 1000 denier polyester fabric with 5.18 of PVC laminated to the back of the fabric and 7.76 oz. Laminated to the face.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 270596 and 27-507 of the Building Code, for use on flexsigns. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance JAN/30/04

Examined By S. Deshpande