



NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 66-01-E Vol. 2

Manufacturer: Franke Foodservice Systems Inc.
1 Franke Blvd.
Fayetteville, TN 37334

Trade Name(s): Franke

Product: Frozen Fry Dispenser
Bottle Beverage Refrigerator
Grill-side Freezers
Meat Freezers

Pertinent Code Section(s): 27-800, 27-826; Reference Standard RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.11)

Laboratory: CSA International

Test Report(s): Project 2027948 dated March 31, 2008.

Description: Commercial refrigerators and freezers as described below:

Frozen Fry Dispensers – Model #s: F3D and F3Dn

Freezer that allows pre-measured amounts of fries to dispense and remain frozen until cooking. Refrigerant R404A (13.5 – 18 oz.) is used for the systems.

SA4044, Volume 3, Section 6

Bottle Beverage Refrigerators – Model #s: BBR, B2R, BBR36

Closed display refrigerator with glass doors used to store pre-packaged foods. Refrigerant R404A (18 oz.) is used for the systems

SA4044, Volume 3, Section 8

Grill Side Freezers – Model #s: GSF18 and GSF30

Freezers that are used to hold pre-packaged foods.

Refrigerant R404A (19 oz, 20 oz) is used for the systems

SA4044, Volume 3, Section 7

Meat Freezers – Freezers that are used to hold pre-packaged foods.

SA4044 Volume 3, Section 5

M11628, M12091, M12092, Refrigerant R404A in 10 oz cap tube or 12 oz with accumulator

M12885, M13191, Refrigerant R404A in 8 oz cap tube or 10 oz with accumulator

M14803, M12885-xx, M13191-xx, Refrigerant R404A in 15.2 oz with accumulator

(-xx – means with Danfoss condensing unit)

Terms and Conditions: The above commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions, and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 1, 2008

Examined By Sun Derphadar