



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 66-08-E

Manufacturer: Whirlpool Corporation
303 Upton Drive
St. Joseph, MI 49085

Trade Name(s): Maytag, Whirlpool

Product: Commercial gas-fired tumble dryers
MEA Index #200-20 - Dryers

Pertinent Code Section(s): 27-800, 27-807, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.5.1)

Laboratory: CSA International

Test Report(s): CSA Master Contract 154166, Report 1956345 dated February 19, 2008.

Description: Commercial gas-fired tumble dryers for use in coin laundries or non-coin institutional laundries. The machines are manufactured with either an electronic processor or a mechanical timer, and are operated with a non-pay, coin-pay or card-reader operation.

Type: (Located on serial plate)	Input Heating Rating (Btu/hr)
(B, C, D)DLV-(NAT, LLP or LPB)-1206006-##24	24,000

Note: Units maybe installed on combustible flooring. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above-described commercial gas-fired tumble dryers are accepted with the following conditions:

1. Units shall be fired with natural gas only.
2. Provision for combustion air and ventilation air shall be made in accordance with Section 27-807 and other applicable Building Code requirements.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance April 28, 2008

Examined By Simon Derkhotam