



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 66-97-M Vol. II

Manufacturer: Unity Creations, Ltd./ Unity Surfacing Systems. Office: 56 Bloomingdale Rd. Hicksville, NY 11801

Trade Name(s): Unity Creations.

Product: Tough-Land, Pave-Land, Play-Land & Soft-Land series for roof covering materials in the tile-mat-block form.

Pertinent Code Section(s): 27-337.

Prescribed Test(s): RS 5-10 (ASTM E-108 & E108 Modified).

Laboratory: VTEC Laboratories Inc.

Test Report(s): VTEC test reports no. 100-684-1 April 04,1997 and 100-938 May 12, 1999.

Description – Interlocking rubberized safety surfacing, flooring and paver products in the tile-mat-block form that are resilient and come in a wide variety of colors and thicknesses for roof covering applications over new and existing roofs. This product is made from 100% recycled tires and rubber particles blended with polyurethane and pigments, which are molded, pressed and cured to a measurement of 22" X 44" in length. This material when tested complies with ADA, CPSC and ASTM safety guidelines that meet a Class A rating and must be installed by certified installers following manufacturer's instructions for the fire resistance classification indicated.

Terms and Conditions: That the above roof covering assemblies, utilizing the rubber tiles-mats-blocks when installed in accordance with the instructions for installation supplied by the manufacturer on the roof, and be accepted for the fire resistance classification indicated. A certificate, or label, shall accompany all shipments and deliveries of such materials, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use as provided for in article 27-131 of the Building Code.

Final Acceptance SEP 22, 2005

Examined By S Derkudam