CITY OF NEW YORK DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

> Satish K. Babbar, R.A., Acting Commissioner MEA 7-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue. St. Charles, IL. 60174

Trade Name(s) - System Sensor, G.S. Building Systems Corp.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 521.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL ML File S1122, issued February 16, 1989 and revised September 10, 1999.

Description - Multiple listing for G.S. Building Systems' heat detectors as follows:

Basic Applicant's (Supplier) Product Designation Systems Sensor	Multiple Listee G.S. Building Systems Corp.	Description
5251P	5251F	Fixed Temperature Heat Detector
5251RP	5251FR	Rate of Rise Heat Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated October 21, 1999, F.P. Index No. 9907078A under MEA 236-99-E.

Recommendation - That the above heat detectors be accepted on conditions that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17 as applicable, including the NFPA as appropriate, the UL listing, the manufacturer's instructions, and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 27,2000

Examined By Mork facily