



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 72-01-E Vol. 3

Manufacturer: Fire Lite Alarms, Inc., 12 Clintonville Road, Northford, CT 06472

Trade Name(s): Notifier

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS-17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing File No. S635 issued November 3, 2006, revised January 23, 2007

Description: Fire alarm equipment, six-zone interface module by Fire-Lite.

Fire-Lite Model No.	Notifier Model No.	Description
MMF-301	NMM-100P	Monitor modules
MMF-300	NMM-100	Monitor modules
CMF-300	NC-100	Monitor modules
CRF-300	NC-100R	Monitor modules
MMF-302	NZM-100	Monitor modules
MMF-302-6	NZM-100-6	Six-zone interface module

Terms and Conditions: The above equipment is accepted under the following conditions:

1. All uses, locations and installations shall comply with Article 17, Reference Standard RS-17 of the New York Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives and Fire Department Rules, and the manufacturer's instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance April 17, 2007.
Examined By Donald [Signature]