

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found to be acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

**MEA 79-00-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer - Royalton Foodservice Equipment Company, 9981 York-Theta Drive,  
North Royalton, Ohio 44133.**

**Trade Name - Royalton.**

**Product – Commercial electric food warmers.**

**Pertinent Code Section – 27-787, 27-792.**

**Prescribed Test – RS 14-6 (UL 197)**

**Laboratory –Underwriters Laboratories Inc.**

**Test Reports – UL file E109494, dated July 30, 1999, and September 3, 1999.**

**Description – Commercial electrical food warmers as tabulated below. Units  
comprise heating elements, thermostat, on/off switch and terminal block.**

**PRODUCTS COVERED:**

Carving station, Model RCS-1800-1, RCS-1800-2, RCS-1850-1, RCS-1850-2,  
RCS-2600-1, RCS-2600-2, RCS-2650-1 and RCS-2650-2, heated shelf RSW-30-2.

**ELECTRICAL RATINGS:**

Model Number	Ratings, 50/60 Hz		
	V	A	W
RCS-1800-1	120	2.0	250
RCS-1800-2	120	4.0	500
RCS-1850-1	120	5.2	650
RCS-1850-2	120	7.2	900
RCS-2600-1	120	2.0	250
RCS-2600-2	120	4.0	500
RCS-2650-1	120	5.2	650
RCS-2650-2	120	7.2	900
RSW-30-2	120	14.5	1740

**Recommendation – That the above electric food warmers be accepted under the following conditions:**

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room and space enclosing equipment for ventilation requirements.
3. Satisfactory room exhaust system shall be furnished.
4. The installation shall not interfere with accessibility for operation and servicing.
5. All shipments and deliveries of such materials shall be accompanied by a metal tag, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 5/25/2000  
Examined By S.M. Khan