

# FREQUENTLY ASKED QUESTIONS

## PRESENTATION: Worker Safety Overview – DAY 2

---

- Q1. Do site safety training requirements apply to those installing appliances? How about ‘final cleaning’ companies?**
- A1. Site Safety Training (SST) requirements do not apply to appliance installers. Final cleaning at the end of the construction does not require the training.
- Q2. If a Construction Super (CS) goes on vacation, or they get sick, does the CS have to be replaced with another CS on the PW2 or just make notation in the logbook?**
- A2. An alternate CS can be designated in the logbooks and act as the alternate CS for up to two (2) weeks. If the alternate CS is needed for more than 2 weeks a new PW2 will need to be filed.
- Q3. Does the Alternate CS need to be a ‘registered’ or ‘licensed’ CS?**
- A3. Yes, only a licensed/registered CS can be designated as an alternate CS. This will also be the case if a new PW2 is filed.
- Q4. Any data on how many active C Joists projects?**
- A4. DOB does not keep an active list however that information is captured in the construction documents.
- Q5. Should plywood placed over an open hole have the capacity to withstand a specified load?**
- A5. It may require a PE dependent on the location, traffic, and the imposed load and size of the hole. At a minimum the plywood must be properly marked and secured. Please consult with the PE and the Site Safety Plan for the site.
- Q6. For Code questions, is there a specific email address?**
- A6. Please send Code related questions to [codequest@buildings.nyc.gov](mailto:codequest@buildings.nyc.gov). For technical questions related to the Code, email [ConstructionCodes@buildings.nyc.gov](mailto:ConstructionCodes@buildings.nyc.gov).