

View Those Met

Showing 1-5 of 7

Objections - 7 Open

Non-Certifiable

Floor 061:34-KNOCKOUTS ARE NOT CLOSED IN PANEL BOX

open ko in panel

Open | 02/08/2019

Floor 061:40-LOCKNUTS ARE MISSING OR LOOSE

locknuts missing in panel

Open | 02/08/2019

Floor 061:999-OTHER

open j-box on ceiling 110.2

Open | 02/08/2019

Floor 061:999-OTHER

bushings missing in panel 1 awg wire 300.4(G)

Open | 02/08/2019

BEC objection.
Electric heaters are
not part of the
interpretation request.



Floor ALL:999-OTHER

all apartment missing afci protection for outlets in closets (e.g. washing machines) and electric heaters 210.12

Open | 02/08/2019