

3. INSPECTION INFORMATION

Inspection Result: Fail-Final

Inspection Date: 10/31/18 Inspection Time: 1:41 PM

Inspector Badge#: 2482

4. OBJECTIONS

Failed Guidesheet Item	Result	Certifiable?	Floor No.	Comments
999-OTHER	Fail		GND	Panels ckt not grouped 210.4D
999-OTHER	Fail		GND	Communication equipment and cable install in electric room 800.133
999-OTHER	Fail		GND	Panels breakers not per mfg listing 110.2