

**RESCINDED BY BUILDINGS
BULLETIN 2023-013**

C O P Y

The City of New York
HOUSING AND DEVELOPMENT ADMINISTRATION

• Exit Signs
•(AC)-Title C-Part II-Sec. C26-272.0
•(AC)-Title C-Part II-Sec. C26-279.0

DEPARTMENTAL MEMORANDUM

Date: October 24, 1968

TO: Borough Superintendents
FROM: Thomas V. Burke
Director of Operations
SUBJECT: Exit Signs (C26-272.0 and C26-279.0)

The Board of Education, Office of School Buildings, has been in touch with this department on the subject of phosphorescent exit signs for existing buildings and buildings currently under construction.

Phosphorescent exit signs required by provisions of paragraphs C26-272.0 and C26-279.0 Administrative Building Code shall have eight inch high letters except that in existing buildings and in buildings currently under construction signs with letters no smaller than four inches may be accepted where construction features prohibit larger letters.

/signed/

Thomas V. Burke
Director of Operations

TVB:CFJ:njc