

THE CITY OF NEW YORK
HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS
DIRECTIVE #10 of 1975

DEPARTMENTAL MEMORANDUM

DATE: August 28, 1975

TO: Borough Superintendents
FROM: Thomas V. Burke, P.E., Director of Operations
SUBJECT: Non-central Air-conditioning Systems - Local Law #5/73

The provisions of Local Law #5/73 do not apply to air-conditioning and/or mechanical ventilation systems that do not serve more than the floor on which the equipment is located. Specifically, the provisions of the following do not apply:

C26-1704.5 (f) (9)d

C26-1704.5 (g) (8)d

C26-1704.8 (b) (7)

RS 17-3A Item 9 (n)(7) and
RS 17-3B Item 9 (n)(7)



Thomas V. Burke, P.E.
Director of Operations

TVB:JWS:ASR
cc: Comm. Walsh
Deputy Comm. Jenkins
Assistant Comm. Parascandola
Executive Staff
— Fire Department
Industry