## RESCINDED BY BUILDINGS BULLETIN 2016-015

# THE CITY OF NEW YORK HOUSING AND DEVELOPMENT ADMINISTRATION DEPARTMENT OF BUILDINGS

#### DEPARTMENTAL MEMORANDUM

DATE: January 24, 1975

to: Borough Superintendents, Pat Dillon, Chief Beiler Inspector

FROM: Thomas V. Burke, P.E., Director of Operations

SUBJECT: NOTICE OF PROPOSED STEAM OR HOT WATER BOILER INSTALLATION

(Department Forms 900 and 900A) Section 204 Labor Law

### APPLICABILITY:

The provisions of this memorandum do not relate to:

1. Hot water and steam boilers operating at a pressure of not more than 15PSI, located in dwellings occupied by less than six families.

2. Boilers used to heat water for a supply of warm water.

#### PROCEDURE:

- 1. Prior to the approval of an application that includes a new installation or replacement of a hot water or steam boiler used for space heating, a notification to the Beiler Division is to be completed by the Plan Examiner on Form 900. The original copy is to be attached to the respective New Building, Alteration, Building Notice or Miscellaneous application, one copy is to be sent to the Department of Buildings, Beiler Division, Room 617, 2 ladayeatte Street, New York, N.Y. 10007, and one copy is to be forwarded to the Plumbing Inspector.
- 2. Prior to the installation of a hot water or steam boiler, Form 900% is to be completed by the contractor, and sent to the Boiler Division. Boilers shall not be placed in operation upon completion of construction until inspections and tests are made by a Boiler Inspector of the Department of Buildings (this applies to all boilers used for space heating regardless of the fuel used gas/oil, coal others).
- 2a. Where a boiler is to be fabricated on the pramises, it is the duty of the contractor to notify the Boiler Inspection Division prior to commencement of said fabrication. The contractor shall be the helder of an "A" symbol stamp, and all welders shall be qualified in accordance with A.S.M.E. Boiler Code or New York State Industrial Code Rule 14.
  - 3. No application for a new installation or replacement of a hot water or steam boiler is to be reported as completed, and a contificate of occupancy is not to be issued, until a certification of an inspection and approval of the boiler is received from the Boiler Division.

RESCINDED

continued...

- 4. All boilers are inspected periodically, at least once each year, insofar as personnel limitations permit by a Boiler Inspector of the Department of Buildings or by an inspector of an authorized insurance company.
- 5. It is to be noted that Section C26-116.3(1) of the Administrative Code requires that plans for boiler installations and boiler attorations shall contain at least the following data and inflormation: The ETU per hour output capacity and the operation weight of each boiler; and the pressure setting of the relief valves, horsepower and heating surface. Also, FORM 15 shall indicate the building's occupancy as indicated on attachments #1 through #4.
- 6. All new and replacement boilers are to be manufactured and associated under the specifications of the Doiler and Pronounce Vescel Code of the American Society of Mechanical Engineers. In addition, approval of boilers is required by the Enterials and Equipment Acceptance Division of the Department of Buildings. Boilers previously approved by the New York City Board of Standards and Appeals may be accepted.

These regulations are premulgated in conformance with Section 20% of the State Labor Law and Industrial Code Rules #4 and #14.

Thomas V. Burke, P.E.

Director of Operations

TVE/FI/FEO/sc

ATTACL FINTS: Sample Form 15

DISTRI DICCH: \_

Enoc. staff Endustry ECAC Oil Heat Institute

RESCINDED 87