

**RESCINDED BY BUILDINGS
BULLETIN 2025-007**

C O P Y

DIRECTIVE NO. 23 of 1969

The City of New York
DEPARTMENT OF BUILDINGS

Cranes

Administrative Engr. Jacob Grill, Crane & Derrick Section Date: Dec. 19, 1969

From: Thomas V. Burke, Director of Operations

Subject: Fire Extinguishers - Rules and Regulations for Power
Operated Cranes, Derricks and Cableways - Sub-Rule 28.1

The fire extinguishers required by the subject sub-Rule 28.1 shall be a type approved or listed by a nationally recognized testing laboratory, shall be kept in the cab or in the immediate vicinity of the crane or derrick and shall be of at least ten pounds carbon dioxide capacity, five pounds of dry chemical capacity or an equivalent type and size of fire extinguisher deemed acceptable by the Fire Commissioner.

This directive shall be enforced by the Crane and Derrick Section.

(Signed)

Thomas V. Burke
Director of Operations