

**RESCINDED BY
BUILDINGS BULLETIN 2022-009**

THE CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: September 22, 1982

TO: Chief Elevator Inspectors

FROM: *BFP* Blaise F. Parascandola
Deputy Commissioner

SUBJECT: Teflon Wire in elevator shaft

This will confirm my directive concerning the above subject in connection with the installation of Local Law # 5 Class E alarm and communication systems. It shall be permitted to install teflon wire without conduit in elevator shafts provided measures are taken to prevent mechanical injury to the wire.

The provisions to install teflon wire without conduit extends to low voltage installations only.

BFP:mh

cc: Commr. Fruchtman
Dep. Commr. Minkin
Asst. Commr. Dennis
Boro. Supts.
T. Loudon
M. Mody
Chief Hess, Fire Dept.
Chief Johnston, Fire Dept.
Captain Fauci, Fire Dept.

1882