

**Rescinded By Buildings  
Bulletin 2023-011**



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES  
60 HUDSON STREET, NEW YORK, NY 10013

CHARLES M. SMITH, Jr., R.A., Commissioner

March 28, 1988

Mr. Peter F. Oddo, Jr.  
Peter F. Oddo, Jr., Architect  
3309 Richmond Avenue  
Staten Island, N.Y. 10312

GEORGE E. BERGER, P.E.  
Assistant Commissioner  
Building Construction

RE: Emergency Exit Lights


Dear Mr. Oddo:

Your letter, dated March 15, 1988 to Commissioner Smith, has been forwarded to my office for review and response.

Section 27-381 requires exit lighting in exits and their access facilities in all occupancies. This section requires exit lighting in the path of egress and not in general occupied floor area. This section also exempts dwelling units in a multiple dwelling.

Whereas Section 27-382 requires emergency exit lighting in new buildings in all occupancies and in existing buildings in certain occupancy when more than four lights are required in a building. Furthermore this section does not require emergency exit lighting in existing buildings classified in occupancy group J-2.

Very truly yours,



George E. Berger, P.E.  
Assistant Commissioner

GEB:NTP:lg

cc: Commissioner Charles M. Smith Jr., R.A.  
Deputy Commissioner Cornelius F. Dennis, P.E.  
Deputy Commissioner Stewart P. O'Brien  
Executive Engineer Irving Polsky, P.E.  
Borough Superintendents