

**Rescinded By Buildings  
Bulletin 2023-011**



DEPARTMENT OF BUILDINGS  
EXECUTIVE OFFICES  
60 HUDSON STREET, NEW YORK, N.Y. 10013  
RUDOLPH J. RINALDI, Commissioner

GEORGE C. SAKONA, P.E.  
Deputy Commissioner  
Technical Affairs  
(212) 312-8120

TO: Borough Superintendents  
FROM: George C. Sakona, P.E.  
Deputy Commissioner  
DATE: April 10, 1991  
SUBJECT: EMERGENCY EXIT LIGHTS IN NEW MULTIPLE DWELLINGS



-----  
The requirements of Section 27-381(a) regarding exit lighting are not applicable to dwelling units, however they are applicable to the exits and their access facilities (corridors and public halls) in buildings classified as J-2.

GCS:NTP:cn