RESCINDED BY BUILDINGS BULLETIN 2023-007



HOUSING AND DEVELOPMENT ADMINISTRATION ROGER STARR, Administrator

Department of Buildings 100 GOLD STREET, NEW YORK, N. Y. 10038

JEREMIAH T. WALSH, P.E., Commissioner

September 16, 1976

Mr. Ivan Pinsker 2980 Briggs Avenue New York, N.Y., 10458 an

361 Broadway, NYC Re: FP 384/76

Dear Mr. Pinsker:

This is in reply to your letter dated July 6, 1976 in regard to the additional fee you were required to pay for the construction work needed to enclose the oil tank.

C26-320 (7b) of the New York City Building Code states the fees for a permit to install oil-burning equipment including the installation of storage tanks. Building Department Memorandum dated April 18, 1972, revised June 7, 1972, permits the enclosure of fuel oil tanks as part of the work filed on Form 15. Furthermore, the memorandum states that any construction work that involves structural work such as encasing an oil tank underground, installation of structural steel or reinforced concrete, shall be filed on a Building Notice or Alteration application.

If the enclosure work included any structural work, an additional fee would have been required as asked by the examiner. If no structural work was required then an additional fee would not have been required and an application to the Comptroller's Office for a refund would be advised. A copy of this response is being distributed to our borough offices for their advise and guidance.

Very truly yours.

Irving Minkin, P.E.

Director of Operations

JEM: GB: ah

J.T. Walsh, Comm.

A.J. Jenkins, Dep. Comm. B.F. Parascandola, Asst. Comm

Borough Superintendents