



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES  
60 HUDSON STREET, NEW YORK, N.Y. 10013

RUDOLPH J. RINALDI, Commissioner

RESCINDED BY  
BUILDINGS BULLETIN 2022-017

GEORGE C. SAKONA, P.E.  
First Assistant Commissioner  
Technical Affairs  
(212) 312-8120

June 5, 1990

Mr. C.T. Vogel P.E.  
50 East 42nd Street  
New York, N.Y. 10017-5405

RE: Fire and Smoke Damper  
Requirements in Occupancy  
Group H-2

Dear Mr. Vogel:

Your request in a letter, dated April 17, 1990 to waive the requirements of smoke dampers in ducts for toilet exhaust penetrating toilet shafts has been reviewed by the office and is hereby approved provided the following conditions are compiled with:

1. No other ducts shall be permitted in the toilet shafts
2. Toilet exhaust fan shall remain on continuously.

Very truly yours

  
George C. Sakona, P.E.  
Acting First Assistant Commissioner

GCS:cn

cc: Commissioner Rinaldi  
Borough Superintendent  
Executive Engineer I. Polsky, P.E.  
Chief Toohey, Fire Dept.,  
File