

HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS

DIRECTIVE #9 of 1974

DEPARTMENTAL MEMORANDUM


DATE: May 21, 1974

TO: Borough Superintendents

FROM: Thomas V. Burke, P.E., Director of Operations

SUBJECT: SPRINKLERS IN TOILET ROOMS
LOCAL LAW #5/1973

In existing office buildings, 100 ft. or more in height, sprinklers may be omitted from toilet rooms when complete sprinkler protection is provided in accordance with Section C26-504.1(c)(5) or when the building is completely sprinklered throughout.



Thomas V. Burke, P.E.
Director of Operations

TVB:JWS:ASR

cc: Comm. Walsh
Deputy Comm. Jenkins
Assistant Comm. Parascandola
Kenneth Patton, Real Estate Board
Mayor's Advisory Council on
Building and Construction
Executive Staff
Fire Chief John T. O'Hagan