

## SERVICE NOTICE

### Deadline to Install Natural Gas Alarms is January 1, 2027

On or before January 1, 2027, natural gas alarms shall be provided and installed in accordance with Section 908.13 of the New York City Building Code and relevant Department rules.

Per [Local Law 102 of 2025](#), natural gas alarms must be installed on or before January 1, 2027, if the Department of Buildings ('the Department') identifies at least 4 distinct manufacturers of battery-powered alarms. The Department has identified at least 4 distinct manufacturers of battery-powered alarms, which means the installation date will not be extended beyond January 1, 2027.

#### **Additional Information**

For additional information, review the [Natural Gas Detection Devices FAQs](#) and refer to [1 RCNY §908-02](#) and [1 RCNY 3616-06](#) for relevant standards regarding the installation and location of natural gas alarms.

For assistance, please send inquiries to [LL102of2025@buildings.nyc.gov](mailto:LL102of2025@buildings.nyc.gov).