

Permanent Energy Efficiency Certificate

Insulation Rating					
Ceiling/Roof	Attic	R-50 cavity			
	Vaulted	R-50 cavity			
Walls	Framed wall (wood frame)	R-6 continuous	+ R-21 cavity		
	Mass wall	n/a			
	Basement	R-15 continuous			
	Crawl Space	n/a			
Floors	Over unconditioned space	R-30 cavity			
	Slab Edge	R-12 continuous	4 ft deep		
Ducts outside	Attic	R-10			
	Conditioned space	Other	R-8		
Fenestration Rating					
Window	U-Factor (NFRC)	U-0.25		SHGC (NFRC)	0.36
Opaque door		U-0.27			n/a
Skylight		n/a			
Air Leakage Test Results					
Blower door testing	2.7	ACH	@ Pressure differential of	50	Pascals
Duct leakage testing	3.6	cfm/100ft ²	@ Post-construction test		
Equipment Performance					
Heating System	Gas-fueled Hot Water Boiler	140,000 Btu/h	Efficiency	91.4%	AFUE
Cooling System	Air-Cooled Air Conditioner	54,000 Btu/h	Efficiency	16	SEER
Water Heater	Gas-Storage Water Heater	74,000 Btu/h – 98 gallon Storage	Efficiency	0.57	EF
Indicate if the following have been installed (an efficiency shall not be listed)					
<input type="checkbox"/> electric furnace <input type="checkbox"/> gas-fire unvented room heater <input type="checkbox"/> baseboard electric heater <input type="checkbox"/> Other:					
Notes:					

Premises (address)	123 West 456 Street, New York, NY		
Certificate Completed & Posted by	XYZ Home Builders		
NYC Energy Conservation Code version	2020 NYCECC	Posting/ Update Date	05/30/2020

Permanent Energy Efficiency Certificate

Insulation Rating					
Ceiling/Roof					
Walls					
Floors					
Ducts outside	Attic				
Conditioned space	Other				
Fenestration Rating					
Window	U-Factor ()	U-		SHGC ()	
	U-Factor ()	U-		SHGC ()	
Opaque door	U-Factor ()	U-		SHGC ()	
Skylight	U-Factor ()	U-		SHGC ()	
Air Leakage Test Results					
Blower door testing					
Duct leakage testing					
Equipment Performance					
Heating System					
Cooling System					
Water Heater					
Indicate if the following have been installed (an efficiency shall not be listed)					
<input type="checkbox"/> electric furnace <input type="checkbox"/> gas-fire unvented room heater <input type="checkbox"/> baseboard electric heater <input type="checkbox"/> Other:					
Notes:					

Premises (address)			
Certificate Completed & Posted by			
NYC Energy Conservation Code version	2020 NYCECC	Posting/ Update Date	