

**RESCINDED BY
BUILDINGS BULLETIN 2022-017**



DEPARTMENT OF BUILDINGS

**EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, NY 10013**

CHARLES M. SMITH, Jr., R.A., Commissioner

April 28, 1989

**GEORGE E. BERGER, P.E.
Assistant Commissioner
Building Construction**

Mr. Walter Gorman, P.E., P.C.
115-14 Beach Channel Drive
Rockaway Park, New York 11694

**RE: 1 Little Street
Brooklyn**

Dear Mr. Gorman:

Your request in a letter, dated February 28, 1989 for variance to allow use of exposed fluoropolymer wiring in lieu of THHN in rigid conduit for the installation of smoke detection system in above referenced building is approved with the following requirements:

1. Fluoropolymer (teflon) wiring without conduit in floor spaces shall be above the hung ceiling.
2. All vertical risers and wiring in other exposed areas shall be in rigid conduits.
3. Fluoropolymer wiring shall be Board of Standards and Appeals approved and shall be used for the system operating under 50 volts.

Very truly yours,

A handwritten signature in black ink, appearing to read "George E. Berger".

George E. Berger, P.E.
Assistant Commissioner

GEB:NTP:lg

cc: Shirley Klein, R.A., Borough Superintendent
Chief Joseph DeMeo, Fire Department
Henry Gittlitz, Fire Department
Deputy Commissioner C. Dennis, P.E.
Executive Engineer, I. Polsky, P.E.
Borough Superintendents