



**RESCINDED BY
BUILDINGS BULLETIN
2022-003**

DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, NY 10013

CHARLES M. SMITH, Jr., R.A., Commissioner

October 7, 1988

GEORGE E. BERGER, P.E.
Assistant Commissioner
Building Construction

Mr. Leonard T. Epstein, P.E.
Syska & Hennessy, Inc., Engineers
11 West 42 Street
New York, New York 10036

RE: Combined Standpipe and
Sprinkler Systems

Dear Mr. Epstein:

This is in response to your letter dated September 19, 1988 regarding the use of combined standpipe and sprinkler system in the buildings classified in Occupancy Group F.

Section 27-962(h) does not permit combined systems in Occupancy Group F. Since the Building Code takes the precedence over the Reference Standard, inclusion of Occupancy Group F in paragraphs 2-4.3.2 and 3-8.7 of RS 17-2 is incorrect and RS 17-2 will be amended to correct this situation.

Thank you for bringing this conflict to our attention.

Very truly yours,


George E. Berger, P.E.

GEB:NTP:an

cc:Deputy Commissioner Dennis
Executive Engineer Polsky
Chief DeMeo, Fire Dept.
Chief Hodgens, Fire Dept.