



DEPARTMENT OF BUILDINGS  
120 WALL STREET, NEW YORK, N. Y. 10005  
IRWIN FRUCHTMAN, P.E. Commissioner

September 28, 1978

Mr John Scolaro, P.E.  
Chief, Bureau of Standardization  
Dept. of General Services  
Division of Municipal Supplies  
1900 Municipal Bldg.  
N.Y., N.Y. 10007


Re: Standpipe fire hose couplings

Dear Mr Scolaro:

In response to your letter of 9/15/78 regarding a substitute for brass couplings on standpipe fire hose, you are advised that high strength aluminum alloy couplings, conforming with the standards set forth by the Fire Department in their Dept. Order No. 62, dated 5/5/78, is acceptable as an alternate.

Kindly contact Fire Prevention Chief-in-Charge Sidney Ifshin for the detailed specifications.

Very truly yours,

  
Irwin Fruchtmman, P.E.  
Commissioner

cc: Bur. Sups.  
Executive Staff