



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
120 WALL STREET, NEW YORK, N.Y. 10005

CHARLES M. SMITH, Jr., R. A., Commissioner

July 22, 1986

GEORGE E. BERGER, P.E.
Assistant Commissioner
Building Construction
Special Projects

Mr. John Esposito
Vice President
Ampak Electrical Construction Corporation
6319 14th Avenue
Brooklyn, New York 11219

Re: Ceiling Fixtures

Dear Mr. Esposito:


Your letter dated July 7th, 1986 to Mr. Sanchez-Gomez of the Bureau of Electrical Control of this Department has been forwarded to this office for technical review.

Please be advised that all lighting fixtures installed in the suspended ceiling shall be done in accordance with the requirements of Section 5.3 of the Reference Standard RS 5-16 of the Building Code. The copy of this section and relevant figures are enclosed for your information.

All borough offices as well as the Bureau of Electrical Control is being advised of the above ruling.

This should resolve any misunderstanding on this matter, however, please feel free to contact my office should there be any outstanding question.

Very truly yours,


George E. Berger, P.E.
Assistant Commissioner
Technical Review & Compliance

GEB:rmr

cc: Executive Staff
Borough Superintendents
Director R. Sanchez-Gomez, ECB