

THE CITY OF NEW YORK
HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: May 5, 1975

TO: I. M. Cohen, P.E. Borough Supt. Bronx


FROM: Commissioner Jeremiah T. Walsh, P.E.

SUBJECT: New Building - Park Drive - Exterior frame walls

This memo is to confirm my telephone conversation with you the other day whereby I indicated that the exterior wood frame wall covered with 5/8 in F.C. sheetrock both sides and asbestos shingle on the exterior face was acceptable for the above noted detached, one family, class 2 B building.

Please place a copy of this memo in the subject folder.

You may use this memo as a guide for determination of any similar situation that may arise in the future.


Jeremiah T. Walsh, P.E.
Commissioner

CC: Jenkins, Parascandola, Minkin, Burke

RESCINDED 1057