RESCINDED BY BUILDINGS BULLETIN 2022-015



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES 60 HUDSON STREET, NEW YORK, NY 10013

CHARLES M. SMITH, Jr., R.A., Commissioner

Issuance #62

GEORGE E. BERGER, P.E. Assistant Commissioner Building Construction

TECHNICAL POLICY AND PROCEDURE NOTICE # 9 /87

TO: BOROUGH SUPERINTENDENTS

FROM: George E. Berger, P.E. Assistant Commissioner

- SUBJECT: Smoke Control Corridors of Hospitals 27-777.01 (a) (2)
- DATE: December 10, 1987

Enclosed or unenclosed passageways serving patient rooms in a hospital where doors from such rooms are not required to be closed, shall not be considered as corridors for the purpose of required separation of ventilation systems as per Section 27-777.01 (a) (2).

GEB:NTP:lg

cc: Executive Staff Industry Fire Department