

# 1 RCNY §3007-02

## CHAPTER 3000

### Elevators and Conveying Systems

**§3007-02 Fire service access elevator (FSAE) hoistway lighting.** Where hoistway lighting is required to be provided in accordance with Building Code section 3007.5.2, the following lighting control requirements shall apply:

- (a) A two-position ON-AUTO switch shall be provided for FSAE hoistway lighting controls.
- (b) One switch for each hoistway containing FSAE shall be provided.
- (c) Each switch's label descriptor shall include a reference to the FSAE car designation (e.g. A-1).