

1 RCNY §3616-06

CHAPTER 3600

Appendices

§3616-06 National Fire Protection Association (“NFPA”) 715 amendment relating to the installation and location of natural gas alarms.

Pursuant to Section 28-103.19 of the New York City Administrative Code, NFPA 715 (2023 edition) is hereby amended as follows:

4.14.1 and 4.14.1.1 through 4.14.1.5 Delete and replace with the following: **Approval and Acceptance.** The design and installation of natural gas detecting systems and components must be subject to the applicable permit requirements established in the Administrative Code and the *New York City Electrical Code*.

9.5.1.2 Delete and replace with the following: Electrically powered fuel gas warning equipment must be provided with a primary ac power source in accordance with 9.5.2.1 and a secondary power source in accordance with 9.5.4, unless otherwise permitted by the following:

- (1) Detectors must be permitted to be powered by a monitored dc circuit of a control unit where power for the control unit meets the requirements of Section 9.5 and the circuit remains operable upon loss of primary ac power.
- (2) A detector and a wireless transmitter that serves only that detector must be permitted to be powered from a monitored battery primary source where part of a listed, monitored, low-power radio wireless system.
- (3) A monitored battery primary power source in accordance with 9.5.3 must be permitted in existing buildings, as defined in section 28-101.5 of the Administrative Code, that were constructed before January 1, 2024.