



Promulgation Details for 1 RCNY 4000-06

This rule became effective on September, 02, 2008.

Since such date, one or more amendments have been made to this rule. Each rule amendment has its own effective date and Statement of Basis and Purpose.

Below you will find one or more rule amendments (the most recent appearing at the top), followed by the original rule.

The effective date of each amendment and the original rule can be found at the top of each "NOTICE OF ADOPTION OF RULE."

This rule has an effective date of 01-04-16.

NEW YORK CITY DEPARTMENT OF BUILDINGS

NOTICE OF ADOPTION OF RULE


NOTICE IS HEREBY GIVEN, pursuant to the authority vested in the Commissioner of the Department of Buildings by Section 643 of the New York City Charter and in accordance with Section 1043 of the Charter, that the Department of Buildings hereby repeals the following rules and Reference Standards found in Title 1 of the Official Compilation of the Rules of the City of New York:

- Section 6-01 of Chapter 6 of Title 1 of the Rules of the City of New York relating to the erection and dismantling of climber/tower cranes
- Section 8-01 of Chapter 8 of Title 1 of the Rules of the City of New York relating to the commencement of demolition and heavy and light duty sidewalk sheds
- Section 27-03 of Chapter 27 of Title 1 of the Rules of the City of New York relating to signs at demolition or construction sites
- Section 27-04 of Chapter 27 of Title 1 of the Rules of the City of New York relating to advisory signs required on construction sites
- Section 403-01 of Chapter 400 of Title 1 of the Rules of the City of New York relating to impact resistant stair and elevator shaft enclosures
- Section 4000-06 of Chapter 4000 of Title 1 of the Rules of the City of New York relating to fire alarm wiring and power sources

- Reference Standard 19-1 relating to power-actuated fastening systems-safety requirements
- Reference Standard 19-4 relating to safety nets.

This rule was first published on October 14, 2015 and no public hearing was held thereon.

Dated: 11.24.15
New York, New York



Rick D. Chandler, P.E.
Commissioner

Statement of Basis and Purpose of Rule

The purpose of the rule is to repeal rules and Reference Standards that are now addressed in the New York City Building or Electrical Codes. The rules and Reference Standards to be repealed relate to:

- the erection and dismantling of climber/tower cranes (1 RCNY § 6-01);
- the commencement of demolition and heavy and light duty sidewalk sheds (1 RCNY § 8-01);
- signs at demolition or construction sites (1 RCNY § 27-03);
- advisory signs required on construction sites (1 RCNY § 27-04);
- impact resistant stair and elevator shaft enclosures (1 RCNY § 403-01);
and
- fire alarm wiring and power sources (1 RCNY § 4000-06)
- power-actuated fastening systems-safety requirements during construction operations (RS 19-1) and
- the use of safety nets during construction operations (RS 19-4).

The Department of Buildings' authority for these rules is found in sections 643 and 1043 of the New York City Charter and section 28-103.19 of the New York City Administrative Code.

New material is underlined.

[Deleted material is in brackets.]

“Shall” and “must” denote mandatory requirements and may be used interchangeably in the rules of this department, unless otherwise specified or unless the context clearly indicates otherwise.

Section 1. Section 6-01 of Title 1 of the Rules of the City of New York, relating to the erection and dismantling of climber/tower cranes, is REPEALED.

§ 2. Section 8-01 of Title 1 of the Rules of the City of New York, relating to the commencement of demolition and heavy and light duty sidewalk sheds, is REPEALED.

§ 3. Section 27-03 of Title 1 of the Rules of the City of New York, relating to signs at demolition or construction sites, is REPEALED.

§ 4. Section 27-04 of Title 1 of the Rules of the City of New York, relating to advisory signs required on construction sites, is REPEALED.

§ 5. Section 403-01 of Title 1 of the Rules of the City of New York, relating to impact resistant stair and elevator shaft enclosures, is REPEALED.

§ 6. Section 4000-06 of Title 1 of the Rules of the City of New York, relating to fire alarm wiring and power sources, is REPEALED.

§ 7. Reference Standard 19-1, relating to power-actuated fastening systems-safety requirements, is REPEALED.

§ 8. Reference Standard 19-4, relating to safety nets, is REPEALED.



Robert D. LiMandri
Commissioner
rlimandri@buildings.nyc.gov

280 Broadway
(Floor)
New York, NY 10007
www.nyc.gov/buildings

+1 212 566 3103 tel
+1 212 566 3785 fax

Statement of Substantial Need for Earlier Implementation

I hereby find, pursuant to Subparagraph (c) of Paragraph (1) of Subdivision (e) of Section 1043 of the New York City Charter, and hereby represent to the Mayor, that there is a substantial need for the earlier implementation of the repeal and repromulgation of Section 4000-06 of Chapter 4000 of Title 1 of the Rules of the City of New York, relating to fire alarm wiring and power sources, upon the publication in the City Record of its Notice of Adoption.

Beginning July 1, 2009, applicants are required to comply with the provisions of the 2008 New York City Building Code relating to fire protection systems for new buildings and alterations. 1 RCNY 4000-06, which implements the fire alarm wiring provisions of the Building Code, as currently promulgated, fails to provide all requirements and standards necessary for the design and installation of code compliant fire alarm systems. It is critical to have in effect as early as possible the repeal and repromulgation of 1 RCNY 4000-06 in order to ensure the fire protection of buildings and the health and safety of building occupants.

Therefore, there is a substantial need for the earlier implementation of this rule pursuant to Charter § 1043(e)(1)(c).

A handwritten signature in black ink, appearing to read "Robert D. LiMandri", written over a horizontal line.

Robert D. LiMandri
Commissioner
Department of Buildings

APPROVED:

A handwritten signature in black ink, appearing to read "Michael R. Bloomberg", written over a horizontal line.

Michael R. Bloomberg
Mayor

DATE:


8/5/09

NOTICE OF ADOPTION OF RULE

NOTICE IS HEREBY GIVEN, pursuant to the authority vested in the Commissioner of Buildings by Section 643 of the New York City Charter and in accordance with Section 1043 of the Charter, Section 28-103.19 of the New York City Administrative Code and Section BC 2701 of the New York City Building Code, that the Department of Buildings hereby repeals and repromulgates Section 4000-06 of Chapter 4000 of Title 1 of the Rules of the City of New York, relating to fire alarm wiring and power sources.

This rule was first published on June 5, 2009, and a public hearing thereon was held on July 8, 2009.

Dated: 7/30, 2009
New York, New York


Robert D. LiMandri
Commissioner

Chapter 4000 of Title 1 of the Rules of the City of New York is amended by repealing and repromulgating Section 4000-6 to read as follows:

§4000-06 Fire alarm wiring and power sources.

(a) Scope. Electrical wiring and power sources serving fire alarm systems shall be installed in accordance with this section. This section shall apply to the alteration of existing buildings, in accordance with Section 101.4.3 of Title 28 of the New York City Administrative Code, and to all new installations.

(b) References. Where Article 760 of the New York City Electrical Code refers to the requirements for the installation of wiring and equipment as set forth by RS 17-3, RS 17-3A, RS 17-3B, and RS 17-3C of the 1968 Building Code, the requirements of this section shall replace Sections 1 and 3 of RS 17-3, Sections 1 and 3 of RS 17-3A, Sections 1 and 3 of RS 17-3B, and Sections 3 and 5 of RS 17-3C. Unless otherwise indicated, any reference in this section to an article of National Fire Protection Association (“NFPA”) 70: National Electrical Code is to the 2008 edition.

(c) Electrical wiring and power sources. Electrical wiring and power sources serving fire alarm systems shall be installed in accordance with Article 760 of NFPA 70: National Electrical Code, as modified for New York City in accordance with this section. The New York City modifications to Article 760 are as follows:

Section 760.1

Section 760.1 - Revise FPN No. 1 by deleting “guard’s tour” in the first sentence.

Revise the last sentence of FPN No. 1 to read as follows:

For further information on the installation and monitoring for integrity requirements for fire alarm systems, refer to NFPA 72: National Fire Alarm Code, 2002 edition.

Add a new FPN No. 3 to read as follows:

FPN No. 3: See Section BC 907 of the New York City Building Code for components’ description and use.

Section 760.2

Section 760.2 - At the end of the definition of “Abandoned Fire Alarm Cable” add: “However, a tag shall be securely fixed to each end indicating location of opposing end.”

Section 760.3

Subsection 760.3(B) - Delete the subsection in its entirety.

Subsection 760.3(F) - Revise to read as follows:

(F) Optical Fiber Cables. Where optical fiber cables are utilized for fire alarm circuits, the cables shall be supervised, and installed in raceway per Article 342, 344 or 358 and in accordance with Article 770 and terminated in equipment listed for fire alarm use.

Subsection 760.3(G) - Revise to read as follows:

(G) Installations of Conductors with Other Systems. Installations shall comply with 300.8 and 760.136.

Section 760.24

Section 760.24 - At the end of the last paragraph add: "Raceways, where installed, shall be minimum 1.9 cm (3/4 in.) trade size. See 760.52 and 760.131 for installations requiring raceways."

Section 760.25

Section 760.25 - At end of the last sentence add: "and securely fixed to each end indicating location of opposing end."

Section 760.32

Section 760.32 - Revise to read as follows:

760.32 Fire Alarm Circuits Extending Beyond One Building. Power-limited fire alarm circuits that extend beyond one building and run outdoors shall be installed in raceway in accordance with Articles 342 or 344. Non-power-limited fire alarm circuits that extend beyond one building and run outdoors shall meet the installation requirements of Part 1 of Article 300 and the applicable sections of Part 1 of Article 225 and shall be installed in raceway in accordance with Article 342 or 344.

Section 760.33

Section 760.33 - Add a new section 760.33 to read as follows:

760.33 Fire Alarm Circuit and Equipment Grounding. Fire alarm circuits and equipment shall be grounded in accordance with Article 250 and shall comply with the following requirements:

(A) Grounding Electrode Conductor. At the primary and secondary power source supplying the fire alarm system, a grounding electrode conductor shall be sized and installed in accordance with Article 250, Table 250.66 (#10 AWG minimum).

(B) Equipment Grounding Conductor. Where there are conduits supplying 120V power to a fire command station, control unit or distributed control cabinets,

a separate green insulated equipment ground conductor shall be sized and installed in accordance with Article 250, Table 250.122 (#10 AWG minimum).

(C) Grounding Separately Derived Supply. For distributed cabinets where 120V supply is not derived from the main fire alarm power supply, a green insulated equipment grounding conductor shall be sized and installed in accordance with Article 250, Table 250.122 (#10 AWG minimum). In steel framed buildings, an additional connection to local steel shall be permitted.

Section 760.41

Section 760.41 - Delete the section and replace to read as follows:

760.41 Power Source Requirements. The power source for fire alarm circuits shall comply with the following:

(A) Primary Power Source. All fire alarm circuits shall be provided with a primary power source. The primary power source shall be generated electric power not exceeding 277/480 volts, supplied by utility company power or isolated plant. The primary power supply to the fire alarm system shall comply with the following:

(1) Primary power supply for the fire alarm system shall be connected to the primary power source ahead of all building service disconnecting means so that the building service disconnecting means can be opened without de-energizing the fire alarm supply. All utility metering of the fire alarm system, including disabling or removal of meters, shall maintain power continuity to the fire alarm system at all times.

(2) Primary power supply for sub-systems or other limited interior fire alarm systems may be connected to the power supply through the protected area of such systems by means of a connection ahead of the disconnecting means for the power supply to the protected area.

FPN: Sub-systems and limited interior fire alarm systems may also use the connected means defined in paragraph (1) above where available.

(B) Secondary Power Source. Where an emergency power system is provided or required to be provided for emergency system loads, the fire alarm circuits shall be provided with a secondary power source. Batteries shall not be a substitute for connection to a secondary power source. The secondary power source shall comply with the requirements for emergency power systems and/or an emergency generator that are used for emergency systems loads as articulated below:

(1) Emergency power systems complying with Chapter 27 of the New York City Building Code shall be permitted to serve as a secondary power source; or

(2) Emergency power systems and/or emergency generators in existing buildings in compliance with Title 27, Chapter 1, Subchapter 6, Section 27-396.4 of the New York City Administrative Code (also referred to as the 1968 Building Code) shall be permitted to serve as the secondary power source.

The secondary power supply shall be connected such that all other disconnecting means serving other building emergency loads can be opened without de-energizing the facility fire alarm secondary power supply.

FPN: The use of a main disconnecting means on the output of the generator(s) is permitted where disconnect of all other loads does not interrupt the facility fire alarm system secondary power supply.

(C) **Battery.** Regardless of whether a secondary power source is also provided, each fire alarm system and subsystem shall be equipped with a storage battery power supply sized to meet the operating power requirements of the system in accordance with paragraphs (1), (2) or (3) below and shall automatically connect to and operate the fire alarm system upon failure of the primary or secondary power supply or sources. Batteries shall not be a substitute for connection to a secondary power source when a secondary power source is required pursuant to subsection (B) above.

(1) Supervisory operation for 24 hours followed by full load operation for 6 hours for systems with voice communications capability.

FPN: A 45 minute period of voice/alarm operation at maximum connected load shall be considered equivalent to 6 hours of total system operation.

(2) Supervisory operation for 24 hours followed by full load operation for 15 minutes for systems without voice communications capability.

(3) Supervisory operation for 24 hours followed by full load operation for 5 minutes for sub-systems or other limited interior fire alarm systems operating within a facility that reports to the overall facility fire alarm system.

(D) **Arrangement of Power Sources.** One source of power shall be connected to the fire alarm system at all times. The primary and secondary power sources shall be arranged and controlled by automatic transfer switches dedicated to the fire alarm system such that when the primary source of power fails, the secondary source will be connected automatically to the fire alarm system. The following conditions shall also be observed:

(1) Intermediary devices between the system supply and the source of power, other than fused disconnect switches, transformers and automatic transfer switches are prohibited. Such disconnect switches, transformers and automatic

transfer switches shall supply only the fire alarm system and other systems specifically permitted by the New York City Construction Codes, New York City Fire Code, and Rules of the City of New York.

(2) The primary source of power and the secondary source of power shall each be provided with a means of disconnect from the fire alarm system. Each disconnect shall consist of a fused disconnect switch, locked in the ON position with key kept on premises accessible only to authorized personnel. Such disconnect shall be painted red and permanently identified as fire alarm circuit and labeled as to system/location served, with a means of interrupting the unfused neutral and all ungrounded conductors.

(3) For buildings served at up to 300 volts to ground, the service voltage shall be transformed to 120/208 volts and a fire alarm fused disconnect provided within a circuit length of ten 3.05 m (10 ft.), shall be connected at the transformer secondary on the 120/208 volt side. The fire alarm system fused disconnect switch on the transformer secondary side shall comply with the requirements of the primary and secondary power source fused disconnect switches specified above. Fused cutouts shall be provided where multiple circuits are required to support the fire alarm system and related auxiliaries mounted in a fused cutout panel suitable for the number of circuits needed.

Section 760.43

Section 760.43 - Revise the first sentence by replacing "14 AWG" with "12 AWG" and delete the last sentence.

Section 760.45

Section 760.45 - Delete the exceptions and the FPN in their entirety.

Section 760.46

Section 760.46 - Revise to read as follows:

760.46 NPLFA Circuit Wiring. Installation of non-power limited fire alarm circuits shall be in accordance with applicable portions of 110.3(B), 300.7, 300.15, 300.17 and other appropriate articles of Chapter 3 using raceway methods described in Articles 342 and 344 or Type MI cable in accordance with Article 332.

Exception No.1: As provided in 760.48 through 760.53.

Exception No. 2: Where other articles of the New York City Electrical Code require other methods.

Section 760.48

Subsection 760.48(A) - Revise to read as follows:

(A) NPLFA Circuits. NPLFA circuits shall not be permitted to occupy the same cable, enclosure or raceway with circuits of other systems.

Subsection 760.48(B) - Revise to read as follows:

(B) Fire Alarm with Power-Supply Circuits. Power supply and fire alarm circuit conductors shall be permitted in the same enclosure only where connected to the same equipment.

Section 760.49

Subsection 760.49(A) - Revise to read as follows:

(A) Size and Use. Only copper conductors #12 AWG and larger shall be permitted to be used as NPLFA circuit conductors.

Subsection 760.49(B) - Delete the FPN and revise to read as follows:

(B) Insulation. Insulation on conductors shall be suitable for 600 volts, 90°C, and shall comply with Article 310. Conductors shall be Type THHN, THWN/THHN, TFFN, TFN, FEP, RHH, RHW2, XHH, XHHW, MI or CI-NYC Certified Cable. Application of conductor ampacity shall be in accordance with 110.14 for terminal device ratings.

Subsection 760.49(C) - Revise to read as follows:

(C) Conductor Materials. Conductors shall be solid copper up to size #10 AWG. Stranded copper conductors shall be used for sizes #8 AWG and larger.

Section 760.51

Subsection 760.51(A) - Delete: "and Class 1 Circuits" in title and "and Class 1 circuit" in text.

Subsection 760.51(B) - Delete the subsection in its entirety.

Subsection 760.51(C) - Revise to read as follows:

(C) Cable Trays. Where non-power limited fire alarm circuit conductors are installed in cable trays, they shall comply with 392.9 through 392.11 and shall be barriered from any other wiring installed in the cable tray.

Section 760.52

Section 760.52 - Add a new section 760.52 to read as follows:

760.52 Mechanical Execution of Work. Installation shall conform to the following:

(A) Mechanical Rooms, Elevator Rooms, Garages and Loading Docks. All wiring installed up to 2.4 m (8 ft.) above the finished floor in garages, loading docks, mechanical rooms, and elevator rooms shall be installed in raceway pursuant to Article 344. All wiring installed above 2.4 m (8 ft.) shall be installed pursuant to Articles 332, 342, 344 or 358.

Exception: For mechanical rooms and elevator rooms having a floor area of less than 83.61 m² (900 ft.²), installation pursuant to Articles 332, 342, 344 or 358 is permitted without height limitation.

(B) Installation. Installation of raceways, boxes, enclosures, cabinets, and wiring shall conform to the following requirements:

(1) Covers of boxes, enclosures and cabinets shall be painted red and permanently identified as to use.

(2) Penetrations through rated walls, ceilings and floors shall be fire stopped.

(3) Raceways or wiring shall not penetrate the top of any control equipment cabinet or enclosure.

(4) Raceways installed up to 2.4 m (8 ft.) in stairways shall not reduce or obstruct required stairway radius or egress path.

Section 760.53

Section 760.53 - Delete the section and replace to read as follows:

760.53 Fire Alarm Circuit Integrity (CI) Cable. Cables suitable for use in fire alarm systems to ensure survivability of critical circuits during a specified time under fire conditions shall be listed as circuit integrity cable. Cables so identified shall have the classification "CI-NYC certified fire alarm cable."

Section 760.121

Section 760.121 - Delete FPN Nos. 1 and 2 in their entirety.

Section 760.124

Section 760.124 - Delete the FPN in its entirety.

Section 760.127

Section 760.127 - Delete the exception in its entirety.

Section 760.130

Subsection 760.130(A) - Revise exception 2 by adding ", 760.51" after "760.49" and delete exception No. 3 and the FPN in their entirety.

Subsection 760.130(B) - Revise the last sentence to read as follows:

Devices shall be installed in accordance with Sections 110.3(B), 300.11(A) and 300.15 with all wiring supported independently from the building structure.

Subsection 760.130(B)(1) - Revise to read as follows:

(1) **Exposed or Fished in Concealed Spaces.** In raceway or exposed above 2.4 m (8 ft.) on the surface of ceiling and sidewalls or fished in concealed spaces, cable splices or terminations shall be made in listed fittings, boxes, enclosures, fire alarm devices or utilization equipment. Where installed exposed, cables shall be supported at a maximum of 1.5 m (5 ft.) spacing and installed in such a way that maximum protection against physical damage is afforded by building construction. Where located within 2.4 m (8 ft.) of the floor, cables shall be installed in raceway pursuant to Article 342, 344, 358 or 386.

Subsection 760.130(B)(2) - Revise to read as follows:

(2) **Passing Through a Floor or Wall.** In metal raceways where passing through a wall or floor to a height of 2.4 m (8 ft.) above the floor, unless protection can be afforded by building construction such as detailed in 760.130(B)(1) or unless an equivalent solid guard is provided.

FPN: Protected by building construction includes raised floors, shafts, telephone and communications equipment rooms and closets, and rooms used exclusively for fire alarm equipment.

Subsection 760.130(B)(3) - Delete: "rigid nonmetallic conduit,".

Subsection 760.130(B)(4) - Add a new subsection 760.130(B)(4) to read as follows:

(4) **Terminations and Splices.** Terminations and splices shall be made with terminal blocks and in listed fittings, boxes, enclosures, fire alarm devices or utilization equipment. Splices shall be limited to locations where the conditions of installation require the use of splices. Splices and terminations in riser cables are prohibited except where made in fire alarm equipment terminal cabinets. Mechanical connections listed under Underwriters Laboratories ("UL") 486-03, A & C shall be used for the conductors, or if soldered, first joined so as to be mechanically and electrically secure prior to soldering. Temperature rating of the completed splices shall equal or exceed the temperature rating of the highest rated conductor.

Section 760.131

Section 760.131 - Add a new section 760.131 to read as follows:

760.131 Mechanical Execution of Work. Installation shall conform to the following requirements.

(A) Mechanical Rooms, Elevator Rooms, Garages and Loading Docks. All wiring installed up to 2.4 m (8 ft.) above the finished floor in garages, loading docks, mechanical rooms, and elevator rooms shall be installed in raceway pursuant to Article 344.

Exception: For mechanical rooms and elevator rooms having a floor area of less than 83.61 m² (900 ft.²), installation pursuant to Articles 332, 342, 344 or 358 is permitted without height limitation.

(B) Extinguishing Systems. Extinguishing and suppression systems activated by automatic fire detection and using fire alarm cables shall be installed pursuant to Article 332, 342, 344 or 358. Such systems shall include, but not be limited to, pre-action sprinkler, deluge sprinkler, water mist, clean air agent, Halon, range hood, CO₂, and dry chemical systems.

(C) Installation. Installation of raceways, boxes, enclosures, cabinets, and wiring shall conform to the following requirements:

(1) Covers of boxes, enclosures and cabinets shall be painted red and permanently identified as to use.

(2) Penetrations through rated walls, ceilings and floors shall be fire stopped.

(3) Raceways or wiring shall not penetrate the top of any control equipment cabinet or enclosure.

(4) Raceways installed up to 2.4 m (8 ft.) in stairways shall not reduce or obstruct required stairway radius or egress path.

(5) Cables shall be secured by cable ties, straps or similar fittings designed and installed so as not to damage the cables. Such fitting shall be secured in place at intervals not exceeding 1.5 m (5 ft.) on center and within 0.3 m (1 ft.) of associated cabinet or box.

Section 760.136

Subsection 760.136(D)(2)(a) - Revise to read as follows:

(a) The fire alarm power-limited circuits are installed using Type FPL, FPLP or permitted substitute cables with Type FPLP 'NYC certified fire alarm cable' or other NYC certified fire alarm cable, provided that these power-limited cable conductors extending beyond the jacket are separated by a minimum of 6 mm (0.25 in) or by a nonconductive barrier from all other conductors.

Subsection 760.136(D)(2)(b) - Delete the subsection in its entirety.

Subsection 760.136(F) - Delete: "rigid nonmetallic conduit" and "liquidtight flexible nonmetallic conduit".

Subsection 760.136(G)(1)(b) – Revise to read as follows:

(b) all of the power-limited fire alarm circuit conductors are in a raceway or in metal-sheathed or metal-clad cables.

Section 760.139

Section 760.139 - Delete the section in its entirety.

Section 760.142

Section 760.142 - Revise to read as follows:

760.142 Conductor Size. Conductors shall not be smaller than #18 AWG in size.

Section 760.143

Section 760.143 - Revise to read as follows:

760.143 Support of Conductors. Power-limited fire alarm circuit conductors shall not be strapped, taped, or attached by any means to the exterior of any piping, duct, conduit, or raceway as a means of support.

Section 760.154

Subsection 760.154(A) - Revise to read as follows:

(A) Cables in Other Spaces Used for Environmental Air. Cables installed in other spaces used for environmental air, or where permitted to run exposed in other areas, shall be Type FPLP 'NYC certified fire alarm cable'.

Subsection 760.154(B)(1) - Revise by replacing "Type FPLR" with: "Type FPLP 'NYC certified fire alarm cable' or other NYC certified fire alarm cable" in each of the two locations.

Subsection 760.154(B)(2) - Revise by replacing "Other" with: "Type FPLP 'NYC certified fire alarm cable'".

Subsection 760.154(C) - Delete the subsection and revise to read as follows:

(C) Other Wiring Within Buildings. Cables installed in building locations other than those covered in 760.154(A) or (B) shall be Type FPLP 'NYC certified fire alarm cable.'

Subsection 760.154(D) - Delete FPN, table 760.154(D) and figure 760.154(D) and revise to read as follows:

(D) **Fire Alarm Cable Substitutions.** Substitutions of Type FPLP or NYC certified fire alarm cables shall not be permitted.

Section 760.176

Section 760.176(G) - Delete the first sentence of the first paragraph, the FPN and the table in their entirety.

Section 760.179

Section 760.179 - Revise the title to read as follows:

760.179 Listing and Marking of PLFA Cables and Insulated Continuous Line-Type Fire Detectors.

Subsection 760.179(B) - Revise to read as follows:

(B) **Conductor Size.** The size of conductors in single or multi-conductor cables shall not be smaller than 18 AWG.

Subsection 760.179(D) - Delete the FPN and revise to read as follows:

(D) **Type FPLP.** Type FPLP power-limited fire alarm cable shall be listed to UL 1424-05, Standard for Cables for Power-Limited- Fire-Alarm Circuits with the listing agency certifying compliance with the following additional requirements:

(1) **Type FPLP only; minimum insulation thickness 15 mils; minimum temperature 150°C.**

(2) **Red colored jacket overall; minimum thickness 25 mils.**

(3) **Cable marked as per UL 1424 must bear additional description "ALSO CLASSIFIED NYC CERT. FIRE ALARM CABLE" legible without removing jacket.**

Subsection 760.179(E) - Delete the subsection in its entirety.

Subsection 760.179(F) - Delete the subsection in its entirety.

Subsection 760.179(G) - Revise by deleting the parenthetic "CI" in the first sentence of the first paragraph and replacing with "CI-NYC certified Circuit Integrity fire alarm cable" and by deleting, "(E), (F)" in the second sentence of the first paragraph

Subsection 760.179(H) - Replace "Type FPLP, FPLR, or FPL cable" at the end of the sentence with "Type FPLP 'NYC certified fire alarm cable'."

Subsection 760.179(I) - Delete the subsection and revise to read as follows:

(I) **Cable Marking.** The cable shall be marked in accordance with subsection 760.179(D)(3) and its rating as 'NYC Cert. Fire Alarm Cable' or 'NYC Cert. Circuit Integrity Cable.'

Subsection 760.179(J) - Revise by deleting "through (F)" in the fourth line of the paragraph.

Subsection 760.179(K) - Add new subsection 760.179(K) to read as follows:

760.179(K) Listed Fire-Rated Assemblies. MI cable meeting the requirements of Article 332 or listed fire-rated assemblies that have a minimum fire rating of 2 hours shall be permitted when installed in accordance with the listing requirements.

STATEMENT OF BASIS AND PURPOSE

This rule repeal and repromulgation relating to fire alarm wiring and power sources is promulgated pursuant to the authority of the Commissioner of Buildings under sections 643 and 1043 of the New York City Charter.

The 2008 New York City Construction Codes, title 28 of the Administrative Code of the City of New York, require that buildings other than existing buildings adhere to the New York City Electrical Code. Article 760 of the New York City Electrical Code requires fire alarm wiring to be installed in accordance with Reference Standard ("RS") 17-3, RS 17-3A, RS 17-3B, and RS 17-3C of the 1968 Building Code, title 27 of the Administrative Code. This rule replaces the provisions of these reference standards relating to fire alarm wiring and power sources: sections 1 and 3 of RS 17-3, sections 1 and 3 of RS 17-3A, sections 1 and 3 of RS 17-3B, and sections 3 and 5 of RS 17-3C. The rule makes corrections and additions to the current version of rule 4000-6 so that all the relevant fire alarm wiring and power source standards are addressed.

The rule adopts article 760 of National Fire Protection Association ("NFPA") 70: National Electrical Code, 2008 edition, along with New York City-specific modifications. Adoption of the requirements of the most recent version of the National Electrical Code, with amendments taking into account New York's unique safety needs and building conditions, will benefit the public by providing technical standards for buildings erected in compliance with title 28 of the Administrative Code and enhancing safety practices. These National Electrical Code amendments may be adopted as part of the 2010 New York City Electrical Code, in which case this rule may be phased out.

Relevant changes from the reference standards include the elimination of archaic terms and references to old and outdated technology, the clarification of grounding requirements, and the establishment of one set of standards across all fire alarm types.

This rule does not apply to an existing building, unless, pursuant to section 28-101.4.3 of the Administrative Code, the existing building undergoes a change in occupancy or an alteration to its fire alarm system. Existing buildings not subject to this rule continue to be bound by the fire alarm wiring and power sources requirements of RS 17-3, RS 17-3A, RS 17-3B, and RS 17-3C of the 1968 Building Code.



NYC Department of Buildings
280 Broadway, New York, NY 10007

Robert D. LiMandri
Acting Commissioner

280 Broadway, 7th Floor
New York, NY 10007
Phone: (212) 566-3103
Fax: (212) 566-3785

Statement of Substantial Need for Earlier Implementation

I hereby find, pursuant to §1043, subdivision e, paragraph 1(c) of the New York City Charter, and hereby represent to the Mayor, that there is substantial need for the implementation of new Section §4000-06 of Title 1 of the Rules of the City of New York, governing fire alarm wiring, upon the publication in the City Record of its Notice of Adoption.

This is one of the Rules needed to implement the City's new Construction Codes. The proposed rule promotes public safety and efficiency by continuing under the new construction codes the practice under Title 27 of the Administrative Code with respect to fire alarm wiring. By continuing current standards, the proposed rule benefits the public by continuing a proven safety practice.

The 2008 code does not provide any requirements for fire alarm wiring and, instead, references the NYC Electrical Code. However, Article 760 of the NYC Electrical Code, which governs fire alarm wiring, does not contain specific requirements and, in turn, refers to RS-17 of the 1968 Building Code. In order to resolve potential conflicts of applicability between the 1968 code and the 2008 code, this rule sets forth the requirements for fire alarm wiring for construction under the 2008 code. Early implementation is necessary to ensure that fire alarm wiring installations comply as soon as possible with this rule's requirements, since the 1968 building code requirements include the Material and Equipment Approval ("MEA") process, which no longer exists.

A handwritten signature in black ink, appearing to read "Robert D. LiMandri".

Robert D. LiMandri
Acting Commissioner
Department of Buildings

APPROVED: A handwritten signature in black ink, appearing to read "Michael R. Bloomberg".
Michael R. Bloomberg
Mayor

DATE: 8/21/08

NOTICE OF ADOPTION OF RULE

NOTICE IS HEREBY GIVEN, pursuant to the authority vested in the Commissioner of Buildings by section 643 of the New York City Charter and in accordance with section 1043 of the Charter, that the Department of Buildings hereby adopts the addition of section 4000-06 of Title 1 of the Official Compilation of the Rules of the City of New York, regarding fire alarm wiring.

This rule was first published on May 28, 2008 and a public hearing thereon was held on July 1, 2008.

Dated: 8/13, 2008
New York, New York



Robert D. LiMandri
Acting Commissioner

Section 1. Title 1 of the Rules of the City of New York is amended by adding a new chapter 4000 and section 4000-06 to read as follows:

Chapter 4000
Electrical Code

§4000-06 Fire alarm wiring.

(a) Scope. Electrical wiring serving fire alarm systems shall be installed in accordance with this rule.

(b) References. Where Article 760 of the electrical code make reference to the installation of wiring and equipment as required by RS 17-3, RS 17-3A, RS 17-3B, and RS 17-3C of the building code, the requirements herein shall replace Section 3 of RS 17-3, Section 1(C)3 of RS 17-3A, 1(C)3 of RS 17-3B, and Section 5 of RS 17-3C.

(c) Construction requirements. Electrical wiring serving fire alarm systems shall comply with the following requirements:

(1) Power conductors (above 75 volts) shall be:

(i) Copper: THHN, THWN/THHN, TFFN, TFN, FEP, RHH, RHW-2, XHH, or XHHW; minimum 600 volts; 90 C; for installation in rigid metallic conduit (RMC), intermediate metallic conduit (IMC) or electric metallic tubing (EMT).

(ii) Cable type MI, listed for 2-hour fire resistance rating.

(2) Low voltage conductors (75 volts and less) shall be:

(i) Copper: THHN, THWN/THHN, TFFN, TFN, FEP, RHH, RHW-2, XHH, XHHW; minimum 600 volts; 90 C; for installation in RMC, IMC or EMT.

(ii) Minimum wire size No.18 AWG.

(iii) Multi-conductor cables run in raceways, or exposed as described hereinafter, and shall be listed to UL 1424-05, Standard for Cables for Power-Limited Fire-Alarm Circuits, with the listing agency certifying compliance with the following additional requirements:

(A) Type FPLP only; minimum insulation thickness 15 mils; minimum temperature 150 C; colored red.

(B) Red colored jacket overall; minimum thickness 25 mils.

(C) Cable marked as per UL 1424 must bear additional description "ALSO CLASSIFIED NYC CERT. FIRE ALARM CABLE" legible without removing jacket.

(3) Installation of conductors and raceways shall be in accordance with the following:

(i) Power conductors shall not be installed in common raceways with low voltage conductors.

(ii) Installations shall comply with applicable requirements of the electrical code, or if the requirements of this rule exceed those of the electrical code shall comply with the requirements of this rule.

(iii) Conductors other than MI cable shall be run in raceway, except as specifically described in item (c)(3)(iv) of this rule.

(iv) Multi-conductor cables may be installed without raceway protection where cables are protected by building construction. Where not protected by building construction, cables shall be located 8 feet (2438 mm) vertical or more above the finish floor and not subject to physical tampering or hazard. Locations within 8 feet (2438 mm) of the finished floor that are deemed as protected by building construction shall include raised floors, shafts, telephone and communication equipment rooms and closets, and rooms used exclusively for fire alarm system equipment. In any suppression and extinguishing system activated by automatic fire detection, including but not limited to pre-action sprinkler, deluge sprinkler, clean air agent, halon, range hood, carbon dioxide and dry chemical, multi-conductor cables shall be installed in RMC, IMC, or EMT.

(v) All wiring within mechanical and elevator equipment rooms shall be run in raceways.

(vi) Raceways run within 8 feet (2438 mm) vertical of the finish floor in garage areas, loading docks, mechanical rooms, and elsewhere where subject to mechanical damage, shall be rigid galvanized steel conduit only.

(vii) Where wiring is required to be run in raceways, install conductors in RMC, IMC, or EMT except that multi-conductor cables may also be run in surface metal raceway. Flexible metallic conduit, not exceeding 36 inches (914 mm) in length, shall be permitted for final connections to initiating and notification devices. Conductors for other electrical systems shall not be installed in raceways containing conductors serving a fire alarm system.

(viii) Where allowed to be run without raceway protection, multi-conductor cables shall be installed as follows:

(A) Cables shall not depend on ceiling media, pipes, ducts, conduits, or equipment for support. Support independently from the building structure.

(B) Secure by cable ties, straps or similar fittings, so designed and installed as not to damage the cable. Secure in place at intervals not exceeding 60 inches (1524 mm) on centers and within 12 inches (305 mm) of every associated cabinet, box or fitting.

(ix) Installation of raceways, boxes and cabinets shall comply with the following general requirements:

(A) Covers of boxes and cabinets shall be painted red and permanently identified as to their use.

(B) Penetrations of fire-rated walls, floors or ceilings shall be fire stopped.

(C) Within stairways, raceways shall not be installed within 8 feet (2438 mm) vertical of the finish floor.

(D) Raceways or cables shall not penetrate top of any equipment box or cabinet.

(x) All conduits supplying 120-volt power to the fire command station and/or fire alarm control unit and/or to outlying control cabinets, shall contain a green insulated grounding conductor sized in accordance with the electrical code (#10 AWG minimum). The grounding conductor shall be connected to the ground bus or other suitable grounding terminal in each box and cabinet in which it enters. At the fuse cutout panel supplying the fire alarm system, a grounding electrode conductor sized and installed in accordance with the electrical code (#10 AWG minimum) shall be provided.

(xi) For cabinets whose 120-volt supply is not derived from the main fire alarm system cutout panel, green insulated separate grounding electrode conductors, sized and installed as per the electrical code (#10 AWG minimum), shall be provided. In steel-framed buildings, a connection to local steel structure will be acceptable.

(xii) Splices and terminations of wires and cables shall be as follows:

(A) Permitted only in boxes or cabinets specifically approved for that purpose.

(B) Utilize mechanical connections specifically approved by UL 486A-03, Wire Connectors or UL 486C-04, Splicing Wire Connectors for the conductors, or if soldered, first joined so as to be mechanically and electrically secure prior to soldering and insulating. Temperature rating of completed splices shall equal or exceed the temperature rating of the highest rated conductor.

(xiii) Wiring for audible and visual alarm notification devices shall be arranged so that a loss of a portion of the wiring on a floor will not render more than 60 percent of the devices of each type inoperative, and the devices shall be so connected to the circuitry (i.e., by means of alternate circuits) as to maintain at least partial audibility/visibility throughout the entire floor.

STATEMENT OF BASIS AND PURPOSE

The foregoing rule is proposed pursuant to the authority of the Commissioner of Buildings under Sections 643 and 1043(a) of the New York City Charter.

The proposed rule promotes public safety and efficiency by continuing under the new construction codes the practice under Title 27 of the Administrative Code with respect to fire alarm wiring. By continuing current standards, the proposed rule benefits the public by continuing a proven safety practice.

Article 760 of the Electrical Code requires fire alarm wiring to be installed in accordance with RS 17-3, RS 17-3A, RS 17-3B, and RS 17-3C of the *New York City Building Code*. Such requirement references Title 27 of the Administrative Code. The requirements herein shall replace Section 3 of RS 17-3, Section 1(C)3 of RS 17-3A, 1(C)3 of RS 17-3B, and Section 5 of RS 17-3C. This rule will facilitate compliance with the practices and standards established under Title 27 by providing technical standards for buildings erected in compliance with Title 28 of the Administrative Code.