

1 RCNY §43-02

CHAPTER 43 INSTALLATION OF SECURITY ITEMS IN MULTIPLE DWELLINGS

§43-02 Installation of Two 50 Watt Lights at Front Entrance Way.*

- (a) All electrical work shall be done in accordance with the requirements and approval of the Department of Buildings.
- (b) The installation shall be a separate circuit or connected to the house line servicing the public halls.
- (c) The lights shall be encased in a metal guard or shatterproof globe.
- (d) The lights of at least 50 watts of incandescent or equivalent illumination shall be placed on each side of the front entrance-way at a height of between 7 to 11 feet above floor level adjacent to such entrance-way and adequate to light same.

**As promulgated, however provisions of the New York City Housing Maintenance Code may require high wattage requirements.*