





**Department of  
Design and  
Construction**

**SPECIFICATION  
BULLETIN**

**SB  
19-001**

**Title: RESTORATION OF PAVEMENT SURFACE**

Prepared: 	1/25/2019	Approved: 	1/25/2019
Richard Jones, P.E. CWI Director, Specifications – Infrastructure Design	Date	Mohsen Zargarelahi, P.E. Associate Commissioner – Infrastructure Design	Date

**APPLICABILITY:**

- This Specification Bulletin (SB) is effective for projects advertised on or after 3/1/2019.

**SUPERSEDEENCE:**

- This SB supersedes the following SBs: **NONE**

**ATTACHMENTS:**

*NONE*

**REVISIONS TO THE NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL  
STANDARD SEWER AND WATER MAIN SPECIFICATIONS, DATED 7/1/2014:**

All references contained below are to the New York City Department of Environmental Standard Sewer and Water Main Specifications, Dated July 1, 2014. Said Standard Sewer and Water Main Specifications are hereby revised as follows:

- a) **Refer** to Pages IV-27 and IV-28, Section 40.08 – TEMPORARY RESTORATION AND CLEANING UP, Subsection 40.08.01 RESTORATION OF PAVEMENT SURFACE;  
**Delete** the text of Subsection 40.08.1;  
**Substitute** the following text:

**40.08.01 RESTORATION OF PAVEMENT SURFACE**

Unless otherwise specified or directed, in all areas where an existing roadway pavement of any type is disturbed by the work done under this contract (i.e. over trenches, excavations, test pits) but not permanently restored immediately thereafter, the Contractor must temporarily restore the surface as follows:

1. Roadway pavements – Boroughs of Brooklyn, the Bronx, Manhattan and Queens: The pavement must be temporarily restored where disturbed with not less than four (4) inches of 6FRA asphaltic concrete mixture, or as specified by the Engineer. The asphaltic concrete mixture must be placed on compacted dirt backfill immediately after completion of backfilling and compaction.



**Department of  
Design and  
Construction**

**SPECIFICATION  
BULLETIN**

**SB  
19-001**

**Title: RESTORATION OF PAVEMENT SURFACE**

2. Roadway pavements – Borough of Staten Island: The pavement must be temporarily restored where disturbed by the work done under this contract (i.e. over trenches, excavations, test pits) but not permanently restored immediately thereafter, the Contractor must temporarily restore the surface of roadway pavements as follows:
  - Water main trenches: Not less than four (4) inches of 6FRA top asphaltic concrete mixture. The water mains must be backfilled to the underside of the asphalt with Select Granular Fill, meeting the requirements of **Section 26.01.2.(B)**.
  - Sewer trenches and other excavations: Not less than four (4) inches of 6FRA top asphaltic concrete mixture. The water mains must be backfilled to the underside of the asphalt with clean fill, meeting the requirements of **Section 26.01.2.(D)**.
3. Sidewalks, all Boroughs: The sidewalk must be temporarily restored where disturbed with not less than two (2) inches of 6FRA asphaltic concrete mixture or as specified by the Engineer. The asphaltic concrete mixture must be placed on compacted dirt backfill immediately after completion of backfilling and compaction.

All temporary restoration must be maintained in acceptable condition until replaced by final restoration.

All temporary pavement must be thoroughly compacted and laid flush with the surrounding pavement.

(NO FURTHER TEXT ON THIS PAGE)