



**Department of
Design and
Construction**

**SPECIFICATION
BULLETIN**

**SB
17-012**

Title: TEMPORARY HOUSE CONNECTION MATERIAL

Prepared:

8/4/2017

Richard Jones, P.E. CWI
Director, Specifications – Infrastructure Design

Approved:

8/4/2017

Gurdip Saini, P.E.
Associate Commissioner – Infrastructure Design

APPLICABILITY:

- This Specification Bulletin (SB) is effective for projects advertised on or after 9/1/2017.

SUPERSEDEENCE:

- This SB supersedes the following SBs: **NONE**

ATTACHMENTS:

NONE

REVISIONS TO THE NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION STANDARD SEWER AND WATER MAIN SPECIFICATIONS, DATED 7/1/14:

All references contained below are to the New York City Department of Environmental Protection Standard Sewer and Water Main Specifications, Dated July 1, 2014. Said Standard Sewer and Water Main Specifications are hereby revised as follows:

- a) **Refer** to Pages I-8, Section 10.13 – FLOW OF SEWERS AND DRAINS, ETC. INTERRUPTED; SEWERS TO BE KEPT CLEAN; REMOVING AND ABANDONING SEWERS, WATER MAINS, ETC., Sub-Section (1), 3rd Paragraph (“Where the Contractor’s construction...”);

Add to the end of the paragraph:

“All temporary house connection materials, including hoses or tubing, shall be certified per NSF/ANSI 61: “Drinking Water System Components – Health Effects.” The Contractor shall submit to the Engineer certificates of compliance with NSF/ANSI 61 for all temporary house connection materials prior to their use. Garden hoses, hoses specified for industrial use, or other materials not intended for potable water supply shall not be used.”

(NO TEXT THIS PAGE)