


GEOHERMAL SCREENING WEBTOOL PRE-FEASIBILITY



NEW YORK CITY MAYOR'S OFFICE OF SUSTAINABILITY IN COLLABORATION WITH USGS

Prepared For:



Prepared By:



Forward

New York City passed Local Law 6 of 2016 that required the City to develop, and make publicly available, a pre-feasibility screening tool to determine the viability of installing a geothermal system for a particular building. Under the guidance of the Mayor’s Office of Sustainability (MOS) and Department of Design and Construction (DDC), Goldman Copeland, along with the help of PW Grosser and OverMorgen, created this tool based on professional experience, case studies, and the publicly available geology data from the United States Geological Survey (USGS) and building information. This report serves as a basis of understanding on how the tool was built, how it operates, and what exactly it is meant to accomplish.

TABLE OF CONTENTS

| | |
|---|-----------|
| FORWARD | 1 |
| 1.0 EXECUTIVE SUMMARY..... | 3 |
| 2.0 BACKGROUND..... | 4 |
| 3.0 PROJECT OVERVIEW | 4 |
| 4.0 METHODOLOGY SUMMARY..... | 4 |
| 4.1 GEOLOGICAL AND TECHNICAL SUITABILITY..... | 4 |
| 4.2 GROUND THERMAL CAPACITIES | 5 |
| 4.3 BUILDING DEMAND VERSUS AVAILABLE GROUND THERMAL CAPACITY..... | 5 |
| 4.4 ECONOMIC FEASIBILITY..... | 6 |
| 5.0 SCREENING TOOL FUNCTIONALITY..... | 6 |
| 6.0 ASSUMPTIONS AND CONDITIONS..... | 7 |
| 6.1 MECHANICAL SYSTEMS..... | 7 |
| 7.0 GEOTHERMAL HEAT PUMPS (GHP) SYSTEMS REVIEW | 10 |
| 7.1 HYBRID SYSTEMS..... | 10 |
| 8.0 GEOLOGY AND GEOTHERMAL CAPACITIES | 11 |
| 8.1 GEOLOGIC DATA AND MAPPING..... | 11 |
| <i>Depth to Bedrock</i> | <i>11</i> |
| <i>Depth to Water</i> | <i>11</i> |
| <i>Depth to Lloyd Aquifer</i> | <i>12</i> |
| 8.2 GEOLOGIC SUITABILITY | 13 |
| <i>Closed Loop</i> | <i>13</i> |
| <i>Standing Column Wells</i> | <i>13</i> |
| <i>Open Loop.....</i> | <i>14</i> |
| 8.3 TECHNICAL SUITABILITY | 15 |
| <i>Closed Loop</i> | <i>15</i> |
| <i>Standing Column Wells</i> | <i>15</i> |
| <i>Open Loop.....</i> | <i>16</i> |
| 8.4 POTENTIAL GROUND THERMAL CAPACITY CALCULATIONS | 17 |
| <i>Closed Loop.....</i> | <i>17</i> |
| <i>Standing Column Wells</i> | <i>18</i> |
| <i>Open Loop.....</i> | <i>18</i> |
| 9.0 BUILDING LOAD AND FEASIBILITY | 19 |
| 9.1 BUILDING TYPE PARAMETERS | 19 |
| 9.2 ENERGY CONSUMPTION | 20 |
| 9.3 ECONOMIC FEASIBILITY..... | 21 |
| APPENDICES | 22 |

1.0 Executive Summary

The objective of this report is to provide the end user with a clear understanding of the how the tools development methodology and the summary of results found throughout New York City. Overall, three different geothermal systems (closed loop, standing column well, and open loop) were analyzed for potential implementation in comparison to installing a conventional HVAC system. Buildings were categorized into 25 different building types based on vintage, size, and occupancy to establish a baseline for thermal load and the conventional energy consumption. Potential ground thermal capacity was determined by calculating the amount of thermal capacity that could be accessed by wells or loops installed within the available outdoor area on each lot.

Positive results were limited in Manhattan and the Bronx where building loads often exceed the potential thermal capacity accessible using the available outdoor area. Staten Island, Queens, and Brooklyn demonstrate promising results as outdoor area for drilling is much more prevalent and building loads are generally less intense. The majority of commercial buildings were deemed not feasible due to the large cooling load that they require and the limited outdoor area available. Of the feasible lots in New York City the majority were small multifamily buildings or single-family homes where the outdoor space available is sufficient to meet the heating and cooling requirements for those buildings. While our generic installation costs suggested these locations may be feasible, a site-specific review may result in additional costs that negatively impact the payback period of the project. All decisions should be made only after completing an in-depth feasibility study for the site.

| Borough | Payback Period | Closed Loop | | Standing Column Well | | Open Loop | |
|---------------|----------------|-------------|-----------|----------------------|-----------|-----------|-----------|
| | | # of Lots | % of Lots | # of Lots | % of Lots | # of Lots | % of Lots |
| Manhattan | < 12 Years | 8402 | 20% | 0 | 0% | 73 | 0% |
| | < 25 Years | 438 | 1% | 10286 | 24% | 6 | 0% |
| | ≥ 25 Years | 33846 | 79% | 32400 | 76% | 42607 | 100% |
| Bronx | < 12 Years | 68908 | 77% | 0 | 0% | 365 | 0% |
| | < 25 Years | 2103 | 2% | 6227 | 7% | 4 | 0% |
| | ≥ 25 Years | 18674 | 21% | 83458 | 93% | 89316 | 100% |
| Brooklyn | < 12 Years | 203626 | 74% | 0 | 0% | 69788 | 25% |
| | < 25 Years | 4322 | 2% | 3106 | 1% | 176 | 0% |
| | ≥ 25 Years | 68872 | 25% | 273803 | 99% | 206945 | 75% |
| Queens | < 12 Years | 267253 | 82% | 0 | 0% | 200703 | 62% |
| | < 25 Years | 11407 | 4% | 3601 | 1% | 43 | 0% |
| | ≥ 25 Years | 45508 | 14% | 320567 | 99% | 123422 | 38% |
| Staten Island | < 12 Years | 111904 | 90% | 11 | 0% | 51708 | 42% |
| | < 25 Years | 0 | 0% | 51356 | 41% | 0 | 0% |
| | ≥ 25 Years | 11885 | 10% | 72422 | 59% | 72081 | 58% |

Table 1: Results for All Five Boroughs in NYC

The results are explained in more detail throughout this report.

2.0 Background

New York City has committed to reducing its total greenhouse gas (GHG) emissions by 80%, relative to 2005 levels, by 2050 (80 x 50). As described in *New York City's Roadmap to 80 x 50*, meeting heating needs in buildings through the use of heat pump technology is a necessary component in the reduction of our fossil fuel consumption and their associated GHG emissions. One method to efficiently utilize heat pump technology for both heating and cooling is through the use of geothermal systems.

As per Local Law 32 of 2013, the City published *Geothermal Systems and their Application in New York City*, which analyzed the application of geothermal heat pump systems in New York City. This report pointed to the many potential benefits of geothermal systems and their ability to reduce GHG emissions. However, the success of these systems is site-specific and dependent on many variables. Ground source heat pumps should be deployed in the city where they can meet a building's heating and cooling needs cost-effectively.

Following the results of the report, NYC Council passed Local Law 6 of 2016, requiring the City to produce a publicly-available online geothermal heat pump screening tool to provide a threshold assessment of the potential for the use of ground source heat pumps for buildings within New York City.

3.0 Project Overview

The overall purpose of the screening tool is to provide a threshold assessment of the potential for using ground source heat pumps for buildings within New York City. This assessment is based on key known variables, including but not limited to, building thermal demand, land area availability for drilling, and geology at the Borough-Block-Lot (BBL) level. The results provided by the tool are based on a feasibility analysis of three different ground coupling systems (closed loop, standing column well, and open loop) on every building lot. Building owners or other interested parties can choose the location of their building on a web based map which will provide them with a simple payback period to guide them in a decision to fully review project cost, savings, and feasibility.

It is important to note that the tool is limited by the wide variety of actual building stock in New York City and therefore cannot be taken as a guarantee that a geothermal system is feasible. In addition, subsurface geologic conditions beneath a BBL are uncertain without actual drilling and can vary from the inferred mapped conditions thereby affecting system feasibility. Detailed descriptions and information on the evaluation, design and operation of GHPs is provided in DDC's *Geothermal Heat Pump Manual: A Design and Installation Guide for New York City*, (Geothermal Heat Pump Manual) (2013).

4.0 Methodology Summary

The methodologies for the calculations are summarized below.

4.1 Geological and Technical Suitability

Each lot first underwent a "geologic suitability" test, whereby a determination was made of which geothermal systems are suitable based on the underlying geologic and hydrogeologic conditions available from the USGS. Then, for each

geothermal system that is geologically suitable, its “technical suitability” was determined. Technical suitability reviews the lot specific conditions that affect overall thermal capacity and project costs. If either of these criteria are not met the lot is deemed not suitable.

The assumptions for geologic and technical suitability are summarized in Table 2 below along with the default depths for wells and loops used in the tool.

| | Closed Loop | Standing Column Well (SCW) | Open Loop |
|-----------------------------------|--|--|---|
| Default Depth | 500 ft., deeper depths require obtaining NYSDEC mining permit | 1,500 ft., standard SCW depth in NYC | Depths variable depending on geologic conditions |
| Geologic Suitability Assumptions | Suitable everywhere, can be installed in both bedrock and unconsolidated geologic deposits | Suitable where DTB is less than 150 ft. and DTW is less than 100 ft. | Suitable where lot overlies a sand and gravel aquifer (not bedrock) and DTW is less than 100 ft. |
| Technical Suitability Assumptions | Suitable but unit thermal capacity is lower where the Lloyd aquifer exists less than 500 ft. deep. | Suitable but potentially costly where DTB is between 100 and 150 ft. | Suitable where lot is large enough to space out supply and diffusion wells, and there is sufficient outdoor area to install wells |

Table 2: Geologic and Technical Suitability Assumptions

4.2 Ground Thermal Capacities

If a lot passed the geologic and technical suitability tests, the tool calculated its ground thermal capacity and carried it through subsequent calculations. Ground thermal capacities were determined by:

1. Establishing the thermal capacity of a standard individual loop or well for each of the geothermal systems using standard industry values and local experience as referenced in the DDC *Geothermal Heat Pump Manual*.¹
2. Calculating unit ground thermal capacities in Btus per square foot (sf) over the estimated area of influence of an individual loop or well.
3. Calculating the outdoor area available for the installation of the ground coupling of each type of geothermal systems for each building lot by using block and lot size, and building footprint and square footage data from Primary Land Use Tax Lot Output (PLUTO).
4. Multiplying the unit ground thermal capacities by the outdoor area.

4.3 Building Demand versus Available Ground Thermal Capacity

For each suitable system type on a lot, the first test for feasibility was to determine if the geothermal ground coupling could access ground thermal capacity in the available outdoor area that is close to or exceeds the building’s peak and annual heating and cooling loads. This feasibility was determined by:

¹ Nominal capacities are 25 tons per 1,500 ft. deep standing column well, 2.86 tons of heating/cooling capacity per 500 ft. deep closed loop borehole (1 ton per 175 linear feet), and 1 ton of heating/cooling capacity per 2-3 gallons per minute of groundwater flow from an open loop supply well.

1. Determining the approximate building annual heating and cooling loads based on building size, type, and vintage.
2. Determining the dominant load (heating or cooling).
3. Comparing the ground thermal capacity with the building dominant load to determine if sufficient capacity is available, and if annual heating/cooling loads are sufficiently balanced.
4. Reviewing the potential to use a hybrid system to achieve balance if required.

4.4. Economic Feasibility

Where sites were deemed to be feasible as above for a geothermal system, further review was completed to determine economic feasibility of the system as follows:

1. All economic evaluations were completed based on the assumption that the building was planning a full heating/cooling system upgrade. As such, baseline evaluations were completed for each building type, size, and vintage based on current standard, code compliant systems.
2. Sample building baselines were developed to estimate energy consumption and installation costs for standard systems, and applied to all buildings.
3. Based on the ground thermal capacity calculations as described above, and typical geothermal systems, energy consumption, and installation costs were developed and applied to all buildings where these systems were feasible.
4. Annual tons of carbon dioxide equivalent (CO₂e) was calculated based on baseline energy usage versus the geothermal systems. Site to source ratios for electricity and other utilities were used to assure the full scope of GHG emissions was accounted for.
5. Price comparisons were completed based on energy savings with the geothermal system, comparative maintenance costs, a carbon credit as determined by the MOS, and anticipated installation costs.
6. An incremental simple payback period was determined for replacement of the existing system with a geothermal system versus a typical system, and a general recommendation was provided based on these findings.

5.0 Screening Tool Functionality

All analysis completed as a part of this project were then exported to a web-based map for public access. The map enables the user to access the following information upon selection of any lot or building in New York City:

1. Basic lot/building information including lot size, building indoor area (SF), building footprint (SF), and building type for confirmation.
2. Geological/technical feasibility of each geothermal system types.
3. Depth to bedrock (all boroughs) and depth to groundwater (all boroughs, excluding Manhattan and Bronx).
4. Carbon footprint reduction and cost savings with installation of geothermal.

5. Simple payback period analysis based on energy savings and initial costs associated with installation of geothermal, with and without the carbon credit.
6. An option to override basic building information including building type, footprint, and square footage is also included; the tool re-runs the calculations and provides an output for the new building.
7. As is noted within the tool, all findings are preliminary and should not be taken as a guarantee that a full study will determine installation of a geothermal study to be feasible.

As mentioned above, in addition to enabling users to assess existing buildings for geothermal, an override function is available to enable users to investigate the possibility of installing geothermal systems with new construction for any lot or combination of lots in the city.

6.0 Assumptions and Conditions

A number of caveats must be attached to the results. First, all space not occupied by the building was assumed to be available and accessible for the installation of the geothermal system. This may not always be the case. Further evaluation is necessary to ensure that the land is not archeologically significant, protected marshland, or contaminated. The City's critical infrastructure, such as water tunnels, shafts, or appurtenant facilities are regulated by the New York City Department of Environmental Protection ("DEP"). DEP is in the process of promulgating rules to require that any boring, drilling or excavation to a depth of 50 feet in the borough of the Bronx or north of 135th Street in the borough of Manhattan or to a depth of 100 feet in any other location / borough in New York City first be reported to DEP. Please send written notification of intention to drill or excavate to: Chief of Site Connection and Plan Review, Bureau of Water and Sewer Operations, 9605 Horace Harding Expy, 3rd Floor, Flushing, NY 11368-4100.

Second, economic analysis was a comparison between the installation of a geothermal system and the installation of an energy code compliant high efficiency centralized system. However, both system types may be beyond the financial capacity of some building owners. With incentives in place to support the installation of geothermal systems, a full economic analysis should be completed in advance of any decision.

Other consideration in implementing a geothermal system might include preserving building aesthetics or making a statement for clean energy as a public relations initiative. As such, in addition to economic feasibility, the final tool presents the user with technical and geological feasibility. This provides the end user with the option of pursuing a geothermal solution where it may not be viable to install a cooling tower on the roof or a boiler in the basement. The geothermal systems perform all heat rejection and absorption within the ground and utilize minimal building square footage which is appealing to buildings that suffer from the constraints mentioned above.

Further details of the analysis process are described in the sections below.

6.1 Mechanical Systems

As mentioned previously in this report, the mechanical systems proposed for the conventional systems were assumed to be energy code compliant high efficiency centralized systems. Although the existing buildings may not currently have a centralized system (i.e. window units or no air conditioning at all), the only way to justify the economic cost of installing a geothermal system was to compare it with a full renovation of the HVAC system in

the building. For the 25 building types, as defined by the Technical Working Group, three conventional cooling systems and four conventional heating systems were analyzed and applied to the appropriate buildings.

For cooling, a cooling tower and heat pump system was the most comparable technology to a geothermal system and that is what was used for the large multifamily and NYCHA buildings. Similarly, for commercial buildings, the conventional system was assumed to be a cooling tower with packaged AC units. Although buildings normally have a chiller to perform cooling in the summer, packaged AC units were used for ease of comparison with geothermal heat pump systems as the refrigeration cycle is similar throughout and the relevant piece of equipment is the cooling tower which is performing the heat rejection. The smaller multifamily, K-12 schools, and single-family buildings were the only building types assumed to use air cooled packaged units. These units are less efficient than the water cooled packaged units and therefore an air-cooled kW/ton penalty was attributed to the energy consumption. Warehouses were assumed to not have any cooling equipment.

Heating was assumed to be heating hot water throughout with the only difference being the type of boiler being used. In Manhattan, commercial buildings that were greater than 7 stories and built before 1980 were assumed to utilize district steam and a heat exchanger to produce heating hot water. In the remaining boroughs, it was assumed that a condensing boiler would be used. Condensing boilers were used for the majority of the building types, minus K-12 schools and warehouses which used standard boilers. NYCHA buildings were assumed to utilize steam boilers as is common in most NYCHA buildings currently. It should be noted that because warehouses were considered heated but not cooled they were immediately disqualified from the feasibility study as their heating and cooling balance would not work.

See Table 3 below for full breakdown.

| Building Type | Building Description | Cooling System | Heating System |
|---------------|--|-----------------------------------|--|
| C1 | Commercial, Post-1980 > 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler |
| C2 | Commercial, Post-1980 up to 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler |
| C3 | Commercial, Post-war > 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler (District Steam in MN) |
| C4 | Commercial, Post-war up to 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler |
| C5 | Commercial, Pre-war > 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler (District Steam in MN) |
| C6 | Commercial, Pre-war up to 7 Stories | Cooling Tower + Packaged AC Units | Condensing Boiler |
| C7 | Commercial, Very Large | Cooling Tower + Packaged AC Units | Condensing Boiler |
| IN1 | Hospital and Health Facilities | Cooling Tower + Packaged AC Units | Condensing Boiler |
| IN2 | Institutional General | Cooling Tower + Packaged AC Units | Condensing Boiler |
| IN3 | K-12 Schools | Packaged Air Cooled AC Units | Standard Boiler |
| IN4 | Religious | Cooling Tower + Packaged AC Units | Condensing Boiler |
| IN5 | University | Cooling Tower + Packaged AC Units | Condensing Boiler |
| MF1 | Multifamily, Post-1980 > 7 Stories | Cooling Tower + Heat Pumps | Condensing Boiler |
| MF2 | Multifamily, Post-1980 up to 7 Stories | Split System AC Units | Condensing Boiler |
| MF3 | Multifamily, Post-war > 7 Stories | Cooling Tower + Heat Pumps | Condensing Boiler |
| MF4 | Multifamily, Post-war up to 7 Stories | Split System AC Units | Condensing Boiler |
| MF5 | Multifamily, Pre-war > 7 Stories | Cooling Tower + Heat Pumps | Condensing Boiler |
| MF6 | Multifamily, Pre-war up to 7 Stories | Split System AC Units | Condensing Boiler |
| MF7 | Multifamily, Very Large | Cooling Tower + Heat Pumps | Condensing Boiler |
| NYCHA | New York City Housing Authority | Cooling Tower + Heat Pumps | Steam Boiler |
| SF1 | 1 - 4 Family, Free Standing Wood Frame | Split System AC Units | Condensing Boiler |
| SF2 | 1 - 4 Family, Row House, Masonry | Split System AC Units | Condensing Boiler |
| W1 | Warehouse/Factory > 3 Stories | - | Standard Boiler |
| W2 | Warehouse/Factory up to 3 Stories | - | Standard Boiler |
| W3 | Transportation, Garages, and Utilities | - | Standard Boiler |

Table 3: Building Type Conventional System Breakdown

7.0 Geothermal Heat Pumps (GHP) Systems Review

Geothermal Heat Pump (GHP) systems are a growing sector in the space conditioning market as energy efficiency has become a critical issue in building operations. GHPs have been successfully operated for decades in virtually every building type for both heating and cooling. However, within New York City, GHP use has been limited by a number of factors, including the geology of the city, the density of its buildings, and the high cost of construction.

While there are three types of systems considered in this study (closed loop, standing column well, and open loop), all three provide the same function within the building. Each system extracts heat from the ground in the winter to provide space heating, and rejects this heat back into the ground in the summer to provide cooling. This is typically accomplished with water as the medium of heat transfer. The water is delivered to heat pumps throughout the building where, with the use of a typical refrigeration loop, air is conditioned for delivery to the building. The main difference between the three systems is the ground coupling, or the arrangement of piping and fluid handling equipment depending on the geology of the earth. For more information on each type of system and their application in New York City, please refer to the *Geothermal Heat Pump Manual* and *Geothermal Systems and their Application in New York City*, respectively.

7.1 Hybrid Systems

All three of the systems can be used with supplemental heat rejection provided by cooling towers or supplemental heat supply by condensing boilers. Both can be used in conjunction when peak heating and cooling loads are not quite met by the geothermal capacity or where the heating/cooling balance is greater than acceptable. For the purposes of this tool it was assumed that if the heating/cooling balance is greater than 30% than a hybrid system was necessary. After a more precise site-specific feasibility study is completed, it may be necessary to utilize a hybrid system even with a closer balance. This increases system cost, but may still be economical in some cases.

8.0 Geology and Geothermal Capacities

The viability of geothermal systems on a lot and the type(s) of ground coupling that is suitable depends on the underlying geological conditions. Larger versions of the maps included in the section can be found in Appendix D.

8.1 Geologic Data and Mapping

As part of an ongoing mapping project, the USGS compiled geologic data from several City agencies into a preliminary GIS database that was used in the screening tool. The data provided by USGS were for depth to bedrock and depth to groundwater. Published USGS data for the Lloyd Aquifer in Brooklyn and Queens was also incorporated into this tool. Limitations associated with this aquifer are addressed below in this report.

Depth to Bedrock

Depth to bedrock (DTB) was one of two criteria used to delineate the geologic suitability of standing column wells (SCWs). Figure 1 indicates DTB throughout the city.

Depth to Water

Depth to water (DTW) was the second criteria used to delineate the geologic suitability of SCWs, and one of two criteria used for the open loop system. At the time of publication, data was only available for Staten Island, Brooklyn, and Queens. Data for Manhattan and the Bronx is limited. Figure 2 is the DTW map provided by USGS.




Figure 1: USGS Preliminary Depth to Bedrock for the Five Boroughs of New York City




Figure 2: USGS Preliminary Depth to Water Map for Kings, Queens, and Richmond Counties, NY

Depth to Lloyd Aquifer

The Lloyd is a protected aquifer that is reserved for usage only by coastal communities in Nassau and Suffolk Counties. Depth of the top of this aquifer varies, and in some areas, falls within the typical depth for open loop and closed loop systems. The New York State Department of Environmental Conservation (NYSDEC) has imposed a moratorium on any new wells being installed in this aquifer. In addition, drilling into this protected aquifer is not permitted. All references in this study to the top of the Lloyd aquifer are for estimation of the maximum depth available for geothermal applications and is not an endorsement to drill into the Lloyd aquifer by NYC. It is highly recommended that project managers research the hydrogeology carefully in the area of their projects and review any planned drilling to insure a safety factor of at least 50 feet above the estimated depth to the top of Lloyd aquifer. The estimated depths presented in this report are estimates since the hydrogeology in parts of NYC can be highly variable and complex. Figure 3 indicates the extent of the Lloyd Aquifer and the depth to the top of the Lloyd. This figure also presents the areas where the Lloyd Aquifer exists with estimated iso-contour lines. Due to the limitations on the mapping data, care should be taken that these are estimates of the depth to the top of the Lloyd aquifer




Figure 3: Estimated Depth to the top of the Lloyd Aquifer in Kings and Queens Counties, NY

Using the updated USGS data and information developed in the *Geothermal Heat Pump Manual*, criteria was established where the “geologic suitability” and “technical suitability” of a geothermal system on a lot can be determined. If a site passes the geological suitability test, it proceeds to the technical suitability test. If a site also passes that test, it proceeds to the ground thermal capacities calculation and calculations developed related to the feasibility to meet the building demand or not, etc.

The approach and assumptions for determining geologic suitability, technical suitability, and ground thermal capacity are discussed below for each system type.

8.2 Geologic Suitability

Geologic suitability is described below by GHP type and is illustrated in Figures 4, 5, and 6. These maps are updated versions found in the *Geothermal Heat Pump Manual*. More detailed information on geothermal systems and their suitability to geology is presented in the *Geothermal Heat Pump Manual*.

Closed Loop

Only vertical, closed loop systems were evaluated for the screening tool, per Local Law 6 of 2016 requirements. Closed loop systems are not dependent on the presence of groundwater and can be installed in both unconsolidated geologic deposits as well as bedrock. Therefore, closed loop systems are geologically suitable throughout the city (Figure 4).

Standing Column Wells

A SCW is designed to be installed predominantly in bedrock rather than unconsolidated deposits. A steel, 'surface casing' for a SCW is required to extend a minimum of 75 ft. into competent bedrock as per NYSDEC regulations and as cited in the *Geothermal Heat Pump Manual*.² Below this depth, the well is a self-supporting, uncased open borehole. If the DTB is greater than 150 ft., the high cost for additional steel casing becomes cost prohibitive.³

Therefore, for the tool, SCWs are geologically suitable where the DTB is less than 150 feet (see Figure 5 developed by PWGC from the preliminary GIS DTB data provided by the USGS). A second test of geologic suitability for SCWs was applied if




Figure 4: Closed Loop Suitability




Figure 5: Standing Column Well Suitability

² NYSDEC routinely accepts waivers of 50 ft. into bedrock.

³ The *Geothermal Heat Pump Manual* states that the installation costs for SCWs increases as DTB increases above 100 ft. and is cost-prohibitive above 150 ft.

the lot passed the DTB test. Where DTW is greater than 100 ft., SCWs are not geologically suitable due to the high cost of pumping groundwater to the building.

Open Loop

Open loop systems are geologically suitable where permeable unconsolidated deposits exist, e.g., sand and gravel aquifers. These aquifers have been extensively mapped by USGS. Figure 6 shows the areas where these aquifers exist throughout the city and open loop systems may be suitable. The thickness, depth, yield, and water quality of these aquifers vary significantly from one area to another.

An open loop system also requires DTW to be less than 100 ft., consistent with the *Geothermal Heat Pump Manual*, before proceeding to the technical suitability test and beyond.




Figure 6: Open Loop Suitability

8.3 Technical Suitability

If a geothermal system is geologically suitable for a lot, a second test is run to determine if it is “technically suitable.”

These criteria are explained below by system type and technical suitability is illustrated in Figures 4, 5, and 7. System technical suitability is discussed in more detail in the *Geothermal Heat Pump Manual*.

Closed Loop

The thermal capacity of a closed loop borehole is primarily dependent on the depth of each loop. At depths greater than 500 feet a NYSDEC mining permit is required. Obtaining this permit is potentially time-consuming and costly. Therefore, virtually all closed loop projects terminate at 500 ft. or less, and 500 ft. is the default depth in the tool.

Some closed loops may be less than 500 feet in areas where the Lloyd Aquifer exists; therefore, shallower borehole (loop) depths will result in a lower unit thermal capacity per loop. The unit thermal capacity of a 500-foot-deep closed loop is 2.8 tons/loop, or 33.6 kBtu/loop. Where the Lloyd aquifer is absent, or deeper than 500 feet beneath a lot, the unit thermal capacity per loop was applied. Where the top of the Lloyd is shallower than 500 feet, the thermal capacity of the loops on the lot were reduced proportionally.

Figure 4 indicates the extent of the Lloyd aquifer and where it is shallower than 500 feet deep; boreholes on lots that fall within the cross-hatched area will have a lower thermal capacity than the standard borehole because shallower boreholes will provide less thermal capacity.

Standing Column Wells

The SCW depth in the tool was set at 1,500 ft., which is the typical depth of wells installed in the city and as cited in the *Geothermal Heat Pump Manual*. Unlike closed loop boreholes, permits and approvals are required to drill SCWs, including the NYSDEC mining permit noted above under closed loop.

The *Geothermal Heat Pump Manual* states that SCWs are feasible where DTB is less than 100 ft. deep, and both cost-prohibitive and technically infeasible (i.e., cannot physically be constructed) where DTB exceeds 200 ft. Between 100 and 200 ft. the cost of SCWs increases as depth increases. In the tool, SCWs are technically suitable where DTB is less than 150 ft. deep, however, the end user should be aware that installation costs may be higher than the tool presents where the DTB exceeds 100 ft.


Figure 5 on page 13 delineates three areas, where DTB is less than 100 feet (green), between 100 feet and 150 feet (yellow), and greater than 150 feet (red).

Open Loop

Proper spacing is required between the supply and diffusion wells of an open loop system to avoid thermal interference, a condition by which the thermally-altered water is drawn back into the supply wells. Additionally, sufficient spacing is required between individual supply wells, and individual return wells, to avoid hydraulic interference between the wells creating an excessive “drawdown” or “mounding” effect near each well.

These criteria are lot-specific, in contrast to geology-specific for closed loop and SCW systems. Therefore, there is no map of technical suitability. Instead, Figure 7 illustrates the minimum outdoor area and lot size thresholds for systems of various demand ranges. Calculations using these requirements were completed through ArcGIS to determine technical suitability for individual lots.

**FIGURE 7
OPEN LOOP TECHNICAL SUITABILITY**



| Open Loop - Technical Suitability | | | | | | |
|-----------------------------------|------------------------|------------|---------------------------------|------------------|---------------------------|-----------------------|
| Dominant Demand (tons) | Dominant Demand (kBtu) | Flow (gpm) | No. of Wells (@50-135 gpm cap.) | | Outdoor Area Minimum (sf) | Lot Area Minimum (sf) |
| | | | SW | RW | | |
| 0-25 | 0-300 | Up to 50 | 1 | 1 ⁽¹⁾ | 800 | 1,900 ⁽¹⁾ |
| 25-50 | 300-600 | 50 - 100 | 1 | 2 | 800 | 4,800 |
| 50-100 | 600-1,200 | 100-200 | 2 | 4 | 2,500 | 7,200 |
| 100-200 | 1,200-2,400 | 200 - 400 | 3 | 5 | 3,200 | 32,000 |
| >200 | >2,400 | > 400 | >3 | >5 | 4,000 | 54,600 |

NOTES:
(1) 0-300 kBtu Dominant Demand Lot Area Minimum is 1,900 sf to capture 20' x 100' lots, which constitute a high percentage of lot sizes throughout the city.

8.4 Potential Ground Thermal Capacity Calculations

After determining geological and technical suitability, potential ground thermal capacity (GTC) was calculated for each lot and geothermal system type to compare to the building demand and determine geothermal feasibility as presented in Section 8. Every effort was made to provide accurate analysis of potential ground thermal capacity for each site; however, all calculations are generalized and do not take the place of a detailed site-specific study. The procedures used to calculate GTC are presented separately below for closed loop, SCWs, and open loop systems

Closed Loop

The GTC for a closed loop system was determined by first calculating the maximum number of loops that could “fit” in the available open area of each lot using the “Point Grid Method” (Zhang and Soga, 2015). Using ArcGIS software, 25 iterations of point-grids were spaced across the city, where each point represented a closed loop. The points/loops were spaced 20-ft. apart, which is the minimum spacing cited in the *Geothermal Heat Pump Manual*, and after each iteration the grid was shifted over then down four feet. For each iteration, the number of points that fell within the open area was recorded. The maximum number over all iterations was finally multiplied by 2.8 tons, or 33.6 kBtu, per 500-ft. loop to arrive at the GTC.⁴

Where the Lloyd aquifer exists and restricts the allowable drilling depth to less than 500 ft., the per loop capacity was reduced proportionally (depth of the aquifer/500 ft.). Figure illustrates the Point Grid Method results for a portion of Bronx following six iterations.

When the open area or building footprint is overwritten by the user, a new potential GTC needs to be calculated. The Point Grid Method could not be integrated into the tool functionality. Instead, the results of the Point Grid Method were back-calculated to develop unit thermal capacities (tons or Btus per square foot) that are multiplied by the new open area.



Figure 8: Closed Loop Point Grid Map

⁴ 2.8 tons equals the industry-standard rule of thumb thermal capacity of 175 linear ft./ton of drilled borehole, multiplied by 500 ft.; this is an average value consistent with ASHRAE estimates for the geologic deposits that exist beneath the city, and is in the middle of the range value cited in the *Geothermal Heat Pump Manual* of 2.5-3.3 tons per 500-ft. borehole

Standing Column Wells

The GTC for SCWs was calculated using the same techniques as the closed loop system. The Point Grid Method was used initially to determine the maximum number of wells that could fit in the available open area of each lot within a subarea of Staten Island where SCWs are geologically and technically suitable.⁵ The points/wells were spaced 50-ft. apart, which is the minimum spacing cited in the Geothermal Heat Pump Manual, and after each iteration the grid was shifted over then down five feet, for a total of 100 iterations. The maximum number of wells over all iterations was multiplied by 25 tons, or 300 kBtu, per 1,500-ft. well to arrive at the GTCs for the lots in this subarea.⁶

Like the closed loop system, unit thermal capacities were back-calculated from the Point Grid Method results and were applied for both the baseline and override tool options for SCWs. Figure 9 illustrates the Point Grid Method results for the portion of Staten Island analyzed.



Figure 9: SCW Point Grid Map

Open Loop

Based on the well system flow/capacity versus lot areas shown on Figure 7, there is a direct linear relationship between peak capacity/flow and total lot size, equal to 0.048 kBtu/SF. Potential GTC was calculated for each lot by multiplying the lot outdoor area by this factor. The same factor is applicable when the outdoor area is overwritten; the new potential GTC is calculated by multiplying the new outdoor area by 0.048 kBtu/SF.

⁵ The entire area where SCWs are suitable, i.e., remaining area of Staten Island, and all of Manhattan and the Bronx, could not be used this analysis due to computational constraints.

⁶ 25 tons is in the middle of the range value cited in the *Geothermal Heat Pump Manual* of 15-42 tons per 1,500-ft. well

9.0 Building Load and Feasibility

A previous analysis completed by the Mayor’s Office of Sustainability divided building types into a number of categories based on findings by the Buildings Technical Working Group (TWG), as summarized below.

9.1 Building Type Parameters

| Building Type | Building Description | Building Type | Building Description |
|---------------|---------------------------------------|---------------|--|
| C1 | Commercial, Post-1980 > 7 Stories | MF1 | Multifamily, Post-1980 > 7 Stories |
| C2 | Commercial, Post-1980 up to 7 Stories | MF2 | Multifamily, Post-1980 up to 7 Stories |
| C3 | Commercial, Post-war > 7 Stories | MF3 | Multifamily, Post-war > 7 Stories |
| C4 | Commercial, Post-war up to 7 Stories | MF4 | Multifamily, Post-war up to 7 Stories |
| C5 | Commercial, Pre-war > 7 Stories | MF5 | Multifamily, Pre-war > 7 Stories |
| C6 | Commercial, Pre-war up to 7 Stories | MF6 | Multifamily, Pre-war up to 7 Stories |
| C7 | Commercial, Very Large, > 500,000 SF | MF7 | Multifamily, Very Large |
| IN1 | Hospital and Health Facilities | NYCHA | New York City Housing Authority |
| IN2 | Institutional General | SF1 | 1 - 4 Family, Free Standing Wood Frame |
| IN3 | K-12 Schools | SF2 | 1 - 4 Family, Row House, Masonry |
| IN4 | Religious | W1 | Warehouse/Factory > 3 Stories |
| IN5 | University | W2 | Warehouse/Factory up to 3 Stories |
| | | W3 | Transportation, Garages, and Utilities |

Table 4: Building Type Breakdown

As part of the TWG report, for each of these building types, data was analyzed to determine the energy consumption of the buildings, and the portion of this energy that was used for heating and cooling. We analyzed a spreadsheet of all buildings in New York City which included all buildings listed by block and lot number, building type, building square footage, and building lot size, along with additional information.

Based on these findings, we developed a spreadsheet model for each building type based on typical parameters to size building peak heating and cooling requirements. Cooling load was estimated based on typical tons/SF, and heating load was based on approximate building surface area, volume, and ventilation rates. Factors were added to account for window to wall ratio, building envelope, and building usage. Bin weather analysis was then used to estimate approximate annual heating and cooling loads. This information was tabulated into peak and annual heating and cooling loads per 1000 SF for the various building types.

The feasibility calculation imported the load data to determine geological feasibility for the three geothermal systems. After confirming the feasibility of each system for the site, the thermal capacity of the site for the given system was compared with the required capacity. If this requirement was met, the annual heating and cooling loads were compared to confirm that an appropriate balance was achieved. A factor of 1.2 was applied to the total cooling load in this phase to account for compressor heat rejection into the heat transfer fluid. If the heating and cooling systems were found to be appropriately balanced, the system was deemed feasible. If they were found to be nearly appropriately balanced, a hybrid system was deemed feasible. It should be noted that, as this

tool is intended only to determine potential, somewhat optimistic figures were selected in terms of heating/cooling balance. A detailed study specific to the site would be necessary to confirm that the system will not be saturated over time.

9.2 Energy Consumption

Where geothermal systems were found to be geologically feasible, we completed follow up calculations to determine economic feasibility. To enable a generalization of all of the buildings in NYC into the very few categories listed above, it was necessary to make a number of assumptions in the development of this tool. The first assumption was that any building considering an upgrade to a geothermal system was already committed to an upgrade of heating and cooling equipment to a centralized system meeting current code requirements. The cost of the installation would never be justified by payback period alone unless considered incrementally against the installation of an alternative conventional centralized system. As actual buildings often have more antiquated systems, this means that our baseline energy projections are somewhat lower than actual findings as reported by the TWG.

Based on this assumption, we developed a baseline for each building type based on the conventional system most likely to be installed for that building type. Commercial buildings were assumed to operate with cooling towers and packaged water cooled AC Units, and natural gas fired condensing boilers or district steam for heating. Institutional sites were assumed to primarily have cooling towers and packaged water cooled AC units for cooling, and condensing boilers for heating, with the exception of schools which were assumed to have packaged air-cooled units and standard boilers. High rise residential buildings were assumed to have cooling towers and heat pumps, while low-rise residential buildings were assumed to have split system AC units and condensing boilers. Single family homes were assumed to have split system AC units and condensing boilers. Warehouses are typically heating only facilities, and were disqualified in all cases based on heating/cooling balance issues.

Once the system types were determined, a comparison between energy costs for the geothermal and the conventional systems were developed. Only the portions of the heating and cooling load that were impacted by the system type were considered in this portion of the study. Pump and fan peak energy consumption was determined based on ASHRAE standards for all cases, and weather bin data analysis was applied to determine annual consumption. For compressor energy consumption, factors were applied to the conventional case to reflect efficiency penalties in the summer for the relatively hot heat transfer fluid. In building types where heat pumps were utilized as a baseline, these factors were partially offset by efficiency gains from the hot heat transfer fluid in the winter. Boiler consumption was based on an assumed average condensing boiler efficiency of 90%. While this relatively high efficiency may not be consistently achieved in practice, it was deemed logical to assume that a building considering conversion to a geothermal system would be optimally run with either upgrade. Boiler consumption was also calculated based on weather bin data.

Once energy consumption data had been developed for each building type on a per SF basis, our results were compared to the findings of the TWG. As expected, our results were comparable but somewhat more efficient than those findings. A major exception, also as expected, was for older residential buildings. As these buildings are currently cooled primarily by window AC units, cooling is primarily logged as a basic plug load and does not

show up in the TWG data. As our calculation assumes conversion to a centralized system, cooling is more in line with other building types.

9.3 Economic Feasibility

After development of the energy consumption analysis for the various building types, this data was applied to the actual buildings to determine economic feasibility of the geothermal systems. Tables based on the weather bin data analysis summarized the energy consumption per 1000 SF for the various building types for both conventional and geothermal systems. This information was then imported into the master building table and individualized for the buildings based on type and square footage. Where the Master building table called for a hybrid system, energy consumption was pro-rated between the conventional and geothermal system types per the requirements of the hybrid system. Energy savings from the geothermal system was thus determined for each system in terms of both energy (Btus) and cost (\$). A further cost savings was then attributed to the geothermal system based on the Carbon Credit as outline by LL6 of 2013. Output includes payback period with and without the Carbon Credit.

Installation costs were estimated based on tons for cooling equipment (including geothermal systems), horsepower for pumps, and kBtu for boilers. These assumptions are all based on prior work and rules of thumb. Actual costs vary considerably for each site, so it should be extensively reviewed during an individualized feasibility study before any decisions are implemented.

An incremental payback period is then determined by comparing the cost of the conventional system to the cost of the geothermal system, and then dividing by the energy savings. If the incremental payback is less than 12 years, a recommendation is made to move forward with the feasibility study, if it is less than 25 years, a recommendation is made to consider the study. Otherwise, it is not recommended to take the next step.

Appendices

- A. Glossary
- B. Building Type Calculations
- C. Master Building Sheet Sample
- D. Sample Maps

Appendix A: Glossary

1. Glossary

Definitions were drawn from Department of Design and Construction's [Geothermal Heat Pump Manual](#) [*link to document if possible*].

Closed loop system - Type of geothermal heat pump system that circulates water with an antifreeze solution in a network of closed piping installed in the group.

Coefficient of performance - Ratio of the heat extracted to the energy consumed in the process.

Ground coupling - Arrangement of piping and fluid handling equipment designed to exchange heat with the earth's interior.

Geothermal (ground source) heat pumps - Heating and cooling devices that take advantage of the relatively constant temperature of the earth's interior, using it as a source or sink for heat. When cooling, heat is extracted from the building and dissipated into the earth; when heating, heat is extracted from the earth and pumped into the space.

Geothermal potential capacity- Based on geological conditions, the thermal energy available from the lot. The capacity varies depending on the system utilized (open loop, closed loop, or standing column well).

Ground couple - Arrangement of piping and fluid handling equipment designed to exchange heat with the earth's interior.

Ground thermal capacity - See Geothermal potential capacity

Heat Exchangers - Device for transferring thermal energy from one fluid to another.

Heat pump - Device used for heating and cooling, which operates by moving heat from a cooler to a warmer location and vice versa, by extracting heat from the air, water, or earth.

Heating, ventilation and air conditioning (HVAC)

Hybrid systems – A system which uses a condensing boiler and/or a cooling tower to supplement the geothermal system

Open loop system - Type of geothermal heat pump system that uses ground water pumped from a supply well to transfer heat and returns the water to the ground through diffusion wells.

Simple payback period – The period of time required to recoup the funds expended in an investment. The calculation is determined by the initial cost divided by the annual savings, and is not a full life cycle cost analysis.

Standing column well system - Type of geothermal heat pump system that also uses ground water, but relies on smaller amounts inside a very deep well to exchange heat with the surrounding bedrock.

Appendix B: Building Type Calculations

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | |
|----------------|-------|----------|-------|-------|-------|-------|-----------------|---------------|--------------|---------------|------------------------|-----------------------|-----------------------|-------------------------|--------------|-------------------------|----------------|----------------|---------------|-------------------------------------|----------------------|---------------------|----------------------|-------------|----------------------|-----------------------|-------------------------|-----------------------|-------------------------|-----------------------|-------------------------|
| DB (+-2) | MCWB | h | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load | Heating Load | Condensing Boiler Load | Primary HW Pump Speed | Primary CW Pump Speed | Secondary CW Pump Speed | CT Fan Speed | Condensing Boiler Usage | HW Pump Demand | CW Pump Demand | CT Fan Demand | Cooling Penalty and Heating Benefit | Pump Energy Usage | CT Fan Energy Usage | Energy Usage | Demand Cost | Energy Cost | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs |
| | | [btu/lb] | | | | | | (Tons) | (Btu) | (%) | (%) | (%) | (%) | (%) | (Therms) | (kW) | (kW) | (kW) | (kW) | (kW) | (kWh) | (kWh) | (kWh) | (\$) | (\$) | (kWh) | (\$) | (kWh) | (\$) | (kWh) | (\$) |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 300 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 7 | 0.92 | 276 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 34.7 | 5.3 | 82.8 | 244 | 38 | 864 | \$ 1,041 | \$ 157 | 164.6 | \$ 30 | 192.0 | \$ 35 | 428.0 | \$ 78 |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 45 | 0.84 | 252 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 31.2 | 4.0 | 75.6 | 1,414 | 180 | 5,020 | \$ 914 | \$ 912 | 953.3 | \$ 173 | 1112.2 | \$ 202 | 2478.6 | \$ 450 |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 170 | 0.76 | 228 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 27.9 | 2.7 | 68.4 | 4,755 | 461 | 16,865 | \$ 796 | \$ 3,063 | 3205.5 | \$ 582 | 3739.7 | \$ 679 | 8334.2 | \$ 1,513 |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 256 | 0.68 | 204 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 24.9 | 1.8 | 61.2 | 6,366 | 468 | 22,506 | \$ 694 | \$ 4,087 | 4290.9 | \$ 779 | 5006.1 | \$ 909 | 11156.4 | \$ 2,026 |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 291 | 0.60 | 180 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 22.0 | 1.1 | 54.0 | 6,406 | 329 | 22,456 | \$ 601 | \$ 4,078 | 4318.1 | \$ 784 | 5037.8 | \$ 915 | 11227.1 | \$ 2,039 |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 314 | 0.52 | 156 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 19.4 | 0.6 | 46.8 | 6,070 | 177 | 20,925 | \$ 518 | \$ 3,800 | 4091.7 | \$ 743 | 4773.7 | \$ 867 | 10638.5 | \$ 1,932 |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 321 | 0.44 | 132 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 17.1 | 3.1 | 39.6 | 5,489 | 1,003 | 19,215 | \$ 525 | \$ 3,489 | 3700.0 | \$ 672 | 4316.7 | \$ 784 | 9620.1 | \$ 1,747 |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 214 | 0.36 | 108 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 14.8 | 2.0 | 32.4 | 3,168 | 437 | 10,536 | \$ 438 | \$ 1,913 | 2135.7 | \$ 388 | 2491.7 | \$ 452 | 5552.9 | \$ 1,008 |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 246 | 0.28 | 84 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 12.7 | 1.3 | 25.2 | 3,131 | 322 | 9,652 | \$ 365 | \$ 1,753 | 2110.5 | \$ 383 | 2462.3 | \$ 447 | 5487.4 | \$ 997 |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 208 | 0.20 | 60 | 0 | 0% | 0% | 60% | 60% | 28% | 0 | 0.0 | 10.8 | 0.7 | 18.0 | 2,249 | 155 | 6,142 | \$ 301 | \$ 1,115 | 1516.0 | \$ 275 | 1768.7 | \$ 321 | 3941.6 | \$ 716 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 298 | 0.36 | 0 | 1,604,383 | 29% | 68% | 0% | 68% | 0% | 5,304 | 7.9 | 6.9 | 0.0 | -13.4 | 4,407 | 0 | 429 | \$ 385 | \$ 4,838 | 2970.6 | \$ 539 | 3465.7 | \$ 629 | 7723.6 | \$ 1,403 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 306 | 0.44 | 0 | 1,941,410 | 35% | 72% | 0% | 72% | 0% | 6,608 | 9.2 | 7.9 | 0.0 | -16.2 | 5,234 | 0 | 278 | \$ 444 | \$ 5,981 | 3528.1 | \$ 641 | 4116.1 | \$ 747 | 9173.1 | \$ 1,666 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 277 | 0.52 | 0 | 2,278,436 | 42% | 76% | 0% | 76% | 0% | 7,019 | 10.4 | 9.0 | 0.0 | -19.0 | 5,366 | 0 | 102 | \$ 503 | \$ 6,317 | 3617.2 | \$ 657 | 4220.0 | \$ 766 | 9404.6 | \$ 1,708 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 156 | 0.60 | 0 | 2,615,463 | 48% | 80% | 0% | 80% | 0% | 4,534 | 11.8 | 10.2 | 0.0 | -21.8 | 3,433 | 0 | 32 | \$ 572 | \$ 4,075 | 2314.0 | \$ 420 | 2699.6 | \$ 490 | 6016.4 | \$ 1,093 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 106 | 0.68 | 0 | 2,952,490 | 54% | 84% | 0% | 84% | 0% | 3,472 | 13.3 | 11.5 | 0.0 | -24.6 | 2,630 | 0 | 27 | \$ 646 | \$ 3,120 | 1773.1 | \$ 322 | 2068.6 | \$ 376 | 4610.1 | \$ 837 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 59 | 0.76 | 0 | 3,289,516 | 60% | 88% | 0% | 88% | 0% | 2,164 | 15.0 | 12.9 | 0.0 | -27.4 | 1,653 | 0 | 30 | \$ 726 | \$ 1,947 | 1114.2 | \$ 202 | 1299.9 | \$ 236 | 2896.9 | \$ 526 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 6 | 0.84 | 0 | 3,626,543 | 66% | 92% | 0% | 92% | 0% | 260 | 16.7 | 14.5 | 0.0 | -30.2 | 202 | 0 | 6 | \$ 811 | \$ 235 | 136.0 | \$ 25 | 158.6 | \$ 29 | 353.5 | \$ 64 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 4 | 0.92 | 0 | 3,963,569 | 72% | 96% | 0% | 96% | 0% | 176 | 18.6 | 16.1 | 0.0 | -33.0 | 139 | 0 | 7 | \$ 902 | \$ 159 | 93.6 | \$ 17 | 109.2 | \$ 20 | 243.3 | \$ 44 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 4,300,596 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,637,623 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 4,974,649 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 3,285 | | 304,400 | 2,658,337,032 | | | | | | 29,537 | 19 | 35 | 5 | | 62,357 | 3,569 | 135,093 | \$ 12,498 | \$ 63,537 | 4,318 | \$ 7,633 | 5,038 | \$ 8,905 | 11,227 | \$ 19,846 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | C1 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 70% |
| Outside Air CFM | 14,775 |
| Cooling Design Load (Tons) | 300 |
| Heating Design Load (Btu) | 3,215,520 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 360,000 |
| Cooling Tower | \$ 300,000 |
| Primary CW Pump | \$ 3,000 |
| Primary HW Pump | \$ 2,600 |
| Secondary CW Pump | \$ 2,600 |
| Maintenance Costs | |
| Condensing Boiler | \$ 27,361 |
| Cooling Tower | \$ 4,200 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 5,472 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 16.8 |
| Primary CW Pump Peak kW | 19.8 |
| Primary HW Pump Peak kW | 19.8 |
| Secondary CW Pump Peak kW | 17.1 |
| Closed Loop Pump Peak kW | 24.9 |
| Open Loop Pump Peak kW | 29.0 |
| Standing Column Well Pump Peak kW | 64.7 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | |
|----------------|-------|----------|-------|-------|-------|-------|-----------------|---------------|--------------|---------------|------------------------|-----------------------|-----------------------|-------------------------|--------------|----------------------|----------------|----------------|---------------|-------------------------------------|----------------------|---------------------|----------------------|-------------|----------------------|-----------------------|-------------------------|-----------------------|-------------------------|-----------------------|-------------------------|
| DB (+-2) | MCWB | h | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load | Heating Load | District Steam Load | Primary HW Pump Speed | Primary CW Pump Speed | Secondary CW Pump Speed | CT Fan Speed | District Steam Usage | HW Pump Demand | CW Pump Demand | CT Fan Demand | Cooling Penalty and Heating Benefit | Pump Energy Usage | CT Fan Energy Usage | Energy Usage | Demand Cost | Energy Cost | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs |
| | | [btu/lb] | | | | | | (Tons) | (Btu) | Mlbs | (%) | (%) | (%) | (%) | (%) | (Mlbs) | (kW) | (kW) | (kW) | (kW) | (kWh) | (kWh) | (kWh) | (\$) | (\$) | (kWh) | (\$) | (kWh) | (\$) | (kWh) | (\$) |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 300 | 0 | 0 | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 7 | 0.92 | 276 | 0 | 0 | 0% | 96% | 96% | 62% | 0 | 0.0 | 34.7 | 5.3 | 82.8 | 244 | 38 | 864 | \$ 1,041 | \$ 157 | 151.1 | \$ 27 | 176.2 | \$ 32 | 392.8 | \$ 71 |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 45 | 0.84 | 252 | 0 | 0 | 0% | 92% | 92% | 55% | 0 | 0.0 | 31.2 | 4.0 | 75.6 | 1,414 | 180 | 5,020 | \$ 914 | \$ 912 | 874.9 | \$ 159 | 1020.7 | \$ 185 | 2274.7 | \$ 413 |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 170 | 0.76 | 228 | 0 | 0 | 0% | 88% | 88% | 47% | 0 | 0.0 | 27.9 | 2.7 | 68.4 | 4,755 | 461 | 16,865 | \$ 796 | \$ 3,063 | 2941.8 | \$ 534 | 3432.1 | \$ 623 | 7648.6 | \$ 1,389 |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 256 | 0.68 | 204 | 0 | 0 | 0% | 84% | 84% | 40% | 0 | 0.0 | 24.9 | 1.8 | 61.2 | 6,366 | 468 | 22,506 | \$ 694 | \$ 4,087 | 3937.9 | \$ 715 | 4594.2 | \$ 834 | 10238.6 | \$ 1,859 |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 291 | 0.60 | 180 | 0 | 0 | 0% | 80% | 80% | 33% | 0 | 0.0 | 22.0 | 1.1 | 54.0 | 6,406 | 329 | 22,456 | \$ 601 | \$ 4,078 | 3962.9 | \$ 720 | 4623.3 | \$ 840 | 10303.4 | \$ 1,871 |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 314 | 0.52 | 156 | 0 | 0 | 0% | 76% | 76% | 25% | 0 | 0.0 | 19.4 | 0.6 | 46.8 | 6,070 | 177 | 20,925 | \$ 518 | \$ 3,800 | 3755.1 | \$ 682 | 4381.0 | \$ 796 | 9763.3 | \$ 1,773 |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 321 | 0.44 | 132 | 0 | 0 | 0% | 72% | 72% | 50% | 0 | 0.0 | 17.1 | 3.1 | 39.6 | 5,489 | 1,003 | 19,215 | \$ 525 | \$ 3,489 | 3395.7 | \$ 617 | 3961.6 | \$ 719 | 8828.7 | \$ 1,603 |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 214 | 0.36 | 108 | 0 | 0 | 0% | 68% | 68% | 42% | 0 | 0.0 | 14.8 | 2.0 | 32.4 | 3,168 | 437 | 10,536 | \$ 438 | \$ 1,913 | 1960.0 | \$ 356 | 2286.7 | \$ 415 | 5096.1 | \$ 925 |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 246 | 0.28 | 84 | 0 | 0 | 0% | 64% | 64% | 35% | 0 | 0.0 | 12.7 | 1.3 | 25.2 | 3,131 | 322 | 9,652 | \$ 365 | \$ 1,753 | 1936.9 | \$ 352 | 2259.7 | \$ 410 | 5036.0 | \$ 915 |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 208 | 0.20 | 60 | 0 | 0 | 0% | 60% | 60% | 28% | 0 | 0.0 | 10.8 | 0.7 | 18.0 | 2,249 | 155 | 6,142 | \$ 301 | \$ 1,115 | 1391.3 | \$ 253 | 1623.2 | \$ 295 | 3617.4 | \$ 657 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 298 | 0.36 | 0 | 1,477,375 | 1.55 | 68% | 0% | 68% | 0% | 462 | 7.9 | 6.9 | 0.0 | -12.3 | 4,407 | 0 | 744 | \$ 385 | \$ 11,247 | 2726.2 | \$ 495 | 3180.6 | \$ 578 | 7088.2 | \$ 1,287 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 306 | 0.44 | 0 | 1,786,178 | 1.88 | 72% | 0% | 72% | 0% | 576 | 9.2 | 7.9 | 0.0 | -14.9 | 5,234 | 0 | 674 | \$ 444 | \$ 13,953 | 3237.9 | \$ 588 | 3777.5 | \$ 686 | 8418.5 | \$ 1,529 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 277 | 0.52 | 0 | 2,094,980 | 2.20 | 76% | 0% | 76% | 0% | 611 | 10.4 | 9.0 | 0.0 | -17.5 | 5,366 | 0 | 526 | \$ 503 | \$ 14,777 | 3319.6 | \$ 603 | 3872.8 | \$ 703 | 8630.9 | \$ 1,567 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 156 | 0.60 | 0 | 2,403,783 | 2.53 | 80% | 0% | 80% | 0% | 395 | 11.8 | 10.2 | 0.0 | -20.0 | 3,433 | 0 | 308 | \$ 572 | \$ 9,535 | 2123.6 | \$ 386 | 2477.6 | \$ 450 | 5521.4 | \$ 1,003 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 106 | 0.68 | 0 | 2,712,586 | 2.85 | 84% | 0% | 84% | 0% | 302 | 13.3 | 11.5 | 0.0 | -22.6 | 2,630 | 0 | 238 | \$ 646 | \$ 7,299 | 1627.2 | \$ 296 | 1898.4 | \$ 345 | 4230.8 | \$ 768 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 59 | 0.76 | 0 | 3,021,388 | 3.18 | 88% | 0% | 88% | 0% | 188 | 15.0 | 12.9 | 0.0 | -25.2 | 1,653 | 0 | 162 | \$ 726 | \$ 4,550 | 1022.5 | \$ 186 | 1193.0 | \$ 217 | 2658.6 | \$ 483 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 6 | 0.84 | 0 | 3,330,191 | 3.50 | 92% | 0% | 92% | 0% | 23 | 16.7 | 14.5 | 0.0 | -27.8 | 202 | 0 | 22 | \$ 811 | \$ 548 | 124.8 | \$ 23 | 145.6 | \$ 26 | 324.4 | \$ 59 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 4 | 0.92 | 0 | 3,638,993 | 3.83 | 96% | 0% | 96% | 0% | 15 | 18.6 | 16.1 | 0.0 | -30.3 | 139 | 0 | 18 | \$ 902 | \$ 371 | 85.9 | \$ 16 | 100.2 | \$ 18 | 223.3 | \$ 41 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 3,947,796 | 4.15 | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,256,599 | 4.48 | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 4,565,401 | 4.80 | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 3,285 | | 304,400 | 2,444,629,440 | | | | | | 2,572 | 19 | 35 | 5 | 333 | 62,357 | 3,569 | 136,874 | \$ 12,498 | \$ 99,145 | 3,963 | \$ 7,005 | 4,623 | \$ 8,173 | 10,303 | \$ 18,214 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | C3 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 70% |
| Outside Air CFM | 14,775 |
| Cooling Design Load (Tons) | 300 |
| Heating Design Load (Btu) | 2,862,720 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|------------------------|------------|
| Steam Heat Exchanger | \$ 10,000 |
| Cooling Tower | \$ 300,000 |
| Primary CW Pump | \$ 3,000 |
| Primary HW Pump | \$ 2,600 |
| Secondary CW Pump | \$ 2,600 |
| Maintenance Costs | |
| Steam Trap Maintenance | \$ 4,850 |
| Cooling Tower | \$ 4,200 |

| Auxiliary Equipment | |
|---------------------------------------|------|
| Heat Content for District Steam (Btu) | 970 |
| Heat Exchanger Efficiency | 98% |
| Cooling Tower Peak kW | 16.8 |
| Primary CW Pump Peak kW | 19.8 |
| Primary HW Pump Peak kW | 19.8 |
| Secondary CW Pump Peak kW | 17.1 |
| Closed Loop Pump Peak kW | 22.8 |
| Open Loop Pump Peak kW | 26.6 |
| Standing Column Well Pump Peak kW | 59.4 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|------------------------------|--------------------------------|---------------------|-------------------------------------|------------------------|------------------------|-----------------------|---|----------------------------|------------------------------|-----------------------|---------------------|----------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Primary CW Pump Speed (%) | Secondary CW Pump Speed (%) | CT Fan Speed (%) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | CW Pump Demand (kW) | CT Fan Demand (kW) | Cooling Penalty and Heating Benefit (kW) | Pump Energy Usage (kWh) | CT Fan Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 400 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 9 | 0.92 | 368 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 46.3 | 7.1 | 110.4 | 416 | 64 | 1,474 | \$ 1,389 | \$ 268 | 225.0 | \$ 41 | 262.4 | \$ 48 | 584.9 | \$ 106 |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 60 | 0.84 | 336 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 41.6 | 5.3 | 100.8 | 2,496 | 317 | 8,862 | \$ 1,219 | \$ 1,609 | 1348.3 | \$ 245 | 1573.0 | \$ 286 | 3505.6 | \$ 637 |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 257 | 0.76 | 304 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 37.2 | 3.6 | 91.2 | 9,568 | 927 | 33,933 | \$ 1,062 | \$ 6,162 | 5167.8 | \$ 938 | 6029.1 | \$ 1,095 | 13436.3 | \$ 2,440 |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 480 | 0.68 | 272 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 33.1 | 2.4 | 81.6 | 15,909 | 1,169 | 56,246 | \$ 925 | \$ 10,214 | 8592.2 | \$ 1,560 | 10024.3 | \$ 1,820 | 22339.8 | \$ 4,057 |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 734 | 0.60 | 240 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 29.3 | 1.5 | 72.0 | 21,534 | 1,105 | 75,487 | \$ 802 | \$ 13,708 | 11630.2 | \$ 2,112 | 13568.6 | \$ 2,464 | 30238.6 | \$ 5,491 |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 845 | 0.52 | 208 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 25.8 | 0.8 | 62.4 | 21,806 | 635 | 75,170 | \$ 691 | \$ 13,651 | 11777.6 | \$ 2,139 | 13740.5 | \$ 2,495 | 30621.8 | \$ 5,561 |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 977 | 0.44 | 176 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 22.8 | 4.2 | 52.8 | 22,257 | 4,069 | 77,911 | \$ 701 | \$ 14,149 | 12021.0 | \$ 2,183 | 14024.5 | \$ 2,547 | 31254.6 | \$ 5,676 |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 656 | 0.36 | 144 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 19.7 | 2.7 | 43.2 | 12,954 | 1,785 | 43,079 | \$ 584 | \$ 7,823 | 6996.7 | \$ 1,271 | 8162.8 | \$ 1,482 | 18191.3 | \$ 3,304 |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 712 | 0.28 | 112 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 17.0 | 1.7 | 33.6 | 12,083 | 1,242 | 37,248 | \$ 487 | \$ 6,764 | 6526.0 | \$ 1,185 | 7613.6 | \$ 1,383 | 16967.5 | \$ 3,081 |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 571 | 0.20 | 80 | 0 | 0% | 0% | 60% | 60% | 28% | 0 | 0.0 | 14.4 | 1.0 | 24.0 | 8,246 | 570 | 22,520 | \$ 401 | \$ 4,090 | 4453.8 | \$ 809 | 5196.1 | \$ 944 | 11579.8 | \$ 2,103 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 751 | 0.36 | 0 | 1,845,983 | 32% | 68% | 0% | 68% | 0% | 15,404 | 10.6 | 9.2 | 0.0 | -15.4 | 14,830 | 0 | 3,278 | \$ 513 | \$ 14,419 | 8009.9 | \$ 1,455 | 9344.9 | \$ 1,697 | 20825.7 | \$ 3,782 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 863 | 0.44 | 0 | 2,192,841 | 38% | 72% | 0% | 72% | 0% | 21,027 | 12.2 | 10.6 | 0.0 | -18.3 | 19,660 | 0 | 3,890 | \$ 592 | \$ 19,576 | 10618.3 | \$ 1,928 | 12388.1 | \$ 2,250 | 27607.7 | \$ 5,014 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 799 | 0.52 | 0 | 2,539,699 | 43% | 76% | 0% | 76% | 0% | 22,547 | 13.8 | 12.0 | 0.0 | -21.2 | 20,619 | 0 | 3,709 | \$ 671 | \$ 20,907 | 11136.5 | \$ 2,022 | 12992.5 | \$ 2,359 | 28954.8 | \$ 5,258 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 496 | 0.60 | 0 | 2,886,558 | 49% | 80% | 0% | 80% | 0% | 15,908 | 15.7 | 13.6 | 0.0 | -24.1 | 14,551 | 0 | 2,620 | \$ 763 | \$ 14,752 | 7859.1 | \$ 1,427 | 9169.0 | \$ 1,665 | 20433.7 | \$ 3,711 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 305 | 0.68 | 0 | 3,233,416 | 55% | 84% | 0% | 84% | 0% | 10,958 | 17.8 | 15.4 | 0.0 | -26.9 | 10,109 | 0 | 1,890 | \$ 862 | \$ 10,177 | 5459.6 | \$ 991 | 6369.6 | \$ 1,157 | 14195.1 | \$ 2,578 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 196 | 0.76 | 0 | 3,580,274 | 61% | 88% | 0% | 88% | 0% | 7,797 | 20.0 | 17.3 | 0.0 | -29.8 | 7,297 | 0 | 1,449 | \$ 968 | \$ 7,260 | 3941.2 | \$ 716 | 4598.1 | \$ 835 | 10247.1 | \$ 1,861 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 32 | 0.84 | 0 | 3,927,133 | 67% | 92% | 0% | 92% | 0% | 1,396 | 22.3 | 19.3 | 0.0 | -32.7 | 1,331 | 0 | 284 | \$ 1,082 | \$ 1,305 | 719.1 | \$ 131 | 838.9 | \$ 152 | 1869.6 | \$ 340 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 17 | 0.92 | 0 | 4,273,991 | 73% | 96% | 0% | 96% | 0% | 807 | 24.8 | 21.4 | 0.0 | -35.6 | 787 | 0 | 181 | \$ 1,203 | \$ 757 | 424.9 | \$ 77 | 495.7 | \$ 90 | 1104.8 | \$ 201 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 4,620,850 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,967,708 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 5,314,566 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 8,760 | | 975,920 | 8,625,959,064 | | | | | | 95,844 | 25 | 46 | 7 | 468 | 216,455 | 11,883 | 449,232 | \$ 16,663 | \$ 184,254 | 12,021 | \$ 21,230 | 14,024 | \$ 24,769 | 31,255 | \$ 55,199 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | IN1 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 39% |
| Outside Air CFM | 48,000 |
| Cooling Design Load (Tons) | 400 |
| Heating Design Load (Btu) | 1,095,730 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 5,846 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 22.4 |
| Primary CW Pump Peak kW | 26.4 |
| Primary HW Pump Peak kW | 26.4 |
| Secondary CW Pump Peak kW | 22.8 |
| Closed Loop Pump Peak kW | 26.6 |
| Open Loop Pump Peak kW | 31.0 |
| Standing Column Well Pump Peak kW | 69.1 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 380,000 |
| Cooling Tower | \$ 400,000 |
| Primary CW Pump | \$ 3,500 |
| Primary HW Pump | \$ 3,500 |
| Secondary CW Pump | \$ 3,000 |
| Maintenance Costs | |
| Condensing Boiler | \$ 29,230 |
| Cooling Tower | \$ 5,600 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|------------------------------|--------------------------------|---------------------|-------------------------------------|------------------------|------------------------|-----------------------|---|----------------------------|------------------------------|-----------------------|----------------------|---------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|
| DB (+2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Primary CW Pump Speed (%) | Secondary CW Pump Speed (%) | CT Fan Speed (%) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | CW Pump Demand (kW) | CT Fan Demand (kW) | Cooling Penalty and Heating Benefit (kW) | Pump Energy Usage (kWh) | CT Fan Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 300 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 9 | 0.92 | 276 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 34.7 | 5.3 | 82.8 | 312 | 48 | 1,106 | \$ 1,041 | \$ 201 | 159.5 | \$ 29 | 186.1 | \$ 34 | 414.7 | \$ 75 |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 60 | 0.84 | 252 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 31.2 | 4.0 | 75.6 | 1,872 | 238 | 6,646 | \$ 914 | \$ 1,207 | 955.9 | \$ 174 | 1115.2 | \$ 203 | 2485.3 | \$ 451 |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 257 | 0.76 | 228 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 27.9 | 2.7 | 68.4 | 7,176 | 695 | 25,450 | \$ 796 | \$ 4,622 | 3663.8 | \$ 665 | 4274.4 | \$ 776 | 9525.9 | \$ 1,730 |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 480 | 0.68 | 204 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 24.9 | 1.8 | 61.2 | 11,931 | 877 | 42,184 | \$ 694 | \$ 7,661 | 6091.6 | \$ 1,106 | 7106.8 | \$ 1,291 | 15838.1 | \$ 2,876 |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 734 | 0.60 | 180 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 22.0 | 1.1 | 54.0 | 16,150 | 829 | 56,615 | \$ 601 | \$ 10,281 | 8245.4 | \$ 1,497 | 9619.6 | \$ 1,747 | 21438.0 | \$ 3,893 |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 845 | 0.52 | 156 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 19.4 | 0.6 | 46.8 | 16,355 | 477 | 56,377 | \$ 518 | \$ 10,238 | 8349.9 | \$ 1,516 | 9741.6 | \$ 1,769 | 21709.7 | \$ 3,942 |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 977 | 0.44 | 132 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 17.1 | 3.1 | 39.6 | 16,693 | 3,052 | 58,434 | \$ 525 | \$ 10,612 | 8522.4 | \$ 1,548 | 9942.9 | \$ 1,806 | 22158.4 | \$ 4,024 |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 656 | 0.36 | 108 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 14.8 | 2.0 | 32.4 | 9,716 | 1,339 | 32,309 | \$ 438 | \$ 5,867 | 4960.4 | \$ 901 | 5787.1 | \$ 1,051 | 12897.0 | \$ 2,342 |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 712 | 0.28 | 84 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 12.7 | 1.3 | 25.2 | 9,062 | 931 | 27,936 | \$ 365 | \$ 5,073 | 4626.7 | \$ 840 | 5397.8 | \$ 980 | 12029.3 | \$ 2,185 |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 571 | 0.20 | 60 | 0 | 0% | 0% | 60% | 60% | 28% | 0 | 0.0 | 10.8 | 0.7 | 18.0 | 6,185 | 428 | 16,890 | \$ 301 | \$ 3,067 | 3157.6 | \$ 573 | 3683.8 | \$ 669 | 8209.7 | \$ 1,491 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 751 | 0.36 | 0 | 1,257,482 | 30% | 68% | 0% | 68% | 0% | 10,493 | 7.9 | 6.9 | 0.0 | -10.5 | 11,123 | 0 | 3,253 | \$ 385 | \$ 10,007 | 5678.7 | \$ 1,031 | 6625.2 | \$ 1,203 | 14764.7 | \$ 2,681 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 863 | 0.44 | 0 | 1,508,517 | 36% | 72% | 0% | 72% | 0% | 14,465 | 9.2 | 7.9 | 0.0 | -12.6 | 14,745 | 0 | 3,896 | \$ 444 | \$ 13,688 | 7528.0 | \$ 1,367 | 8782.7 | \$ 1,595 | 19572.8 | \$ 3,554 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 799 | 0.52 | 0 | 1,759,553 | 42% | 76% | 0% | 76% | 0% | 15,621 | 10.4 | 9.0 | 0.0 | -14.7 | 15,465 | 0 | 3,749 | \$ 503 | \$ 14,699 | 7895.4 | \$ 1,434 | 9211.2 | \$ 1,673 | 20527.9 | \$ 3,728 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 496 | 0.60 | 0 | 2,010,588 | 49% | 80% | 0% | 80% | 0% | 11,081 | 11.8 | 10.2 | 0.0 | -16.8 | 10,913 | 0 | 2,603 | \$ 572 | \$ 10,416 | 5571.8 | \$ 1,012 | 6500.5 | \$ 1,180 | 14486.7 | \$ 2,631 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 305 | 0.68 | 0 | 2,261,623 | 55% | 84% | 0% | 84% | 0% | 7,664 | 13.3 | 11.5 | 0.0 | -18.8 | 7,581 | 0 | 1,833 | \$ 646 | \$ 7,211 | 3870.7 | \$ 703 | 4515.8 | \$ 820 | 10063.8 | \$ 1,828 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 196 | 0.76 | 0 | 2,512,659 | 61% | 88% | 0% | 88% | 0% | 5,472 | 15.0 | 12.9 | 0.0 | -20.9 | 5,473 | 0 | 1,369 | \$ 726 | \$ 5,159 | 2794.2 | \$ 507 | 3259.9 | \$ 592 | 7264.9 | \$ 1,319 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 32 | 0.84 | 0 | 2,763,694 | 67% | 92% | 0% | 92% | 0% | 983 | 16.7 | 14.5 | 0.0 | -23.0 | 999 | 0 | 262 | \$ 811 | \$ 929 | 509.8 | \$ 93 | 594.8 | \$ 108 | 1325.5 | \$ 241 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 17 | 0.92 | 0 | 3,014,730 | 73% | 96% | 0% | 96% | 0% | 569 | 18.6 | 16.1 | 0.0 | -25.1 | 590 | 0 | 163 | \$ 902 | \$ 541 | 301.2 | \$ 55 | 351.5 | \$ 64 | 783.2 | \$ 142 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 3,265,765 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 3,516,800 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 3,767,836 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 8,760 | | 731,940 | 5,971,318,771 | | | | | | 66,348 | 19 | 35 | 5 | 362 | 162,342 | 8,912 | 341,075 | \$ 12,498 | \$ 133,977 | 8,522 | \$ 15,052 | 9,943 | \$ 17,560 | 22,158 | \$ 39,134 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | IN2 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 39% |
| Outside Air CFM | 21,519 |
| Cooling Design Load (Tons) | 300 |
| Heating Design Load (Btu) | 1,685,410 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 320,000 |
| Cooling Tower | \$ 300,000 |
| Primary CW Pump | \$ 3,000 |
| Primary HW Pump | \$ 2,600 |
| Secondary CW Pump | \$ 2,600 |
| Maintenance Costs | |
| Condensing Boiler | \$ 20,723 |
| Cooling Tower | \$ 4,200 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 4,145 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 16.8 |
| Primary CW Pump Peak kW | 19.8 |
| Primary HW Pump Peak kW | 19.8 |
| Secondary CW Pump Peak kW | 17.1 |
| Closed Loop Pump Peak kW | 18.8 |
| Open Loop Pump Peak kW | 22.0 |
| Standing Column Well Pump Peak kW | 49.0 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|--------------------------|--|-------------------------------------|------------------------|-----------------------------|----------------------------|------------------------------------|-----------------------|----------------------|---------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|-----|------|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Split System Load (%) | Extra kW/Ton for Air Cooled System (kW) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | Split System Demand (kW) | Pump Energy Usage (kWh) | Split System Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 250 | 0 | 0% | 0% | 70% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 4 | 0.92 | 230 | 0 | 0% | 0% | 62% | 69 | 0 | 0.0 | 87.2 | 0 | 307 | 307 | \$ 2,267 | \$ 56 | 61.1 | \$ 11 | 88.8 | \$ 16 | 197.8 | \$ 36 | | |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 23 | 0.84 | 210 | 0 | 0% | 0% | 55% | 63 | 0 | 0.0 | 79.1 | 0 | 1,793 | 1,793 | \$ 2,058 | \$ 326 | 354.0 | \$ 64 | 514.1 | \$ 93 | 1145.6 | \$ 208 | | |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 85 | 0.76 | 190 | 0 | 0% | 0% | 47% | 57 | 0 | 0.0 | 70.8 | 0 | 6,028 | 6,028 | \$ 1,841 | \$ 1,095 | 1190.2 | \$ 216 | 1728.6 | \$ 314 | 3852.2 | \$ 700 | | |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 128 | 0.68 | 170 | 0 | 0% | 0% | 40% | 51 | 0 | 0.0 | 62.7 | 0 | 8,033 | 8,033 | \$ 1,631 | \$ 1,459 | 1593.3 | \$ 289 | 2313.9 | \$ 420 | 5156.7 | \$ 936 | | |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 146 | 0.60 | 150 | 0 | 0% | 0% | 33% | 45 | 0 | 0.0 | 54.7 | 0 | 7,960 | 7,960 | \$ 1,422 | \$ 1,446 | 1603.4 | \$ 291 | 2328.5 | \$ 423 | 5189.3 | \$ 942 | | |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 314 | 0.52 | 130 | 0 | 0% | 0% | 25% | 39 | 0 | 0.0 | 46.3 | 0 | 14,532 | 14,532 | \$ 1,205 | \$ 2,639 | 3038.7 | \$ 552 | 4412.9 | \$ 801 | 9834.5 | \$ 1,786 | | |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 321 | 0.44 | 110 | 0 | 0% | 0% | 50% | 33 | 0 | 0.0 | 47.7 | 0 | 15,315 | 15,315 | \$ 1,239 | \$ 2,781 | 2747.8 | \$ 499 | 3990.5 | \$ 725 | 8893.1 | \$ 1,615 | | |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 214 | 0.36 | 90 | 0 | 0% | 0% | 42% | 27 | 0 | 0.0 | 39.3 | 0 | 8,412 | 8,412 | \$ 1,022 | \$ 1,528 | 1586.1 | \$ 288 | 2303.4 | \$ 418 | 5133.3 | \$ 932 | | |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 246 | 0.28 | 70 | 0 | 0% | 0% | 35% | 21 | 0 | 0.0 | 31.3 | 0 | 7,692 | 7,692 | \$ 813 | \$ 1,397 | 1567.4 | \$ 285 | 2276.2 | \$ 413 | 5072.7 | \$ 921 | | |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 208 | 0.20 | 50 | 0 | 0% | 0% | 28% | 15 | 0 | 0.0 | 23.2 | 0 | 4,821 | 4,821 | \$ 604 | \$ 875 | 1539.5 | \$ 280 | 2235.7 | \$ 406 | 4982.5 | \$ 905 | | |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 298 | 0.36 | 0 | 1,584,187 | 31% | 68% | 0% | 0 | 5,238 | 6.6 | 0.0 | 1,971 | 0 | 1,971 | \$ 172 | \$ 5,058 | 2206.1 | \$ 401 | 3203.8 | \$ 582 | 7139.9 | \$ 1,297 | | |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 306 | 0.44 | 0 | 1,885,639 | 37% | 72% | 0% | 0 | 6,418 | 7.6 | 0.0 | 2,340 | 0 | 2,340 | \$ 199 | \$ 6,185 | 2620.1 | \$ 476 | 3805.1 | \$ 691 | 8479.9 | \$ 1,540 | | |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 277 | 0.52 | 0 | 2,187,092 | 43% | 76% | 0% | 0 | 6,737 | 8.7 | 0.0 | 2,399 | 0 | 2,399 | \$ 225 | \$ 6,482 | 2686.2 | \$ 488 | 3901.1 | \$ 708 | 8693.9 | \$ 1,579 | | |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 156 | 0.60 | 0 | 2,488,545 | 49% | 80% | 0% | 0 | 4,314 | 9.8 | 0.0 | 1,535 | 0 | 1,535 | \$ 256 | \$ 4,150 | 1718.4 | \$ 312 | 2495.6 | \$ 453 | 5561.7 | \$ 1,010 | | |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 106 | 0.68 | 0 | 2,789,997 | 55% | 84% | 0% | 0 | 3,280 | 11.1 | 0.0 | 1,176 | 0 | 1,176 | \$ 289 | \$ 3,157 | 1316.8 | \$ 239 | 1912.3 | \$ 347 | 4261.7 | \$ 774 | | |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 59 | 0.76 | 0 | 3,091,450 | 61% | 88% | 0% | 0 | 2,033 | 12.5 | 0.0 | 739 | 0 | 739 | \$ 325 | \$ 1,959 | 827.4 | \$ 150 | 1201.7 | \$ 218 | 2678.0 | \$ 486 | | |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 6 | 0.84 | 0 | 3,392,902 | 67% | 92% | 0% | 0 | 244 | 14.0 | 0.0 | 90 | 0 | 90 | \$ 363 | \$ 235 | 101.0 | \$ 18 | 146.6 | \$ 27 | 326.8 | \$ 59 | | |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 4 | 0.92 | 0 | 3,694,355 | 73% | 96% | 0% | 0 | 164 | 15.5 | 0.0 | 62 | 0 | 62 | \$ 404 | \$ 159 | 69.5 | \$ 13 | 100.9 | \$ 18 | 224.9 | \$ 41 | | |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 3,995,807 | 79% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,297,260 | 85% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 4,598,712 | 91% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 2,900 | | 188,316 | 2,558,608,908 | | | | 28,429 | 16 | 87 | 10,313 | 74,894 | 85,207 | \$ 27,204 | \$ 68,190 | 3,039 | \$ 4,872 | 4,413 | \$ 7,075 | 9,835 | \$ 15,767 | | | |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | IN3 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 45% |
| Outside Air CFM | 38,325 |
| Cooling Design Load (Tons) | 250 |
| Heating Design Load (Btu) | 1,181,219 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Air Cooled kW/Ton Penalty | 0.3 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|-----------------------|------------|
| Condensing Boiler | \$ 330,000 |
| Split System AC Units | \$ 250,000 |
| Primary HW Pump | \$ 2,200 |
| Maintenance Costs | |
| Condensing Boiler | \$ 25,293 |

| Auxiliary Equipment | |
|------------------------------------|-------|
| Condensing Boiler (MBH) | 5,059 |
| Condensing Boiler Efficiency | 90% |
| Split System Condenser Fan Peak kW | 29.3 |
| Primary HW Pump Peak kW | 16.5 |
| Closed Loop Pump Peak kW | 18.5 |
| Open Loop Pump Peak kW | 26.8 |
| Standing Column Well Pump Peak kW | 59.8 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|------------------------------|--------------------------------|---------------------|-------------------------------------|------------------------|------------------------|-----------------------|---|----------------------------|------------------------------|-----------------------|---------------------|----------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|------|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Primary CW Pump Speed (%) | Secondary CW Pump Speed (%) | CT Fan Speed (%) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | CW Pump Demand (kW) | CT Fan Demand (kW) | Cooling Penalty and Heating Benefit (kW) | Pump Energy Usage (kWh) | CT Fan Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 200 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 6 | 0.92 | 184 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 23.1 | 3.6 | 55.2 | 137 | 21 | 486 | \$ 694 | \$ 88 | 148.3 | \$ 27 | 173.1 | \$ 31 | 385.7 | \$ 70 | |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 38 | 0.84 | 168 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 20.8 | 2.6 | 50.4 | 790 | 100 | 2,805 | \$ 610 | \$ 509 | 854.4 | \$ 155 | 996.8 | \$ 181 | 2221.5 | \$ 403 | |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 140 | 0.76 | 152 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 18.6 | 1.8 | 45.6 | 2,598 | 252 | 9,214 | \$ 531 | \$ 1,673 | 2809.5 | \$ 510 | 3277.7 | \$ 595 | 7304.6 | \$ 1,327 | |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 201 | 0.68 | 136 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 16.6 | 1.2 | 40.8 | 3,329 | 245 | 11,769 | \$ 463 | \$ 2,137 | 3599.5 | \$ 654 | 4199.4 | \$ 763 | 9358.7 | \$ 1,700 | |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 211 | 0.60 | 120 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 14.7 | 0.8 | 36.0 | 3,102 | 159 | 10,875 | \$ 401 | \$ 1,975 | 3354.4 | \$ 609 | 3913.5 | \$ 711 | 8721.5 | \$ 1,584 | |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 223 | 0.52 | 104 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 12.9 | 0.4 | 31.2 | 2,878 | 84 | 9,922 | \$ 345 | \$ 1,802 | 3112.4 | \$ 565 | 3631.1 | \$ 659 | 8092.3 | \$ 1,470 | |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 219 | 0.44 | 88 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 11.4 | 2.1 | 26.4 | 2,491 | 455 | 8,720 | \$ 350 | \$ 1,584 | 2693.6 | \$ 489 | 3142.6 | \$ 571 | 7003.5 | \$ 1,272 | |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 145 | 0.36 | 72 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 9.9 | 1.4 | 21.6 | 1,431 | 197 | 4,758 | \$ 292 | \$ 864 | 1547.2 | \$ 281 | 1805.0 | \$ 328 | 4022.6 | \$ 731 | |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 171 | 0.28 | 56 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 8.5 | 0.9 | 16.8 | 1,450 | 149 | 4,471 | \$ 243 | \$ 812 | 1568.3 | \$ 285 | 1829.7 | \$ 332 | 4077.6 | \$ 740 | |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 147 | 0.20 | 40 | 0 | 0% | 0% | 60% | 60% | 28% | 0 | 0.0 | 7.2 | 0.5 | 12.0 | 1,059 | 73 | 2,892 | \$ 201 | \$ 525 | 1145.1 | \$ 208 | 1336.0 | \$ 243 | 2977.4 | \$ 541 | |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 216 | 0.36 | 0 | 1,863,286 | 32% | 68% | 0% | 68% | 0% | 4,479 | 5.3 | 4.6 | 0.0 | -15.5 | 2,136 | 0 | -1,223 | \$ 257 | \$ 3,797 | 2309.8 | \$ 419 | 2694.8 | \$ 489 | 6005.5 | \$ 1,091 | |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 215 | 0.44 | 0 | 2,208,967 | 38% | 72% | 0% | 72% | 0% | 5,269 | 6.1 | 5.3 | 0.0 | -18.4 | 2,445 | 0 | -1,506 | \$ 296 | \$ 4,455 | 2643.9 | \$ 480 | 3084.6 | \$ 560 | 6874.2 | \$ 1,248 | |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 193 | 0.52 | 0 | 2,554,648 | 44% | 76% | 0% | 76% | 0% | 5,469 | 6.9 | 6.0 | 0.0 | -21.3 | 2,486 | 0 | -1,616 | \$ 335 | \$ 4,614 | 2688.1 | \$ 488 | 3136.1 | \$ 570 | 6989.1 | \$ 1,269 | |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 104 | 0.60 | 0 | 2,900,329 | 50% | 80% | 0% | 80% | 0% | 3,351 | 7.9 | 6.8 | 0.0 | -24.2 | 1,526 | 0 | -988 | \$ 381 | \$ 2,828 | 1649.6 | \$ 300 | 1924.5 | \$ 349 | 4288.9 | \$ 779 | |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 74 | 0.68 | 0 | 3,246,010 | 55% | 84% | 0% | 84% | 0% | 2,659 | 8.9 | 7.7 | 0.0 | -27.1 | 1,222 | 0 | -772 | \$ 431 | \$ 2,246 | 1320.9 | \$ 240 | 1541.0 | \$ 280 | 3434.3 | \$ 624 | |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 39 | 0.76 | 0 | 3,591,691 | 61% | 88% | 0% | 88% | 0% | 1,566 | 10.0 | 8.6 | 0.0 | -29.9 | 731 | 0 | -444 | \$ 484 | \$ 1,325 | 790.1 | \$ 143 | 921.7 | \$ 167 | 2054.2 | \$ 373 | |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 3 | 0.84 | 0 | 3,937,372 | 67% | 92% | 0% | 92% | 0% | 147 | 11.2 | 9.6 | 0.0 | -32.8 | 70 | 0 | -40 | \$ 541 | \$ 124 | 75.5 | \$ 14 | 88.1 | \$ 16 | 196.4 | \$ 36 | |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 2 | 0.92 | 0 | 4,283,053 | 73% | 96% | 0% | 96% | 0% | 111 | 12.4 | 10.7 | 0.0 | -35.7 | 54 | 0 | -29 | \$ 602 | \$ 95 | 58.5 | \$ 11 | 68.3 | \$ 12 | 152.2 | \$ 28 | |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 4,628,734 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,974,415 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 5,320,096 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 2,346 | | 149,700 | 2,074,583,623 | | | | | | 23,051 | 12 | 23 | 4 | 131 | 29,935 | 1,736 | 59,292 | \$ 8,332 | \$ 39,785 | 3,600 | \$ 5,878 | 4,199 | \$ 6,858 | 9,359 | \$ 15,283 | |

| Assumptions | |
|-----------------------------------|----------|
| Building Type | IN4 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 21% |
| Outside Air CFM | 51,805 |
| Cooling Design Load (Tons) | 200 |
| Heating Design Load (Btu) | 824,174 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 5,852 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 11.2 |
| Primary CW Pump Peak kW | 13.2 |
| Primary HW Pump Peak kW | 13.2 |
| Secondary CW Pump Peak kW | 11.4 |
| Closed Loop Pump Peak kW | 26.6 |
| Open Loop Pump Peak kW | 31.0 |
| Standing Column Well Pump Peak kW | 69.2 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 390,000 |
| Cooling Tower | \$ 200,000 |
| Primary CW Pump | \$ 2,000 |
| Primary HW Pump | \$ 2,000 |
| Secondary CW Pump | \$ 1,800 |
| Maintenance Costs | |
| Condensing Boiler | \$ 29,261 |
| Cooling Tower | \$ 2,800 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | |
|----------------|-------|----------|-------|-------|-------|-------|-----------------|---------------|--------------|---------------|------------------------|-----------------------|-----------------------|-------------------------|--------------|-------------------------|----------------|----------------|---------------|-------------------------------------|----------------------|---------------------|----------------------|-------------|----------------------|-----------------------|-------------------------|-----------------------|-------------------------|-----------------------|-------------------------|
| DB (+2) | MCWB | h | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load | Heating Load | Condensing Boiler Load | Primary HW Pump Speed | Primary CW Pump Speed | Secondary CW Pump Speed | CT Fan Speed | Condensing Boiler Usage | HW Pump Demand | CW Pump Demand | CT Fan Demand | Cooling Penalty and Heating Benefit | Pump Energy Usage | CT Fan Energy Usage | Energy Usage | Demand Cost | Energy Cost | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs | Geothermal Pump Usage | Geothermal Energy Costs |
| | | [btu/lb] | | | | | | | (Tons) | (Btu) | (%) | (%) | (%) | (%) | (%) | (Therms) | (kW) | (kW) | (kW) | (kW) | (kWh) | (kWh) | (kWh) | (\$) | (\$) | (kWh) | (\$) | (kWh) | (\$) | (kWh) | (\$) |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 230 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 4 | 0.92 | 212 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 26.6 | 4.1 | 63.5 | 94 | 14 | 331 | \$ 798 | \$ 60 | 71.8 | \$ 13 | 83.8 | \$ 15 | 186.7 | \$ 34 |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 23 | 0.84 | 193 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 23.9 | 3.0 | 58.0 | 542 | 69 | 1,924 | \$ 701 | \$ 349 | 415.9 | \$ 76 | 485.2 | \$ 88 | 1081.2 | \$ 196 |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 85 | 0.76 | 175 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 21.4 | 2.1 | 52.4 | 1,823 | 177 | 6,465 | \$ 611 | \$ 1,174 | 1398.3 | \$ 254 | 1631.4 | \$ 296 | 3635.7 | \$ 660 |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 128 | 0.68 | 156 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 19.1 | 1.4 | 46.9 | 2,440 | 179 | 8,627 | \$ 532 | \$ 1,567 | 1871.8 | \$ 340 | 2183.8 | \$ 397 | 4866.8 | \$ 884 |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 146 | 0.60 | 138 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 16.9 | 0.9 | 41.4 | 2,456 | 126 | 8,608 | \$ 461 | \$ 1,563 | 1883.7 | \$ 342 | 2197.6 | \$ 399 | 4897.6 | \$ 889 |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 314 | 0.52 | 120 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 14.8 | 0.4 | 35.9 | 4,654 | 136 | 16,042 | \$ 397 | \$ 2,913 | 3569.9 | \$ 648 | 4164.9 | \$ 756 | 9281.7 | \$ 1,686 |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 321 | 0.44 | 101 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 13.1 | 2.4 | 30.4 | 4,208 | 769 | 14,731 | \$ 403 | \$ 2,675 | 3228.2 | \$ 586 | 3766.2 | \$ 684 | 8393.2 | \$ 1,524 |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 214 | 0.36 | 83 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 11.4 | 1.6 | 24.8 | 2,429 | 335 | 8,078 | \$ 336 | \$ 1,467 | 1863.4 | \$ 338 | 2173.9 | \$ 395 | 4844.7 | \$ 880 |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 246 | 0.28 | 64 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 9.8 | 1.0 | 19.3 | 2,400 | 247 | 7,400 | \$ 280 | \$ 1,344 | 1841.4 | \$ 334 | 2148.3 | \$ 390 | 4787.6 | \$ 869 |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 208 | 0.20 | 46 | 0 | 0% | 0% | 60% | 60% | 28% | 0 | 0.0 | 8.3 | 0.6 | 13.8 | 1,724 | 119 | 4,709 | \$ 231 | \$ 855 | 1322.7 | \$ 240 | 1543.1 | \$ 280 | 3438.9 | \$ 625 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 298 | 0.36 | 0 | 1,494,509 | 31% | 68% | 0% | 68% | 0% | 4,941 | 6.1 | 5.3 | 0.0 | -12.5 | 3,379 | 0 | -327 | \$ 295 | \$ 4,375 | 2591.8 | \$ 471 | 3023.7 | \$ 549 | 6738.6 | \$ 1,224 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 306 | 0.44 | 0 | 1,779,079 | 37% | 72% | 0% | 72% | 0% | 6,056 | 7.0 | 6.1 | 0.0 | -14.8 | 4,013 | 0 | -529 | \$ 341 | \$ 5,338 | 3078.2 | \$ 559 | 3591.2 | \$ 652 | 8003.2 | \$ 1,453 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 277 | 0.52 | 0 | 2,063,648 | 43% | 76% | 0% | 76% | 0% | 6,357 | 8.0 | 6.9 | 0.0 | -17.2 | 4,114 | 0 | -654 | \$ 386 | \$ 5,586 | 3155.8 | \$ 573 | 3681.8 | \$ 669 | 8205.2 | \$ 1,490 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 156 | 0.60 | 0 | 2,348,217 | 49% | 80% | 0% | 80% | 0% | 4,071 | 9.1 | 7.8 | 0.0 | -19.6 | 2,632 | 0 | -421 | \$ 439 | \$ 3,577 | 2018.9 | \$ 367 | 2355.3 | \$ 428 | 5249.1 | \$ 953 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 106 | 0.68 | 0 | 2,632,787 | 55% | 84% | 0% | 84% | 0% | 3,096 | 10.2 | 8.8 | 0.0 | -21.9 | 2,017 | 0 | -305 | \$ 495 | \$ 2,723 | 1547.0 | \$ 281 | 1804.8 | \$ 328 | 4022.1 | \$ 730 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 59 | 0.76 | 0 | 2,917,356 | 61% | 88% | 0% | 88% | 0% | 1,919 | 11.5 | 9.9 | 0.0 | -24.3 | 1,267 | 0 | -172 | \$ 557 | \$ 1,691 | 972.1 | \$ 177 | 1134.1 | \$ 206 | 2527.5 | \$ 459 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 6 | 0.84 | 0 | 3,201,926 | 67% | 92% | 0% | 92% | 0% | 230 | 12.8 | 11.1 | 0.0 | -26.7 | 155 | 0 | -18 | \$ 622 | \$ 203 | 118.6 | \$ 22 | 138.4 | \$ 25 | 308.4 | \$ 56 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 4 | 0.92 | 0 | 3,486,495 | 73% | 96% | 0% | 96% | 0% | 155 | 14.3 | 12.3 | 0.0 | -29.1 | 106 | 0 | -10 | \$ 692 | \$ 137 | 81.6 | \$ 15 | 95.3 | \$ 17 | 212.3 | \$ 39 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 3,771,064 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 4,055,634 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 4,340,203 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 2,900 | | 173,251 | 2,414,154,906 | | | | | | 26,824 | 14 | 27 | 4 | 220 | 40,453 | 2,171 | 74,481 | \$ 9,581 | \$ 47,179 | 3,570 | \$ 5,635 | 4,165 | \$ 6,574 | 9,282 | \$ 14,652 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | INS |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 41% |
| Outside Air CFM | 36,018 |
| Cooling Design Load (Tons) | 230 |
| Heating Design Load (Btu) | 1,125,902 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 360,000 |
| Cooling Tower | \$ 230,000 |
| Primary CW Pump | \$ 2,300 |
| Primary HW Pump | \$ 2,000 |
| Secondary CW Pump | \$ 2,000 |
| Maintenance Costs | |
| Condensing Boiler | \$ 23,871 |
| Cooling Tower | \$ 3,220 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 4,774 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 12.9 |
| Primary CW Pump Peak kW | 15.2 |
| Primary HW Pump Peak kW | 15.2 |
| Secondary CW Pump Peak kW | 13.1 |
| Closed Loop Pump Peak kW | 21.7 |
| Open Loop Pump Peak kW | 25.3 |
| Standing Column Well Pump Peak kW | 56.4 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | | | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|---|---------------|------------------------|-----------------------|------------------------|------------|---------|-----------|--------|--------------|---------|---------|--------|------------------------|----------------------|---------------|----------------------|-------------|----------------------|-----------------|------------|------------|------------|------------|------------|-------|--------|-------|-------|-------|-------|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Fully Occupied Hours with Load Factor* | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing | Primary HW | Primary | Secondary | CT Fan | Condensing | HW Pump | CW Pump | CT Fan | Cooling Penalty | Pump Energy | CT Fan Energy | Energy Usage | Demand Cost | Energy Cost | Geothermal Pump | Geothermal | Geothermal | Geothermal | Geothermal | Geothermal | | | | | | |
| | | | | | | | | | | | Boiler Load | Pump Speed | CW Pump | CW Pump | Speed | Boiler Usage | Demand | Demand | Demand | and Heating Benefit | Usage | Usage | (kWh) | (kWh) | (kWh) | (Therms) | (kW) | (kW) | (kW) | (kW) | (kWh) | (kWh) | (kWh) | (kWh) | (kWh) | (kWh) | (kWh) |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 200 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 4 | 0.92 | 184 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 23.1 | 3.6 | 55.2 | 101 | 16 | 357 | \$ 694 | \$ 65 | 57.9 | \$ 11 | 67.5 | \$ 12 | 150.5 | \$ 27 | 933.9 | \$ 170 | | | | |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 30 | 0.84 | 168 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 20.8 | 2.6 | 50.4 | 625 | 79 | 2,220 | \$ 610 | \$ 403 | 359.2 | \$ 65 | 419.0 | \$ 76 | 933.9 | \$ 170 | | | | | | |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 144 | 0.76 | 152 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 18.6 | 1.8 | 45.6 | 2,675 | 259 | 9,488 | \$ 531 | \$ 1,723 | 1536.4 | \$ 279 | 1792.4 | \$ 326 | 3994.5 | \$ 725 | | | | | | |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 306 | 0.68 | 136 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 16.6 | 1.2 | 40.8 | 5,065 | 372 | 17,909 | \$ 463 | \$ 3,252 | 2908.9 | \$ 528 | 3393.7 | \$ 616 | 7563.1 | \$ 1,373 | | | | | | |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 522 | 0.60 | 120 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 14.7 | 0.8 | 36.0 | 7,658 | 393 | 26,847 | \$ 401 | \$ 4,875 | 4398.0 | \$ 799 | 5131.0 | \$ 932 | 11434.9 | \$ 2,077 | | | | | | |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 612 | 0.52 | 104 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 12.9 | 0.4 | 31.2 | 7,899 | 230 | 27,229 | \$ 345 | \$ 4,945 | 4536.2 | \$ 824 | 5292.2 | \$ 961 | 11794.1 | \$ 2,142 | | | | | | |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 730 | 0.44 | 0 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 5.3 | 0.0 | 0.0 | 3,851 | 0 | 3,851 | \$ 137 | \$ 699 | 4772.2 | \$ 867 | 5567.6 | \$ 1,011 | 12407.8 | \$ 2,253 | | | | | | |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 492 | 0.36 | 0 | 0 | 0% | 0% | 68% | 68% | 42% | 0 | 0.0 | 4.6 | 0.0 | 0.0 | 2,251 | 0 | 2,251 | \$ 119 | \$ 409 | 2789.2 | \$ 507 | 3254.0 | \$ 591 | 7251.9 | \$ 1,317 | | | | | | |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 524 | 0.28 | 0 | 0 | 0% | 0% | 64% | 64% | 35% | 0 | 0.0 | 3.9 | 0.0 | 0.0 | 2,061 | 0 | 2,061 | \$ 102 | \$ 374 | 2553.8 | \$ 464 | 2979.4 | \$ 541 | 6639.9 | \$ 1,206 | | | | | | |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 416 | 0.36 | 0 | 865,132 | 28% | 68% | 0% | 68% | 28% | 3,999 | 5.3 | 4.6 | 0.0 | -7.2 | 4,107 | 0 | 1,108 | \$ 257 | \$ 3,790 | 2358.7 | \$ 428 | 2751.8 | \$ 500 | 6132.7 | \$ 1,114 | | | | | | |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 533 | 0.36 | 0 | 913,732 | 29% | 68% | 0% | 68% | 0% | 5,412 | 5.3 | 4.6 | 0.0 | -7.6 | 5,264 | 0 | 1,204 | \$ 257 | \$ 5,076 | 3022.8 | \$ 549 | 3526.6 | \$ 640 | 7859.3 | \$ 1,427 | | | | | | |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 632 | 0.44 | 0 | 1,104,903 | 36% | 72% | 0% | 72% | 0% | 7,761 | 6.1 | 5.3 | 0.0 | -9.2 | 7,201 | 0 | 1,380 | \$ 296 | \$ 7,215 | 4135.2 | \$ 751 | 4824.4 | \$ 876 | 10751.5 | \$ 1,952 | | | | | | |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 589 | 0.52 | 0 | 1,296,075 | 42% | 76% | 0% | 76% | 0% | 8,479 | 6.9 | 6.0 | 0.0 | -10.8 | 7,598 | 0 | 1,238 | \$ 335 | \$ 7,834 | 4363.1 | \$ 792 | 5090.3 | \$ 924 | 11344.0 | \$ 2,060 | | | | | | |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 376 | 0.60 | 0 | 1,487,246 | 48% | 80% | 0% | 80% | 0% | 6,206 | 7.9 | 6.8 | 0.0 | -12.4 | 5,508 | 0 | 854 | \$ 381 | \$ 5,724 | 3163.4 | \$ 574 | 3690.6 | \$ 670 | 8224.8 | \$ 1,494 | | | | | | |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 224 | 0.68 | 0 | 1,678,418 | 54% | 84% | 0% | 84% | 0% | 4,176 | 8.9 | 7.7 | 0.0 | -14.0 | 3,711 | 0 | 579 | \$ 431 | \$ 3,853 | 2131.1 | \$ 387 | 2486.2 | \$ 451 | 5540.7 | \$ 1,006 | | | | | | |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 147 | 0.76 | 0 | 1,869,589 | 60% | 88% | 0% | 88% | 0% | 3,063 | 10.0 | 8.6 | 0.0 | -15.6 | 2,745 | 0 | 448 | \$ 484 | \$ 2,830 | 1576.4 | \$ 286 | 1839.1 | \$ 334 | 4098.6 | \$ 744 | | | | | | |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 26 | 0.84 | 0 | 2,060,761 | 66% | 92% | 0% | 92% | 0% | 591 | 11.2 | 9.6 | 0.0 | -17.2 | 537 | 0 | 94 | \$ 541 | \$ 548 | 308.6 | \$ 56 | 360.0 | \$ 65 | 802.3 | \$ 146 | | | | | | |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 13 | 0.92 | 0 | 2,251,932 | 72% | 96% | 0% | 96% | 0% | 334 | 12.4 | 10.7 | 0.0 | -18.8 | 309 | 0 | 58 | \$ 602 | \$ 310 | 177.2 | \$ 32 | 206.7 | \$ 38 | 460.7 | \$ 84 | | | | | | |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 2,443,104 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | | | | |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 2,634,276 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | | | | |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 2,825,447 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | | | | |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 6,320 | | 195,584 | 3,601,890,015 | | | | | 40,021 | 12 | 23 | 4 | | 69,166 | 1,349 | 99,175 | \$ 8,332 | \$ 62,257 | 4,772 | \$ 8,199 | 5,568 | \$ 9,565 | 12,408 | \$ 21,317 | | | | | | | |

*These occupancy hours factor in the actual % of occupancy in the multifamily buildings at each time period.

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | MF1 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 30% |
| Outside Air CFM | 9,000 |
| Cooling Design Load (Tons) | 200 |
| Heating Design Load (Btu) | 1,782,144 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 240,000 |
| Cooling Tower | \$ 20,000 |
| Primary CW Pump | \$ 2,000 |
| Primary HW Pump | \$ 2,000 |
| Secondary CW Pump | \$ 1,800 |
| Maintenance Costs | |
| Condensing Boiler | \$ 15,540 |
| Cooling Tower | \$ 2,800 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Condensing Boiler (MBH) | 3,108 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 11.2 |
| Primary CW Pump Peak kW | 13.2 |
| Primary HW Pump Peak kW | 13.2 |
| Secondary CW Pump Peak kW | 11.4 |
| Closed Loop Pump Peak kW | 14.1 |
| Open Loop Pump Peak kW | 16.5 |
| Standing Column Well Pump Peak kW | 36.7 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | Geothermal Heat Pump Energy | | | |
|----------------|-------|---------------|-------|-------|-------|-------|--|---------------|------------------------|-----------------------|-------------------------------|------------------------------|--------------------------|--|-------------------------------------|------------------------|-----------------------------|----------------------------|------------------------------------|-----------------------|----------------------|---------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------------|---|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Fully Occupied Hours with Load Factor* | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Split System Load (%) | Extra kW/Ton for Air Cooled System (kW) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | Split System Demand (kW) | Pump Energy Usage (kWh) | Split System Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Heat Pump Demand (kWh) | Geothermal Heat Pump Energy Costs (\$) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 4 | 0.92 | 92 | 0 | 0% | 0% | 62% | 28 | 0 | 0.0 | 34.9 | 0 | 152 | 152 | \$ 907 | \$ 28 | 31.0 | \$ 6 | 36.2 | \$ 7 | 80.6 | \$ 15 | 0 | \$ - |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 30 | 0.84 | 84 | 0 | 0% | 0% | 55% | 25 | 0 | 0.0 | 31.7 | 0 | 952 | 952 | \$ 823 | \$ 173 | 192.4 | \$ 35 | 224.5 | \$ 41 | 500.3 | \$ 91 | 0 | \$ - |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 144 | 0.76 | 76 | 0 | 0% | 0% | 47% | 23 | 0 | 0.0 | 28.3 | 0 | 4,069 | 4,069 | \$ 736 | \$ 739 | 823.1 | \$ 149 | 960.2 | \$ 174 | 2140.0 | \$ 389 | 0 | \$ - |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 306 | 0.68 | 68 | 0 | 0% | 0% | 40% | 20 | 0 | 0.0 | 25.1 | 0 | 7,671 | 7,671 | \$ 652 | \$ 1,393 | 1558.4 | \$ 283 | 1818.1 | \$ 330 | 4051.8 | \$ 736 | 0 | \$ - |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 522 | 0.60 | 60 | 0 | 0% | 0% | 33% | 18 | 0 | 0.0 | 21.9 | 0 | 11,420 | 11,420 | \$ 569 | \$ 2,074 | 2356.2 | \$ 428 | 2748.8 | \$ 499 | 6126.0 | \$ 1,112 | 0 | \$ - |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 612 | 0.52 | 52 | 0 | 0% | 0% | 25% | 16 | 0 | 0.0 | 18.5 | 0 | 11,346 | 11,346 | \$ 482 | \$ 2,060 | 2430.2 | \$ 441 | 2835.2 | \$ 515 | 6318.5 | \$ 1,147 | 0 | \$ - |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 730 | 0.44 | 0 | 0 | 0% | 0% | 50% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 2556.6 | \$ 464 | 2982.7 | \$ 542 | 6647.2 | \$ 1,207 | 0 | \$ - |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 492 | 0.36 | 0 | 0 | 0% | 0% | 42% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 1494.2 | \$ 271 | 1743.3 | \$ 317 | 3885.0 | \$ 706 | 0 | \$ - |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 524 | 0.28 | 0 | 0 | 0% | 0% | 35% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 1368.1 | \$ 248 | 1596.2 | \$ 290 | 3557.2 | \$ 646 | 0 | \$ - |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 416 | 0.36 | 0 | 463,895 | 28% | 68% | 28% | 0 | 2,144 | 2.6 | 0.0 | 1,102 | 0 | 1,102 | \$ 69 | \$ 2,124 | 1263.6 | \$ 229 | 1474.2 | \$ 268 | 3285.4 | \$ 597 | 9,775 | \$ 1,775 |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 533 | 0.36 | 0 | 488,195 | 29% | 68% | 0% | 0 | 2,892 | 2.6 | 0.0 | 1,412 | 0 | 1,412 | \$ 69 | \$ 2,851 | 1619.4 | \$ 294 | 1889.3 | \$ 343 | 4210.4 | \$ 765 | 13,183 | \$ 2,394 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 632 | 0.44 | 0 | 590,742 | 35% | 72% | 0% | 0 | 4,149 | 3.1 | 0.0 | 1,932 | 0 | 1,932 | \$ 79 | \$ 4,075 | 2215.3 | \$ 402 | 2584.6 | \$ 469 | 5759.9 | \$ 1,046 | 18,917 | \$ 3,435 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 589 | 0.52 | 0 | 693,290 | 42% | 76% | 0% | 0 | 4,536 | 3.5 | 0.0 | 2,038 | 0 | 2,038 | \$ 90 | \$ 4,441 | 2337.4 | \$ 424 | 2727.0 | \$ 495 | 6077.3 | \$ 1,104 | 20,679 | \$ 3,755 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 376 | 0.60 | 0 | 795,838 | 48% | 80% | 0% | 0 | 3,321 | 3.9 | 0.0 | 1,478 | 0 | 1,478 | \$ 102 | \$ 3,248 | 1694.7 | \$ 308 | 1977.2 | \$ 359 | 4406.3 | \$ 800 | 15,139 | \$ 2,749 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 224 | 0.68 | 0 | 898,385 | 54% | 84% | 0% | 0 | 2,235 | 4.4 | 0.0 | 996 | 0 | 996 | \$ 116 | \$ 2,187 | 1141.7 | \$ 207 | 1331.9 | \$ 242 | 2968.3 | \$ 539 | 10,191 | \$ 1,851 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 147 | 0.76 | 0 | 1,000,933 | 60% | 88% | 0% | 0 | 1,640 | 5.0 | 0.0 | 736 | 0 | 736 | \$ 130 | \$ 1,605 | 844.5 | \$ 153 | 985.3 | \$ 179 | 2195.7 | \$ 399 | 7,477 | \$ 1,358 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 26 | 0.84 | 0 | 1,103,481 | 66% | 92% | 0% | 0 | 317 | 5.6 | 0.0 | 144 | 0 | 144 | \$ 145 | \$ 310 | 165.3 | \$ 30 | 192.9 | \$ 35 | 429.8 | \$ 78 | 1,444 | \$ 262 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 13 | 0.92 | 0 | 1,206,028 | 72% | 96% | 0% | 0 | 179 | 6.2 | 0.0 | 83 | 0 | 83 | \$ 161 | \$ 175 | 94.9 | \$ 17 | 110.8 | \$ 20 | 246.8 | \$ 45 | 815 | \$ 148 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 1,308,576 | 79% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 1,411,124 | 85% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 1,513,671 | 91% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 6,320 | | 97,792 | 1,927,096,614 | | | | 21,412 | 6 | 35 | 9,921 | 35,610 | 45,531 | \$ 10,882 | \$ 38,365 | 2,557 | \$ 4,392 | 2,983 | \$ 5,124 | 6,647 | \$ 11,420 | 97,620 | \$ 17,728 | |

*These occupancy hours factor in the actual % of occupancy for the multifamily buildings at each time period.

| Assumptions | |
|-----------------------------------|----------|
| Building Type | MF2 |
| Building Interior Square Footage | 50,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 5.0 |
| Perimeter Surface Area | 24,000 |
| Wall to Window Ratio | 30% |
| Outside Air CFM | 4,500 |
| Cooling Design Load (Tons) | 100 |
| Heating Design Load (Btu) | 978,096 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Air Cooled kW/Ton Penalty | 0.3 |
| Load Factor Decrease per 5 F | 0.08 |

| Installation Costs | |
|-----------------------|------------|
| Condensing Boiler | \$ 130,000 |
| Split System AC Units | \$ 100,000 |
| Primary HW Pump | \$ 1,000 |
| Maintenance Costs | |
| Condensing Boiler | \$ 8,325 |
| Cooling Tower | \$ 1,400 |

| Auxiliary Equipment | |
|------------------------------------|-------|
| Condensing Boiler (MBH) | 1,665 |
| Condensing Boiler Efficiency | 90% |
| Split System Condenser Fan Peak kW | 11.7 |
| Primary HW Pump Peak kW | 6.6 |
| Closed Loop Pump Peak kW | 7.6 |
| Open Loop Pump Peak kW | 8.8 |
| Standing Column Well Pump Peak kW | 19.7 |
| Heat Pump Efficiency (COP) | 4.5 |
| Heat Cooling Coincidence factor | 0.7 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|--|---------------|------------------------|-----------------------|--------------------------|------------------------------|------------------------------|--------------------------------|---------------------|--------------------------------|------------------------|------------------------|-----------------------|---|----------------------------|------------------------------|-----------------------|---------------------|----------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|------|
| DB (+2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Fully Occupied Hours with Load Factor* | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Steam Boiler Load (%) | Primary HW Pump Speed (%) | Primary CW Pump Speed (%) | Secondary CW Pump Speed (%) | CT Fan Speed (%) | Steam Boiler Usage (Therms) | HW Pump Demand (kW) | CW Pump Demand (kW) | CT Fan Demand (kW) | Cooling Penalty and Heating Benefit (kW) | Pump Energy Usage (kWh) | CT Fan Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | 79.9 | 43.2 | 0 | 0 | 0 | 0 | 0 | 1.00 | 200 | 0 | 0% | 0% | 0% | 0% | 70% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 4 | 0.92 | 184 | 0 | 0% | 0% | 96% | 96% | 62% | 0 | 0.0 | 23.1 | 3.6 | 55.2 | 101 | 16 | 357 | \$ 694 | \$ 65 | 49.2 | \$ 9 | 57.4 | \$ 10 | 100.1 | \$ 18 | |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 30 | 0.84 | 168 | 0 | 0% | 0% | 92% | 92% | 55% | 0 | 0.0 | 20.8 | 2.6 | 50.4 | 625 | 79 | 2,220 | \$ 610 | \$ 403 | 305.1 | \$ 55 | 355.9 | \$ 65 | 620.9 | \$ 113 | |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 144 | 0.76 | 152 | 0 | 0% | 0% | 88% | 88% | 47% | 0 | 0.0 | 18.6 | 1.8 | 45.6 | 2,675 | 259 | 9,488 | \$ 531 | \$ 1,723 | 1305.0 | \$ 237 | 1522.5 | \$ 276 | 2655.7 | \$ 482 | |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 306 | 0.68 | 136 | 0 | 0% | 0% | 84% | 84% | 40% | 0 | 0.0 | 16.6 | 1.2 | 40.8 | 5,065 | 372 | 17,909 | \$ 463 | \$ 3,252 | 2470.9 | \$ 449 | 2882.7 | \$ 523 | 5028.3 | \$ 913 | |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 522 | 0.60 | 120 | 0 | 0% | 0% | 80% | 80% | 33% | 0 | 0.0 | 14.7 | 0.8 | 36.0 | 7,658 | 393 | 26,847 | \$ 401 | \$ 4,875 | 3735.8 | \$ 678 | 4358.4 | \$ 791 | 7602.4 | \$ 1,381 | |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 612 | 0.52 | 104 | 0 | 0% | 0% | 76% | 76% | 25% | 0 | 0.0 | 12.9 | 0.4 | 31.2 | 7,899 | 230 | 27,229 | \$ 345 | \$ 4,945 | 3853.2 | \$ 700 | 4495.4 | \$ 816 | 7841.3 | \$ 1,424 | |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 730 | 0.44 | 0 | 0 | 0% | 0% | 72% | 72% | 50% | 0 | 0.0 | 5.3 | 0.0 | 0.0 | 3,851 | 0 | 3,851 | \$ 137 | \$ 699 | 4053.6 | \$ 736 | 4729.2 | \$ 859 | 8249.2 | \$ 1,498 | |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 492 | 0.36 | 0 | 0 | 0% | 0% | 68% | 42% | 0 | 0.0 | 4.6 | 0.0 | 0.0 | 2,251 | 0 | 2,251 | \$ 119 | \$ 409 | 2369.2 | \$ 430 | 2764.1 | \$ 502 | 4821.4 | \$ 876 | | |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 524 | 0.28 | 0 | 0 | 0% | 0% | 64% | 35% | 0 | 0.0 | 3.9 | 0.0 | 0.0 | 2,061 | 0 | 2,061 | \$ 102 | \$ 374 | 2169.3 | \$ 394 | 2530.8 | \$ 460 | 4414.5 | \$ 802 | | |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 416 | 0.36 | 0 | 567,337 | 27% | 68% | 0% | 68% | 28% | 2,622 | 5.3 | 4.6 | 0.0 | -4.7 | 4,107 | 0 | 2,141 | \$ 257 | \$ 2,742 | 2003.6 | \$ 364 | 2337.5 | \$ 424 | 4077.3 | \$ 740 | |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 533 | 0.36 | 0 | 632,137 | 31% | 68% | 0% | 68% | 0% | 3,744 | 5.3 | 4.6 | 0.0 | -5.3 | 5,264 | 0 | 2,455 | \$ 257 | \$ 3,806 | 2567.6 | \$ 466 | 2995.6 | \$ 544 | 5225.2 | \$ 949 | |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 632 | 0.44 | 0 | 756,772 | 37% | 72% | 0% | 72% | 0% | 5,316 | 6.1 | 5.3 | 0.0 | -6.3 | 7,201 | 0 | 3,214 | \$ 296 | \$ 5,354 | 3512.5 | \$ 638 | 4097.9 | \$ 744 | 7148.1 | \$ 1,298 | |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 589 | 0.52 | 0 | 881,407 | 43% | 76% | 0% | 76% | 0% | 5,766 | 6.9 | 6.0 | 0.0 | -7.3 | 7,598 | 0 | 3,273 | \$ 335 | \$ 5,769 | 3706.1 | \$ 673 | 4323.8 | \$ 785 | 7542.0 | \$ 1,370 | |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 376 | 0.60 | 0 | 1,006,042 | 49% | 80% | 0% | 80% | 0% | 4,198 | 7.9 | 6.8 | 0.0 | -8.4 | 5,508 | 0 | 2,360 | \$ 381 | \$ 4,196 | 2687.1 | \$ 488 | 3134.9 | \$ 569 | 5468.2 | \$ 993 | |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 224 | 0.68 | 0 | 1,130,676 | 55% | 84% | 0% | 84% | 0% | 2,813 | 8.9 | 7.7 | 0.0 | -9.4 | 3,711 | 0 | 1,601 | \$ 431 | \$ 2,815 | 1810.2 | \$ 329 | 2111.9 | \$ 384 | 3683.7 | \$ 669 | |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 147 | 0.76 | 0 | 1,255,311 | 61% | 88% | 0% | 88% | 0% | 2,057 | 10.0 | 8.6 | 0.0 | -10.5 | 2,745 | 0 | 1,202 | \$ 484 | \$ 2,064 | 1339.0 | \$ 243 | 1562.2 | \$ 284 | 2724.9 | \$ 495 | |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 26 | 0.84 | 0 | 1,379,946 | 67% | 92% | 0% | 92% | 0% | 396 | 11.2 | 9.6 | 0.0 | -11.5 | 537 | 0 | 240 | \$ 541 | \$ 399 | 262.1 | \$ 48 | 305.8 | \$ 56 | 533.4 | \$ 97 | |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 13 | 0.92 | 0 | 1,504,581 | 73% | 96% | 0% | 96% | 0% | 223 | 12.4 | 10.7 | 0.0 | -12.5 | 309 | 0 | 141 | \$ 602 | \$ 226 | 150.5 | \$ 27 | 175.6 | \$ 32 | 306.3 | \$ 56 | |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 1,629,216 | 79% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 1,753,851 | 85% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 1,878,486 | 91% | 0% | 0% | 0% | 0% | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 6,320 | | 195,584 | 2,442,169,883 | | | | | | 27,135 | 12 | 23 | 4 | 183 | 69,166 | 1,349 | 108,839 | \$ 8,332 | \$ 52,448 | 4,054 | \$ 6,964 | 4,729 | \$ 8,125 | 8,249 | \$ 14,173 | |

*These occupancy hours factor in the actual % of occupancy for the multifamily buildings at each time period.

| Assumptions | |
|-----------------------------------|----------|
| Building Type | NYCHA |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 21% |
| Infiltration CFM | 12,000 |
| Cooling Design Load (Tons) | 200 |
| Heating Design Load (Btu) | 747,936 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Cooling Penalty for EWT (kW/ton) | 0.3 |
| Heating Benefit for EWT (kW/Ton) | 0.1 |
| Load Factor Decrease per 5 F | 0.08 |

| Auxiliary Equipment | |
|-----------------------------------|-------|
| Walls, Steel-Framed R-13 | 2,066 |
| Condensing Boiler Efficiency | 90% |
| Cooling Tower Peak kW | 11.2 |
| Primary CW Pump Peak kW | 13.2 |
| Primary HW Pump Peak kW | 13.2 |
| Secondary CW Pump Peak kW | 11.4 |
| Closed Loop Pump Peak kW | 12.0 |
| Open Loop Pump Peak kW | 14.0 |
| Standing Column Well Pump Peak kW | 24.4 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Installation Costs | |
|--------------------|------------|
| Condensing Boiler | \$ 160,000 |
| Cooling Tower | \$ 200,000 |
| Primary CW Pump | \$ 2,000 |
| Primary HW Pump | \$ 2,000 |
| Secondary CW Pump | \$ 1,800 |

| Maintenance Costs | |
|-------------------|-----------|
| Steam Boiler | \$ 10,332 |
| Cooling Tower | \$ 2,800 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | Geothermal Heat Pump Energy | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|--------------------------|--|-------------------------------------|------------------------|-----------------------------|----------------------------|------------------------------------|-----------------------|----------------------|---------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------------|---|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Split System Load (%) | Extra kW/Ton for Air Cooled System (kW) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | Split System Demand (kW) | Pump Energy Usage (kWh) | Split System Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Heat Pump Demand (kWh) | Geothermal Heat Pump Energy Costs (\$) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 3 | 0.92 | 184 | 0 | 0% | 0% | 62% | 55 | 0 | 0.0 | 69.8 | 0 | 239 | 239 | \$ 1,814 | \$ 43 | 40.6 | \$ 7 | 59.1 | \$ 11 | 131.7 | \$ 24 | 0 | \$ - |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 24 | 0.84 | 168 | 0 | 0% | 0% | 55% | 50 | 0 | 0.0 | 63.3 | 0 | 1,526 | 1,526 | \$ 1,646 | \$ 277 | 256.4 | \$ 47 | 373.5 | \$ 68 | 832.5 | \$ 151 | 0 | \$ - |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 122 | 0.76 | 152 | 0 | 0% | 0% | 47% | 46 | 0 | 0.0 | 56.6 | 0 | 6,933 | 6,933 | \$ 1,472 | \$ 1,259 | 1165.4 | \$ 212 | 1697.5 | \$ 308 | 3783.1 | \$ 687 | 0 | \$ - |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 280 | 0.68 | 136 | 0 | 0% | 0% | 40% | 41 | 0 | 0.0 | 50.2 | 0 | 14,062 | 14,062 | \$ 1,305 | \$ 2,554 | 2374.2 | \$ 431 | 3458.3 | \$ 628 | 7707.1 | \$ 1,400 | 0 | \$ - |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 518 | 0.60 | 120 | 0 | 0% | 0% | 33% | 36 | 0 | 0.0 | 43.7 | 0 | 22,647 | 22,647 | \$ 1,137 | \$ 4,113 | 3883.0 | \$ 705 | 5656.1 | \$ 1,027 | 12605.0 | \$ 2,289 | 0 | \$ - |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 616 | 0.52 | 104 | 0 | 0% | 0% | 25% | 31 | 0 | 0.0 | 37.1 | 0 | 22,824 | 22,824 | \$ 964 | \$ 4,145 | 4062.5 | \$ 738 | 5917.6 | \$ 1,075 | 13187.8 | \$ 2,395 | 0 | \$ - |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 749 | 0.44 | 0 | 0 | 0% | 0% | 50% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | \$ - | \$ - | 4364.8 | \$ 793 | 6358.0 | \$ 1,155 | 14169.3 | \$ 2,573 | 0 | \$ - | |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 504 | 0.36 | 0 | 0 | 0% | 0% | 42% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | \$ - | \$ - | 2543.0 | \$ 462 | 3704.3 | \$ 673 | 8255.3 | \$ 1,499 | 0 | \$ - | |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 537 | 0.28 | 0 | 0 | 0% | 0% | 35% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | \$ - | \$ - | 2328.7 | \$ 423 | 3392.1 | \$ 616 | 7559.6 | \$ 1,373 | 0 | \$ - | |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 420 | 0.20 | 0 | 0 | 0% | 0% | 28% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | \$ - | \$ - | 2120.0 | \$ 385 | 3088.1 | \$ 561 | 6882.0 | \$ 1,250 | 0 | \$ - | |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 531 | 0.36 | 0 | 1,056,767 | 31% | 68% | 0% | 0 | 6,238 | 5.3 | 0.0 | 2,815 | 0 | 2,815 | \$ 138 | \$ 6,109 | 2682.2 | \$ 487 | 3907.1 | \$ 710 | 8707.2 | \$ 1,581 | 28,439 | \$ 5,164 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 642 | 0.44 | 0 | 1,265,204 | 37% | 72% | 0% | 0 | 9,024 | 6.1 | 0.0 | 3,923 | 0 | 3,923 | \$ 159 | \$ 8,810 | 3738.7 | \$ 679 | 5446.0 | \$ 989 | 12136.7 | \$ 2,204 | 41,139 | \$ 7,471 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 600 | 0.52 | 0 | 1,473,641 | 43% | 76% | 0% | 0 | 9,823 | 6.9 | 0.0 | 4,153 | 0 | 4,153 | \$ 180 | \$ 9,569 | 3958.1 | \$ 719 | 5765.5 | \$ 1,047 | 12848.9 | \$ 2,333 | 44,782 | \$ 8,132 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 385 | 0.60 | 0 | 1,682,078 | 49% | 80% | 0% | 0 | 7,204 | 7.9 | 0.0 | 3,034 | 0 | 3,034 | \$ 205 | \$ 7,015 | 2891.0 | \$ 525 | 4211.2 | \$ 765 | 9384.9 | \$ 1,704 | 32,842 | \$ 5,964 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 230 | 0.68 | 0 | 1,890,516 | 55% | 84% | 0% | 0 | 4,828 | 8.9 | 0.0 | 2,044 | 0 | 2,044 | \$ 231 | \$ 4,704 | 1947.8 | \$ 354 | 2837.2 | \$ 515 | 6322.9 | \$ 1,148 | 22,013 | \$ 3,997 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 157 | 0.76 | 0 | 2,098,953 | 61% | 88% | 0% | 0 | 3,657 | 10.0 | 0.0 | 1,566 | 0 | 1,566 | \$ 260 | \$ 3,566 | 1492.4 | \$ 271 | 2173.9 | \$ 395 | 4844.8 | \$ 880 | 16,670 | \$ 3,027 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 28 | 0.84 | 0 | 2,307,390 | 67% | 92% | 0% | 0 | 729 | 11.2 | 0.0 | 317 | 0 | 317 | \$ 290 | \$ 712 | 302.4 | \$ 55 | 440.5 | \$ 80 | 981.7 | \$ 178 | 3,323 | \$ 603 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 15 | 0.92 | 0 | 2,515,827 | 73% | 96% | 0% | 0 | 410 | 12.4 | 0.0 | 182 | 0 | 182 | \$ 323 | \$ 401 | 173.7 | \$ 32 | 253.0 | \$ 46 | 563.8 | \$ 102 | 1,871 | \$ 340 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 2,724,264 | 79% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 2,932,701 | 85% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 3,141,138 | 91% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 6,361 | | 187,550 | 3,772,039,780 | | | | | 41,912 | 12 | 70 | 18,035 | 68,231 | 86,266 | \$ 21,763 | \$ 75,040 | 4,365 | \$ 7,323 | 6,358 | \$ 10,667 | 14,169 | \$ 23,772 | 191,078 | \$ 34,700 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | SF1 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 15% |
| Outside Air CFM | 20,000 |
| Cooling Design Load (Tons) | 200 |
| Heating Design Load (Btu) | 1,255,464 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Air Cooled kW/Ton Penalty | 0.3 |
| Load Factor Decrease per 5 F | 0.08 |

| Auxiliary Equipment | |
|------------------------------------|-------|
| Condensing Boiler (MBH) | 3,455 |
| Condensing Boiler Efficiency | 90% |
| Split System Condenser Fan Peak kW | 23.5 |
| Primary HW Pump Peak kW | 13.2 |
| Closed Loop Pump Peak kW | 12.6 |
| Open Loop Pump Peak kW | 18.3 |
| Standing Column Well Pump Peak kW | 40.8 |
| Heat Pump Efficiency (COP) | 4.5 |
| Heat Cooling Coincidence factor | 0.7 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

| Installation Costs | |
|-----------------------|------------|
| Condensing Boiler | \$ 260,000 |
| Split System AC Units | \$ 200,000 |
| Primary HW Pump | \$ 2,000 |
| Maintenance Costs | |
| Condensing Boiler | \$ 17,276 |

| Weather data | | | Hours | | | | Operating Hours | Building Load | | | Conventional Operation | | | | | | | | Geothermal Operation | | Geothermal Operation | | Geothermal Operation | | Geothermal Heat Pump Energy | | | | | |
|----------------|-------|---------------|-------|-------|-------|-------|-----------------|---------------|------------------------|-----------------------|-------------------------------|------------------------------|--------------------------|--|-------------------------------------|------------------------|-----------------------------|----------------------------|------------------------------------|-----------------------|----------------------|---------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|--------------------------------------|---|
| DB (+-2) | MCWB | h [btu/lb] | 1-8 | 9-16 | 17-0 | Total | Occupied Space | Load Factor | Cooling Load (Tons) | Heating Load (Btu) | Condensing Boiler Load (%) | Primary HW Pump Speed (%) | Split System Load (%) | Extra kW/Ton for Air Cooled System (kW) | Condensing Boiler Usage (Therms) | HW Pump Demand (kW) | Split System Demand (kW) | Pump Energy Usage (kWh) | Split System Energy Usage (kWh) | Energy Usage (kWh) | Demand Cost (\$) | Energy Cost (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Pump Usage (kWh) | Geothermal Energy Costs (\$) | Geothermal Heat Pump Demand (kWh) | Geothermal Heat Pump Energy Costs (\$) |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | 75.7 | 39.6 | 0 | 8 | 1 | 9 | 3 | 0.92 | 184 | 0 | 0% | 0% | 62% | 55 | 0 | 0.0 | 69.8 | 0 | 239 | 239 | \$ 1,814 | \$ 43 | 39.1 | \$ 7 | 57.0 | \$ 10 | 127.0 | \$ 23 | 0 | \$ - |
| 92 | 73.0 | 37.7 | 0 | 51 | 9 | 60 | 24 | 0.84 | 168 | 0 | 0% | 0% | 55% | 50 | 0 | 0.0 | 63.3 | 0 | 1,526 | 1,526 | \$ 1,646 | \$ 277 | 247.3 | \$ 45 | 360.2 | \$ 65 | 802.6 | \$ 146 | 0 | \$ - |
| 87 | 69.7 | 35.7 | 5 | 184 | 68 | 257 | 122 | 0.76 | 152 | 0 | 0% | 0% | 47% | 46 | 0 | 0.0 | 56.6 | 0 | 6,933 | 6,933 | \$ 1,472 | \$ 1,259 | 1124.0 | \$ 204 | 1636.7 | \$ 297 | 3647.4 | \$ 662 | 0 | \$ - |
| 82 | 67.5 | 33.6 | 45 | 257 | 178 | 480 | 280 | 0.68 | 136 | 0 | 0% | 0% | 40% | 41 | 0 | 0.0 | 50.2 | 0 | 14,062 | 14,062 | \$ 1,305 | \$ 2,554 | 2289.9 | \$ 416 | 3334.3 | \$ 606 | 7430.7 | \$ 1,349 | 0 | \$ - |
| 77 | 65.4 | 32.1 | 206 | 263 | 265 | 734 | 518 | 0.60 | 120 | 0 | 0% | 0% | 33% | 36 | 0 | 0.0 | 43.7 | 0 | 22,647 | 22,647 | \$ 1,137 | \$ 4,113 | 3745.1 | \$ 680 | 5453.3 | \$ 990 | 12153.0 | \$ 2,207 | 0 | \$ - |
| 72 | 62.0 | 29.7 | 275 | 276 | 294 | 845 | 616 | 0.52 | 104 | 0 | 0% | 0% | 25% | 31 | 0 | 0.0 | 37.1 | 0 | 22,824 | 22,824 | \$ 964 | \$ 4,145 | 3918.2 | \$ 712 | 5705.4 | \$ 1,036 | 12714.9 | \$ 2,309 | 0 | \$ - |
| 67 | 58.2 | 26.4 | 385 | 267 | 325 | 977 | 749 | 0.44 | 0 | 0 | 0% | 0% | 50% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 4209.8 | \$ 765 | 6130.0 | \$ 1,113 | 13661.2 | \$ 2,481 | 0 | \$ - |
| 62 | 55.2 | 23.6 | 246 | 175 | 235 | 656 | 504 | 0.36 | 0 | 0 | 0% | 0% | 42% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 2452.7 | \$ 445 | 3571.5 | \$ 649 | 7959.3 | \$ 1,445 | 0 | \$ - |
| 57 | 51.3 | 20.8 | 280 | 212 | 220 | 712 | 537 | 0.28 | 0 | 0 | 0% | 0% | 35% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 2246.0 | \$ 408 | 3270.5 | \$ 594 | 7288.5 | \$ 1,324 | 0 | \$ - |
| 52 | 47.0 | 18.3 | 192 | 181 | 198 | 571 | 420 | 0.20 | 0 | 0 | 0% | 0% | 28% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 2044.7 | \$ 371 | 2977.4 | \$ 541 | 6635.3 | \$ 1,205 | 0 | \$ - |
| 47 | 41.9 | 15.9 | 229 | 271 | 251 | 751 | 531 | 0.36 | 0 | 1,021,810 | 31% | 68% | 0% | 0 | 6,032 | 5.3 | 0.0 | 2,815 | 0 | 2,815 | \$ 138 | \$ 5,924 | 2587.0 | \$ 470 | 3767.0 | \$ 684 | 8395.0 | \$ 1,525 | 27,498 | \$ 4,994 |
| 42 | 37.4 | 13.9 | 309 | 265 | 289 | 863 | 642 | 0.44 | 0 | 1,222,478 | 37% | 72% | 0% | 0 | 8,719 | 6.1 | 0.0 | 3,923 | 0 | 3,923 | \$ 159 | \$ 8,537 | 3605.9 | \$ 655 | 5250.7 | \$ 954 | 11701.5 | \$ 2,125 | 39,750 | \$ 7,219 |
| 37 | 32.8 | 12.0 | 294 | 237 | 268 | 799 | 600 | 0.52 | 0 | 1,423,147 | 43% | 76% | 0% | 0 | 9,486 | 6.9 | 0.0 | 4,153 | 0 | 4,153 | \$ 180 | \$ 9,267 | 3817.6 | \$ 693 | 5558.8 | \$ 1,009 | 12388.2 | \$ 2,250 | 43,247 | \$ 7,854 |
| 32 | 28.0 | 10.1 | 187 | 124 | 185 | 496 | 385 | 0.60 | 0 | 1,623,816 | 49% | 80% | 0% | 0 | 6,954 | 7.9 | 0.0 | 3,034 | 0 | 3,034 | \$ 205 | \$ 6,791 | 2788.3 | \$ 506 | 4060.1 | \$ 737 | 9048.3 | \$ 1,643 | 31,704 | \$ 5,757 |
| 27 | 23.2 | 8.3 | 124 | 92 | 89 | 305 | 230 | 0.68 | 0 | 1,824,485 | 55% | 84% | 0% | 0 | 4,660 | 8.9 | 0.0 | 2,044 | 0 | 2,044 | \$ 231 | \$ 4,553 | 1878.6 | \$ 341 | 2735.5 | \$ 497 | 6096.1 | \$ 1,107 | 21,244 | \$ 3,858 |
| 22 | 18.9 | 6.7 | 109 | 50 | 37 | 196 | 157 | 0.76 | 0 | 2,025,154 | 61% | 88% | 0% | 0 | 3,528 | 10.0 | 0.0 | 1,566 | 0 | 1,566 | \$ 260 | \$ 3,450 | 1439.4 | \$ 261 | 2096.0 | \$ 381 | 4671.0 | \$ 848 | 16,084 | \$ 2,921 |
| 17 | 14.7 | 5.2 | 22 | 4 | 6 | 32 | 28 | 0.84 | 0 | 2,225,822 | 67% | 92% | 0% | 0 | 703 | 11.2 | 0.0 | 317 | 0 | 317 | \$ 290 | \$ 689 | 291.7 | \$ 53 | 424.7 | \$ 77 | 946.5 | \$ 172 | 3,205 | \$ 582 |
| 12 | 10.1 | 3.8 | 12 | 3 | 2 | 17 | 15 | 0.92 | 0 | 2,426,491 | 73% | 96% | 0% | 0 | 396 | 12.4 | 0.0 | 182 | 0 | 182 | \$ 323 | \$ 388 | 167.5 | \$ 30 | 243.9 | \$ 44 | 543.6 | \$ 99 | 1,804 | \$ 328 |
| 7 | 11.4 | 2.4 | 0 | 0 | 0 | 0 | 0 | 1.00 | 0 | 2,627,160 | 79% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| 2 | 1.2 | 1.2 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 2,827,829 | 85% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| -3 | (2.6) | 0.0 | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 3,028,498 | 91% | 0% | 0% | 0 | 0 | 0.0 | 0.0 | 0 | 0 | 0 | \$ - | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0.0 | \$ - | 0 | \$ - |
| TOTALS: | | | 2,920 | 2,920 | 2,920 | 8,760 | 6,361 | | 187,550 | 3,642,917,817 | | | | | 40,477 | 12 | 70 | 18,035 | 68,231 | 86,266 | \$ 21,763 | \$ 73,753 | 4,210 | \$ 7,063 | 6,130 | \$ 10,285 | 13,661 | \$ 22,920 | 184,537 | \$ 33,512 |

| Assumptions | |
|-----------------------------------|-----------|
| Building Type | SF2 |
| Building Interior Square Footage | 100,000 |
| Building Footprint Square Footage | 10,000 |
| Number of Floors | 10.0 |
| Perimeter Surface Area | 48,000 |
| Wall to Window Ratio | 15% |
| Outside Air CFM | 20,000 |
| Cooling Design Load (Tons) | 200 |
| Heating Design Load (Btu) | 1,158,360 |
| Demand Cost (\$/kW) | \$ 26.00 |
| Electricity Energy Cost (\$/kWh) | \$ 0.18 |
| Natural Gas Cost (\$/Therm) | \$ 0.90 |
| #2 Fuel Oil Cost (\$/gal) | \$ 1.55 |
| #4 Fuel Oil Cost (\$/gal) | \$ 1.37 |
| District Steam Cost (\$/Mlb) | \$ 24.03 |
| Air Cooled kW/Ton Penalty | 0.3 |
| Load Factor Decrease per 5 F | 0.08 |


| Installation Costs | |
|-----------------------|------------|
| Condensing Boiler | \$ 250,000 |
| Split System AC Units | \$ 200,000 |
| Primary HW Pump | \$ 2,000 |
| Maintenance Costs | |
| Condensing Boiler | \$ 16,657 |

| Auxiliary Equipment | |
|------------------------------------|-------|
| Condensing Boiler (MBH) | 3,331 |
| Condensing Boiler Efficiency | 90% |
| Split System Condenser Fan Peak kW | 23.5 |
| Primary HW Pump Peak kW | 13.2 |
| Closed Loop Pump Peak kW | 12.1 |
| Open Loop Pump Peak kW | 17.7 |
| Standing Column Well Pump Peak kW | 39.4 |
| Heat Pump Efficiency (COP) | 4.5 |
| Heat Cooling Coincidence factor | 0.7 |
| Minimum Fan Speed | 20% |
| Minimum Pump Speed | 20% |

| VFD Efficiency | |
|----------------|------|
| 2% | 0.47 |
| 13% | 0.86 |
| 25% | 0.93 |
| 42% | 0.94 |
| 50% | 0.95 |
| 75% | 0.96 |
| 100% | 0.97 |

Appendix C: Master Table Building Sheet Sample

Appendix D: Sample Maps



74°20'0"W

74°0'0"W

73°40'0"W

EXPLANATION

Depth to water, in feet below land surface

- < 11
- 11 - 20
- 21 - 30
- 31 - 50
- 51 - 75
- 76 - 100
- 101 - 125
- 126 - 150
- 151 - 175
- 176 - 200
- >201



DRAFT --- DO NOT QUOTE OR DISTRIBUTE


DO NOT QUOTE OR DISTRIBUTE

40°45'0"N

40°30'0"N

40°45'0"N

Figure 2
USGS Preliminary Depth to Water Map
for Kings, Queens and Richmond
Counties, NY




Modified from Como and others, 2015 and Soren, 1988

74°20'0"W

74°0'0"W

73°40'0"W



Notes:
 Extent of Lloyd aquifer in NYC limited to color contoured areas.
Source/References:
 1) Depth to Lloyd contours modified from on-line USGS GIS data (relative to ft below surface grade)
 2) Reference: USGS Hydrogeologic Investigations Atlas HA-709, Smolensky et al, 1989.
 3) Ground Surface Elevation from USGS National MapViewer (relative to NGVD 1929)


| | |
|----------------------------|------------------|
| | Borough Boundary |
| Depth to Lloyd (ft) | |
| | < 100 |
| | 100 - 200 |
| | 200 - 300 |
| | 300 - 400 |
| | 400 - 500 |
| | 500 - 600 |
| | > 600 |

Document Path: G:\Projects\E-L\GOC1601\mapfiles\Figures\Depth_Lloyd.mxd


P.W. GROSSER CONSULTING, INC.
 630 Johnson Avenue, Suite 7
 Bohemia, NY 11716-2618
 Phone: (631) 589-6353 • Fax: (631) 589-8705
 E-mail: INFO@PWGROSSER.COM

ESTIMATED DEPTH TO THE TOP OF THE LLOYD AQUIFER IN KINGS AND QUEENS COUNTIES, NY

Five Boroughs of New York City






| | |
|--------------|-----------|
| Project: | GOC1601 |
| Date: | 5/31/2017 |
| Designed by: | BB |
| Drawn by: | TS |
| Approved by: | JR |
| Figure No: | 3 |



Notes:
 Closed loops are technically feasible everywhere. Depths restricted where Lloyd aquifer exists and is less than 500 ft deep. Integrated by PWGC into GIS database.

Source/References:
 1) Extent of Lloyd aquifer lying less than 500 ft deep from on-line USGS GIS data.
 2) Reference: USGS Hydrogeologic Investigations Atlas HA-709, Smolensky et al, 1989.
 3) See Figure 1 for reference.

| | |
|---|------------------|
|  | Lloyd <500 ft |
|  | Borough Boundary |
|  | Suitable |

Document Path: G:\Projects\E-L\GOC1601\mapfiles\Figures\Figures_C1.mxd




PWGC
 Strategic Environmental and Engineering Solutions

P.W. GROSSER CONSULTING, INC.


630 Johnson Avenue, Suite 7
 Bohemia, NY 11716-2618
 Phone: (631) 589-6353 Fax: (631) 589-8705
 E-mail: INFO@PWGROSSER.COM

GEOLOGIC AND TECHNICAL SUITABILITY - CLOSED LOOP

Five Boroughs of New York City



| | |
|--------------|-----------|
| Project: | GOC1601 |
| Date: | 5/31/2017 |
| Designed by: | BB |
| Drawn by: | TS |
| Approved by: | JR |
| Figure No: | 4 |



PWGC
 Strategic Environmental and Engineering Solutions

P. W. GROSSER CONSULTING, INC.

630 Johnson Avenue, Suite 7
 Bohemia - NY - 11716-2818
 Phone: (631) 569-8353 • Fax: (631) 569-8705
 E-mail: INFO@PWGROSSER.COM

UNAUTHORIZED ALTERATION OR ADDITION TO THIS
 DRAWING AND RELATED DOCUMENTS IS A VIOLATION
 OF SEC. 7209 OF THE N.Y. EDUCATION LAW

DRAWING PREPARED FOR:

| REVISION | DATE | INITIAL | COMMENTS |
|----------|------|---------|----------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |


DRAWING INFORMATION:

| | | | |
|----------|-----------|--------------|--|
| Project: | GOC1601 | Designed by: | |
| Date: | 5/31/2017 | Drawn by: | |
| Scale: | AS SHOWN | Approved by: | |




**GEOLOGIC AND TECHNICAL
 SUITABILITY - STANDING
 COLUMN WELLS**

Five Boroughs of
 New York City

FIGURE NO:
 5



Notes:
 Green areas have been mapped by USGS to be underlain by sand and gravel aquifers, manually integrated by PWGC into GIS from hard copy published reports.
Source/References:
 1) USGS Water-Supply Paper 2498, Buxton and Shernoff, 1998.
 2) USGS Water-Resources Investigations Report 87-4048, Soren, 1988.
 3) Water Power and Control Commission Bulletin GW-32, Perlmutter and Arnow, 1953.

| | |
|---|------------------|
|  | Suitable |
|  | Not Suitable |
|  | Borough Boundary |

Document Path: G:\Projects\E-L\GOC1601\mapfiles\Figures\Figs_OL.mxd



P.W. GROSSER CONSULTING, INC.
 630 Johnson Avenue, Suite 7
 Bohemia, NY 11716-2618
 Phone: (631) 589-6353 • Fax: (631) 589-8705
 E-mail: INFO@PWGROSSER.COM


GEOLOGIC SUITABILITY - OPEN LOOP

Five Boroughs of New York City







| | |
|--------------|-----------|
| Project: | GOC1601 |
| Date: | 5/31/2017 |
| Designed by: | BB |
| Drawn by: | TS |
| Approved by: | JR |
| Figure No: | 6 |

FIGURE 7 OPEN LOOP TECHNICAL SUITABILITY



LEGEND

-  SUPPLY WELL
-  RETURN WELL
-  MINIMUM OPEN OUTDOOR AREA REQUIRED FOR DRILL RIG ACCESS (AND FUTURE WELL MAINTENANCE)



| Open Loop - Technical Suitability | | | | | | |
|-----------------------------------|------------------------|------------|---------------------------------|------------------|---------------------------|-----------------------|
| Dominant Demand (tons) | Dominant Demand (kBtu) | Flow (gpm) | No. of Wells (@50-135 gpm cap.) | | Outdoor Area Minimum (sf) | Lot Area Minimum (sf) |
| | | | SW | RW | | |
| 0-25 | 0-300 | Up to 50 | 1 | 1 ⁽¹⁾ | 800 | 1,900 ⁽¹⁾ |
| 25-50 | 300-600 | 50 - 100 | 1 | 2 | 800 | 4,800 |
| 50-100 | 600-1,200 | 100-200 | 2 | 4 | 2,500 | 7,200 |
| 100-200 | 1,200-2,400 | 200 - 400 | 3 | 5 | 3,200 | 32,000 |
| >200 | >2,400 | > 400 | >3 | >5 | 4,000 | 54,600 |

NOTES:

(1) 0-300 kBtu Dominant Demand Lot Area Minimum is 1,900 sf to capture 20' x 100' lots, which constitute a high percentage of lot sizes throughout the city.