



# **Flushing Creek Combined Sewer Overflow Long Term Control Plan**

---

Public Meeting #2

Al Oerter Recreational Center

October 23, 2014

# Welcome & Introductions

Shane Ojar  
DEP


---

## Topic

- |   |  |
|---|--|
| 1 | Welcome and Introductions                    |
| 2 | Long Term Control Plan (LTCP) Process        |
| 3 | Waterbody/Watershed Characteristics          |
| 4 | Water Quality – Current Improvement Projects |
| 5 | Draft Alternatives for LTCP                  |
| 6 | Next Steps                                   |
| 7 | Discussion and Q&A Session                   |

1. Provide background and understanding of the Long Term Control Plan process for Flushing Creek
2. Provide summary of existing water quality improvement projects
3. Gather public input on draft alternatives

# Public Involvement and LTCP Process




# **Overview of Combined Sewer Overflow Long Term Control Plan Process**

Shane Ojar  
DEP

# What is a Combined Sewer Overflow?

➤ NYC's sewer system is approximately 60% **combined**, which means it is used to **convey both sanitary and storm flows**.

- Heavy rain and snow storms can lead to higher than normal flows in combined sewers.
- As it was designed to work, when the sewer system is at full capacity, a diluted mixture of rain water and sewage, also known as combined sewage, are released into local waterways. This is called a combined sewer overflow (CSO).
- CSOs become a concern when they occur too frequently or in large amounts. When they do, they can affect water quality and recreational uses in local waterways.



# What are Long Term Control Plans (LTCPs)?

- Required by state pollution control permits in accordance with the Clean Water Act (CWA) and Federal CSO Control Policy; an agreement between the State and City of New York establishes the time frame for submittal of 11 LTCPs.
- Assesses feasibility of attaining current water quality standards and fishable/swimmable standards.
- Comprehensive evaluation of alternatives to reduce CSOs and improve water quality in NYC's waterbodies.

1. Builds off of improvements in Waterbody/Watershed Facility Plans (WWFP);
2. Assess current waterbody and watershed characteristics;
3. Identifies and analyze grey-green\* infrastructure balance for different watersheds to meet applicable WQS; and
4. Select a preferred alternative based on a robust, targeted public process.


\*Green: sustainable pollution reducing practices that also provide other ecosystem services.

\*Grey: traditional practices such as pipes and sewers.

# **Waterbody & Watershed Characteristics**

Keith Beckmann, P.E.  
DEP

# Current Water Quality Standards



## ➤ Best Use Designations

## ➤ Saline Surface Water Quality Standards

## ➤ Flushing Creek– Class I

- DO ≥ 4.0 mg/L (acute, never less than)
- Fecal Coliform ≤ 2,000 col /100 mL
- Total Coliform ≤ 10,000 col /100 mL

New York State Saline Surface Water Quality Standards				
Class	Bacteria (when disinfection is practiced)			Dissolved Oxygen
	Total Coliform	Fecal Coliform	Enterococci	
SA	Median ≤ 70 MPN/100 ml	—	Geometric mean ≤ 35/100 ml	$DO_t = \frac{13.0}{2.80 + 1.84e^{-0.16}}$ ≥ 3.0 mg/l (acute, never less than)
SB	Monthly median ≤ 2,400/100 ml 80% ≤ 5,000/100 ml	Monthly geometric mean ≤ 200/100 ml	Geometric mean ≤ 35/100 ml	$DO_t = \frac{13.0}{2.80 + 1.84e^{-0.16}}$ ≥ 3.0 mg/l (acute, never less than)
SC	Monthly median ≤ 2,400/100 ml 80% ≤ 5,000/100 ml	Monthly geometric mean ≤ 200/100 ml	Geometric mean ≤ 35/100 ml	$DO_t = \frac{13.0}{2.80 + 1.84e^{-0.16}}$ ≥ 3.0 mg/l (acute, never less than)
I	Monthly geometric mean ≤ 10,000/100 ml	Monthly geometric mean ≤ 2,000/100 ml	—	≥ 4.0 mg/l (acute, never less than)
SD	—	—	—	≥ 3.0 mg/l (acute, never less than)

$DO_t$  = DO concentration in mg/l between 3.0 – 4.8 mg/l

# Designated & Recreational Uses


- New York State DEC classifies the best use of the creek as being suitable for secondary contact recreation and fishing.
- Current Water Uses:
  - No designated access for swimming
- All recreational uses identified by the public during Flushing Creek LTCP public meeting on June 11, 2014 are in Flushing Bay and Meadow Lake.



# Drainage Area Characteristics

Drainage Area	Area (Acres)
Combined Sewered	6,323
Separate/Direct Drainage	4,693
<b>Total watershed area</b>	<b>11,016</b>

- Within Tallman Island WWTP drainage area
- DEP wet weather outfalls include:
  - ▲ 3 CSO Outfalls
  - 5 Permitted Stormwater Outfalls



# Water Quality Sampling Data

- **LTCP Receiving Water Sampling**
  - November 2013 - May 2014
  - 18 dry weather and 60 wet weather samples per station
  - Fecal coliform and enterococci

## Geomean (Average) of LTCP Sampling Data


River Station	Enterococci (col/100ml)			Fecal Coliform (col/100ml)		
	Dry	Wet	All	Dry	Wet	All
<b>OW1</b>	32	51	44	130	131	131
<b>OW2</b>	20	99	61	100	433	278
<b>OW3</b>	61	863	468	327	3310	1940
<b>OW4</b>	23	494	232	119	2176	1063
<b>OW5</b>	20	497	223	112	1894	933
<b>OW6</b>	14	221	111	77	910	490

Additional DEP Water Sampling Programs:


- **Harbor Survey Monitoring**  
[http://www.nyc.gov/html/dep/html/harborwater/harbor\\_water\\_sampling\\_results.shtml](http://www.nyc.gov/html/dep/html/harborwater/harbor_water_sampling_results.shtml)
- **Sentinel Monitoring**



- Model runs are based on ten years of data (2002 – 2011) for pathogens; one year of data used for DO ( “typical year rainfall - 2008”)
- 2040 population projections
- Model is calibrated with Harbor Survey data plus LTCP synoptic sampling data



- Gap Analysis for Water Quality Standard Attainment
  - Calculate Bacteria and DO for Baseline conditions
    - Include WWFP grey infrastructure
    - Green Infrastructure (GI) as per NYC GI Plan
- Bacteria Source Component Analysis
  - CSO, stormwater, direct drainage, upstream rivers
- Matching CSO Scenarios to CSO Engineering Control Alternatives



# Current Improvement Projects

Flushing Creek CSO Retention Facility  
Increased Flow Conveyance to Tallman Island WWTP  
Area-wide GI Projects  
Planned On-site GI Projects  
Potential Area-wide GI Contracts

# Current Improvement Projects

**Upgrades to Increase Flow  
Conveyance to Tallman  
Island WWTP**  
Cost = \$41 million

**Planned On-site GI Projects:**  
● 185Q, Edward Bleeker Jr. High  
● Flushing Town Hall & JSH

**Area-wide GI Projects**  
■ TI-011  
■ TI-022  
Design Cost = \$3.5 million

■ **Flushing Creek CSO  
Retention Facility**  
Cost = \$349 million

■ **Potential Area-wide GI  
Contracts**




## ➤ Grey Infrastructure Projects

- Flushing Creek CSO Retention Facility – Cost \$349 million
  - ✓ Tank operational since May 2007
  - ✓ 43 MG Storage (28 MG tank storage plus 15 MG sewers storage); 40 MGD pump station
- Upgrades to Increase Flow Conveyance to Tallman Island WWTP – Cost \$41 million
  - ✓ New Whitestone Interceptor to come online Winter 2014

## ➤ Green Infrastructure Projects

- Area-wide GI Contracts – Cost \$3.5 million
  - ✓ TI11 and TI22 with NYC Department of Design and Construction
  - ✓ Design underway
- JHS 185Q, Edward Bleecker Jr. High
  - ✓ Rain garden and synthetic turf field for “Schoolyards to Playgrounds” project with Trust for Public Land/School Construction Authority/Dept. of Education
- Flushing Town Hall
  - ✓ Rain garden and swales with the Department of Cultural Affairs

# Modeling Pre-WWFP & LTCP Baseline\*



\*LTCP projections using 2008 Typical Rainfall Year, including 8% GI


# Overview of LTCP Targets

Target	Criteria	Dissolved Oxygen (DO) Criteria	Fecal Coliform Criteria	Enterococci Criteria
Existing Water Quality Criteria	Class I	<ul style="list-style-type: none"> <li>• <math>\geq 4.0</math> mg/L</li> </ul>	<ul style="list-style-type: none"> <li>• Monthly Geometric Mean <math>\leq 2,000</math> col/100 ml</li> </ul>	<ul style="list-style-type: none"> <li>• Not Applicable</li> </ul>
Potential Future Standard: Primary Contact	Class SC with RWQC (EPA Recommended Recreational Water Quality Criteria)	<ul style="list-style-type: none"> <li>• 4.8 mg/L Average</li> <li>• <math>\geq 3.0</math> mg/L</li> </ul>	<ul style="list-style-type: none"> <li>• Monthly Geometric Mean <math>\leq 200</math> col/100 ml</li> </ul>	<ul style="list-style-type: none"> <li>• Rolling 30-Day Geometric Mean 30 col/100 ml</li> <li>• STV (90<sup>th</sup> percentile value) 110 col/100 ml</li> <li>• Recreational Season</li> <li>• Potential 2015 Modification (RWQC)</li> </ul>

# Alternatives Evaluation

Keith Beckmann, P.E.  
DEP

# Flushing Creek CSO Mitigation Toolbox



**Note:** A joint Wetlands Restoration & Dredging project with the US Army Corp of Engineers (ACOE) is being coordinated outside of the LTCP framework.

## Insufficient Opportunity Available

- Additional GI
- Sewer Separation
- Floatables Control

## Limited Hydraulic Capacity

- Fixed Weirs

## Reliability Concerns

- Inflatable Dams

## Minimal CSO Impact Mitigation

- Interceptor Flow Regulation
- Aeration

## Effectiveness Comparison

- Storage Shafts, Tanks, Tunnels

## Concept:

- Disinfect CSO at Existing Tank's Screens
- Operate in recreational season (May – October)
- Install disinfection equipment at existing chemical storage location
- Treat flows discharged through outfall TI-010

## Benefits:

- 31% bacteria load reduction from baseline
- Maximizes use of existing infrastructure

## Water Quality Implications:

- Reduces bacteria loads from CSOs during recreational season

## Challenges:

- Coordination with on-site Parks Dept. operations
- Operation and maintenance of disinfection facilities
- Potential residual chlorine issues

**Capital and O&M Costs:** \$4.7 million

CSO Retention Tank is located underneath soccer Fields 9 & 8




Entrance Gate to the Screening Building



# Option 2 - Outfall Disinfection at Chamber 3 (TI-010)

## Concept

- Move dosing point from screens to upstream of Diversion Chamber 3
- Operate in recreational season (May – October)
- Increases amount of flow disinfected prior to discharge



## Benefits:


- Tank discharge and bypass flow disinfected
- Approximately 40% Recreational Season Bacteria load reduction in Flushing Creek from baseline
- Disinfection equipment can be installed at existing site

## Challenges:

- Design to achieve desired contact time
- Dosing point construction site across College Point Boulevard
- May require control structure at end of outfall
- Potential residual chlorine issues


## Capital and O&M Cost:

- \$5.8 Million



# Option 3 - Outfall Disinfection at Chamber 5 (TI-010)

- Move dosing upstream of Diversion Chamber 5
- Operate tank as offline storage under lower flows by raising the effluent weir slightly
- Disinfect majority of flows that bypass tank up to design flow rate



## Benefits:


- Disinfection of tank bypass flows
- 53% Recreational Season bacterial load reduction in Flushing Creek from baseline
- Does not chlorinate pump back volume, reducing chlorine use
- Disinfection Equipment Can Be Installed at Existing Site

## Challenges:

- Design disinfection system for 15 minutes of contact time
- May require control structure at end of outfall
- Possible floatables & residual chlorine issues

## Capital and O&M Cost (NPV):

- \$6 Million Capital



## Concept:

- CSO disinfection within existing TI-011 outfall
- Operate in recreational season (May – Oct.)
- New disinfection building on existing DEP site

## Benefits:

- 30% bacteria load reduction from baseline
- Maximizes use of existing infrastructure
- Utilizes gravity, no effluent pumping
- No construction of retention tank


## Water Quality Implications:

- Reduces bacteria load from CSO during recreational season

## Challenges:

- Operation and maintenance of disinfection facilities
- Potential residual chlorine issues

**Capital and O&M Cost:** \$9.2 million



# **Wetland Restoration Opportunities**

- Restore the natural state and functioning of the system to support **biodiversity** and **aesthetic improvements**.
- Expand **habitat** for diverse species (e.g. fish, aquatic insects, other wildlife).
- Enhance **water quality** and increased **dissolved oxygen** levels.
- Restoration activities may range from a **removal of fill** that inhibits natural hydrologic function, to **wetland planting** and upstream **constructed wetland**
- **Access**, **property ownership** issues and establishment of proper **elevation**.
- Projects should conduct **monitoring** of conditions after construction, to evaluate effectiveness. This may take considerable time therefore monitoring efforts should be conducted for **several years** after a project has completed.



## ➤ Protecting and improving water quality

- Wetlands are part of the solution in keeping with the spirit of the Clean Water Act (CWA)
- Provide critical functions:
  - Water storage
  - Water filtration
  - Reduction of Biological Oxygen Demand (BOD) for increased Dissolved Oxygen

## ➤ Providing habitat

- Biological productivity
  - Wetlands are one the most biologically productive natural ecosystems known, comparable to tropical rain forests in their productivity species diversity
  - 85% of waterfowl and migratory birds use wetlands

## ➤ Aesthetic value

- Open space
- Education
- Research

# Potential Wetland Restoration Opportunities



- Approximately 2 to 4 acres of additional wetland restoration are possible outside of USACE/DEP restoration/dredging coordination effort
- Approximate cost of restoration is \$850K per acre

## **Dredging and Environmental Restoration with US Army Corp of Engineers (USACE)**

### **Concept:**

- DEP is working with USACE on dredging and wetland restoration

### **Benefits:**

- May improve waterbody aesthetics

### **Water Quality Implications:**

- Reduce odor and aesthetic issues

### **Challenges:**

- Not a CSO reduction strategy
- Does not remove bacteria
- Coordination with ACOE
- Permitting

**Capital Cost: \$35 Million**



# Shortlisted Alternatives Costs

<b>LTCP Alternative</b>	<b>Recreational Season Bacteria Reduction</b>	<b>DO Improvement</b>	<b>High Level Cost (Millions)</b>
Option 1 Tank Disinfection	31%	No	\$5
Option 2 Outfall Disinfection at Diversion Chamber 3	40%	No	\$6
Option 3 Outfall Disinfection at Diversion Chamber 5	53%	No	\$6
TI-011 Outfall Disinfection	30%	No	\$9

<b>Outside LTCP w/ACOE</b>	<b>Recreational Season Bacteria Reduction</b>	<b>DO Improvement</b>	<b>High Level Cost (Millions)</b>
Wetland Restoration/Dredging	NA	Yes	\$35

- Flushing Creek's water quality is affected by CSOs.
- Both pathogens and dissolved oxygen must be considered.
- CSO reduction alternatives vary in size, effectiveness and cost.
- CSO reduction alternatives may be bundled together for further effectiveness
- Ratepayers may be directly impacted by the cost of planned CSO reduction alternatives.
- Submitted LTCP will propose a preferred alternative.

# Next Steps

Shane Ojar  
DEP

- To have public comments on alternatives incorporated into the LTCP, please send comments by November 17, 2014
- Comments can be submitted to:
  - New York City DEP at: [ltcp@dep.nyc.gov](mailto:ltcp@dep.nyc.gov)
- Flushing Creek LTCP Public Meeting #3
  - Objective & Topics: Present and review proposed Draft LTCP

- Visit the informational tables tonight for handouts and poster boards with detailed information
- Go to [www.nyc.gov/dep/ltcp](http://www.nyc.gov/dep/ltcp) to access:
  - LTCP Public Participation Plan
  - Presentation, handouts and poster boards from this meeting
  - Links to Waterbody/Watershed Facility Plans
  - CSO Order including LTCP Goal Statement
  - NYC's Green Infrastructure Plan
  - Green Infrastructure Pilots 2011 and 2012 Monitoring Results
  - Real-time waterbody advisories
  - Upcoming meeting announcements
  - Other LTCP updates

# Discussion and Q&A Session