

Cooling Tower Confirmatory Culture Results

The following list shows the culture test results of cooling towers that initially screened positive for *Legionella* bacteria with a PCR test. A PCR test determines whether live or dead *Legionella* bacteria is present in the cooling tower.

A culture test confirms if the cooling tower had live *Legionella* bacteria at the time the sample was taken. Only live *Legionella* bacteria can cause Legionnaires' disease and make people sick. A culture positive cooling tower may or may not be the source of *Legionella* bacteria exposure in the current cluster.

This list will be updated daily as culture tests are completed.

Culture Positive

Culture positive results indicate that there were live *Legionella* bacteria present at the time the building was sampled.

- 100 East End Avenue
- 180 East End Avenue
- 1381 Lexington Avenue
- 1486 Lexington Avenue *
- 1020 Park Avenue
- 1249 Park Avenue
- 1750 York Avenue
- 1660 Second Avenue
- 1438 Third Avenue
- 1551 Third Avenue
- 1001 Fifth Avenue
- 1080 Fifth Avenue
- 1045 Fifth Avenue *
- 1071 Fifth Avenue
- 135 E 79th Street
- 155 E 79th Street
- 300 E 79th Street
- 301 E 80th Street *
- 511 E 80th Street
- 238 E 81st Street

- 240 E 82nd Street
- 8 E 83rd Street
- 13 E 84th Street
- 145 E 84th Street
- 7 E 86th Street
- 120 E 87th Street
- 125 E 87th Street
- 501 E 87th Street
- 168 E 88th Street
- 410 E 92nd Street
- 200 E 95th Street
- 235 E 95th Street
- 115 E 97th Street *

* Tested PCR negative and culture positive. All have been remediated.

Culture Negative

Culture negative results indicate that no live *Legionella* bacteria were present.

- 117 E 85th Street
- 160 E 88th Street

Test Results Pending

- 60 East End Avenue
- 80 East End Avenue
- 90 East End Avenue
- 1157 Lexington Avenue
- 1025 Madison Avenue
- 1150 Madison Avenue
- 1239 Madison Avenue
- 1275 Madison Avenue
- 920 Park Avenue
- 1520 York Avenue
- 1755 York Avenue
- 1513 First Avenue

- 1875 Second Avenue
- 980 Fifth Avenue
- 1000 Fifth Avenue
- 1110 Fifth Avenue
- 1511 Third Avenue
- 1130 Fifth Avenue
- 153 E 78th Street
- 188 E 78th Street
- 200 E 78th Street
- 124 E 79th Street
- 201 E 79th Street
- 211 E 79th Street
- 40 E 80th Street
- 444 E 82nd Street
- 25 E 83rd Street
- 300 E 83rd Street (unregistered cooling tower, tested PCR negative)
- 500 E 83rd Street
- 40 E 84th Street
- 160 E 84th Street
- 114 E 85th Street
- 401 E 86th Street
- 444 E 86th Street
- 445 E 86th Street
- 51 E 87th Street
- 152 E 87th Street
- 401 E 88th Street
- 108 E 89th Street
- 9 E 90th Street
- 22 E 91st Street
- 333 E 91st Street
- 354 E 91st Street
- 40 E 94th Street
- 312 E 95th Street